

THERMAL-HYDRAULIC ANALYSIS OF A SPECTRAL
SHIFT REACTOR CORE

by

Brian Damiano

Thesis submitted to the Faculty of the
Virginia Polytechnic Institute and State University
in partial fulfillment of the
requirements for the degree of
MASTER OF SCIENCE
in
Nuclear Science and Engineering

APPROVED:

Milton C. Edlund, Chairman

Ronald J. Onega

James R. Thomas

December 1982

Blacksburg, Virginia

ACKNOWLEDGEMENTS

I would like to thank the Mechanical Engineering Department of VPI&SU for providing me with an assistantship during my graduate studies. I would also like to thank Dr. Milton C. Edlund for serving as my major professor and Professors Ronald J. Onega and James R. Thomas for being on my advisory committee.

I am deeply indebted to the Nu Prime Chapter of the Kappa Sigma Fraternity for the fellowship and brotherhood I have shared during the past four years. Finally, I want to acknowledge my family for their love and support.

TABLE OF CONTENTS

	<u>Page</u>
Acknowledgements	ii
List of Figures	v
List of Tables	vi
Chapter 1. Introduction	1
Chapter 2. Reactor Core Description	4
2.1 Design Considerations	4
2.2 Fuel Assembly Description	5
2.3 Core Description	11
Chapter 3. Thermal-Hydraulic Analysis	14
3.1 General Description of the Thermal-Hydraulic Analysis	14
3.2 General Heat Balance Description	15
3.3 Edge Channel Heat Balance	23
3.4 Description of the Finite Difference Equations	27
Chapter 4. The Thermal-Hydraulic Computer Program	32
4.1 General Program Description	32
4.2 Assignment of Coolant Channel Parameters	33
4.3 Calculation of Coolant Properties	37
Chapter 5. Test Case Results	39
5.1 Test Case Procedure	39
5.2 Test Case 1	40
5.3 Test Case 2	40
5.4 Test Case 3	41

	<u>Page</u>
5.5 Summary and Discussion of Results	41
Chapter 6. Conclusions and Recommendations	52
References	54
Appendix A. Program Flow Chart	55
Appendix B. Program Listing	65
Appendix C. Program Input and Output	147
Appendix D. Program Output for Test Case 1	152
Vita	171

LIST OF FIGURES

	<u>Page</u>
2.1 Fuel Assembly Cross Section	6
2.2 Detailed Cross Section of Fuel Assembly	7
2.3 Conceptual Reactor Core Cross Section	12
3.1 Coolant Channel Types	17
3.2 Finite Difference Equation Parameters	30
4.1 Fuel Rod Number Assignment	34
4.2 Coolant Channel Numbers	35
5.1 Fuel Assembly Pressure Drop	49
5.2 Fuel Assembly Enthalpy Increase	50

LIST OF TABLES

	<u>Page</u>
2.1 Geometric Details of Fuel Assemblies	8
2.2 Fuel Assembly Fuel to Water Ratios	10
2.3 Core Parameters	13
3.1 Recommended Constants for the Burnout Heat Flux Correlation	24
5.1a Results From Test Case 1 (English Units)	42
5.1b Results From Test Case 1 (Metric Units)	43
5.2a Results From Test Case 2 (English Units)	44
5.2b Results From Test Case 2 (Metric Units)	45
5.3a Results From Test Case 3 (English Units)	46
5.3b Results From Test Case 3 (Metric Units)	47
C-1 Fuel to Water Ratio Input Parameters	150
C-2 Program Input Parameters	151

CHAPTER 1

INTRODUCTION

Improved utilization of our uranium resources is needed due to the limited supply of economically recoverable uranium. The demand for uranium ore could be greatly reduced by using the uranium-plutonium fuel cycle more efficiently. One alternative to present pressurized water reactors (PWR's) which offers improved fuel cycle utilization is the spectral shift reactor. Spectral shift reactors are fission reactors in which long term reactivity is controlled by changing (shifting) the average energy of the neutron spectrum.

In close-packed fuel rod lattices using low-enriched uranium fuel, the reactivity is inversely proportional to the average energy of the neutron spectrum [1]. Shifting the neutron spectrum to higher energies increases the neutron flux in the resonance energy region. Consequently, the resonance absorption in fertile material is also increased. The reactivity decreases because the absorption cross-section of fertile material is higher than the absorption cross-section of fuel at resonance energies.

The neutron energy spectrum may be shifted by changing the fuel to water ratio (FTWR) of the fuel rod lattice. Increasing the FTWR reduces the amount of moderator in the fuel rod lattice, shifts the neutron spectrum to higher energies, and reduces the reactivity. Conversely, lowering the FTWR increases the amount of moderator in the fuel rod lattice, shifts the neutron spectrum to lower energies, and increases

the reactivity. The FTWR may be adjusted by placing blank zirconium rods in the fuel lattice. Removing the blank rods increases the water volume in the lattice, lowering the FTWR. This method of changing the FTWR to shift the neutron spectrum over the core lifetime is called mechanical spectral shift control.

The major advantages of spectral shift reactors over PWR's are a greater conversion ratio and a longer core lifetime. Previous work has shown that the conversion ratio and core lifetime are increased if the neutron energy spectrum is epithermal at the beginning of the core life and is thermalized as the core ages [1]. It has been estimated that conversion ratios of approximately 0.9 and fuel burnups of 42,000 MWD/MT can be obtained using plutonium recycle fuel in a close-packed lattice [2]. A computer code, RFD-1, has been developed recently to calculate criticality and fuel depletion for reactor cores using mechanical spectral shift. Preliminary results using RFD-1 indicate that higher fuel burnups and greater conversion ratios (compared to PWR's) are characteristics of spectral shift reactors [3].

This thesis presents a thermal-hydraulic analysis of a conceptual mechanical spectral shift reactor core. The conceptual reactor core used in the analysis has a tighter fuel lattice than a standard PWR core. The FTWR can be changed from 1.25 to 0.75 during the core lifetime by removing blank rods from the core. Each fuel assembly is enclosed by a hexagonal can and the coolant flowrate through each fuel assembly can be independently selected. The thermal-hydraulics of tight fuel rod lattices have been studied previously and it has been concluded

that these lattices meet Nuclear Regulatory Commission thermal-hydraulic guidelines [2, 4]. The ability to handle the varying FTWR's of reactor cores that use mechanical spectral shift is the unique feature of this thermal-hydraulic analysis.

The work described in this thesis had three objectives. The first objective was to create a computer code which performs a thermal-hydraulic analysis of reactors that use mechanical spectral shift. This code should be useful during future designs of such reactors. The second objective was to find if the enthalpy increase through each fuel assembly could be made equal by varying the coolant flowrate through each fuel assembly. The third objective was to determine the effect of different FTWR's on the coolant properties at the reactor coolant outlet. The work performed to accomplish these objectives has four main elements. The conceptual reactor core design was developed first. Once the reactor core and fuel assembly design were known, the thermal-hydraulic analysis computer program was written. Sample cases were analyzed by the computer program and conclusions and recommendations were formed based on the sample case results.

CHAPTER 2

REACTOR CORE DESCRIPTION

2.1 Design Considerations

The conceptual design of the reactor core used in the thermal-hydraulic analysis is based on the following design considerations:

- 1) The reactor core should be cylindrical, with approximately the same dimensions as a PWR core.
- 2) The FTWR should range from at least 1.25 to no more than 0.75.
- 3) Each fuel assembly is to be enclosed in a hex can. The coolant flowrate through each fuel assembly is to be determined by an orifice at the coolant inlet.
- 4) Conventional fuel rods should be used. The outside and inside diameters were given to be 0.38 in (0.0097 m) and 0.33 in (0.0084 m) respectively.
- 5) The minimum fuel rod spacing is set at 0.07 in (0.0018 m).
- 6) The fuel rods should be in a hexagonal lattice and should be separated by helical wire wraps.

The selection of sizes for each component was based solely on geometrical considerations. Thermal expansion, stress, and vibration were not considered. Since this is a conceptual design intended only for thermal-hydraulic analysis, no provisions have been made for control rods or instrumentation. Local variations of neutron flux, such as thermal flux peaking, have also been neglected.

2.2 Fuel Assembly Description

The fuel assembly design used in this analysis is shown in Figs. 2.1 and 2.2. Geometric details of the fuel assembly are listed in Table 2.1.

The fuel assembly consists of a lattice of fuel rods which surround seven blank, or void, rods. The void rods are separated from the reactor coolant by a stainless steel void wall. The entire fueled region of each fuel assembly is surrounded by a similar void wall. Six blank, or void, plates are located between the outer void wall and the stainless steel hex can.

The fuel rods use uranium dioxide fuel pellets encased in zirc-alloy cladding. The fuel rods are arranged in a hexagonal lattice with a 0.08 in (0.0020 m) spacing between fuel rods. A 0.08 in (0.0020 m) wire wrap spacer with an axial lead of 9 in (0.220 m) is wound around each fuel rod.

The void rods and void plates are used to vary the FTWR of the fuel assembly. By removing void rods or void plates, more core volume is occupied by moderator, reducing the FTWR. Void rods are used for fine adjustment of the FTWR. Void plates, being larger, are used to obtain medium and low FTWR's.

Seven void rods are placed symmetrically within each fuel assembly. The void rod shape was chosen so the void rod would fit easily into the fuel rod lattice.

Short and long void plates occupy opposite corners of the fuel assembly. The dimensions of the two different void plates were selected




Figure 2.1 Fuel Assembly Cross Section




Figure 2.2 Detailed Cross Section of Fuel Assembly

Table 2.1 Geometric Details of Fuel Assemblies

Number of Fuel Rods	369
Number of Void Rods	7
Number of Shord Void Plates	3
Number of Long Void Plates	3
Fuel Assembly Height	120. in (3.05 m)
Dimension of One Side of the Fuel Assembly	6.07 in (0.154 m)
Fuel Rod Outside Diameter	0.38 in (0.0097 m)
Fuel Rod Inside Diameter	0.33 in (0.0084 m)
Fuel Rod Lattice Pitch	0.46 in (0.0117 m)
Wire Wrap Axial Lead	9.0 in (0.227 m)
Reactor Coolant Flow Area	25.02 in ² (0.0161 m ²)
Short Void Plate Length (Including Corner)	3.75 in (0.0953 m)
Long Void Plate Length (Including Corner)	7.14 in (0.181 m)
Void Plate Thickness	0.4 in (0.0102 m)
Void Rod Cross Sectional Area	0.45 in ² (0.00029 m ²)
Short Void Plate Cross Sectional Area	1.61 in ² (0.00104 m ²)
Long Void Plate Cross Sectional Area	2.96 in ² (0.00191 m ²)
Void Wall Thickness	0.025 in (0.00064 m)
Hex Can Thickness	0.1 in (0.0025 m)
Range of Fuel to Water Ratio	1.25 - 0.75

so the short void plates would provide moderate changes in the FTWR while the long void plates would provide large FTWR changes.

The void walls perform three functions. The void walls are guide tubes during the removal or insertion of void rods or void plates. After a void rod or void plate has been removed, the moderator which replaces the void rod or void plate is separated from the reactor coolant by the void walls. This allows the flowrate through the spaces enclosed by void walls, the void regions, to be independently selected. Finally, the void walls prevent the fuel rod lattice from being disturbed by the insertion or removal of void rods or void plates. The void walls are shaped to be geometrically identical to the fuel rods that would occupy the void wall positions if the fuel rod lattice was undisturbed.

The FTWR of the fuel assembly can be varied from 1.25 to 0.75. Table 2.2 shows recommended combinations of void rods and void plates which, when removed, give the indicated FTWR. The recommended combinations have three important features:

- 1) The recommended combinations of void rods and void plates give relatively uniform FTWR decrements.
- 2) Each combination of void rods and void plates, when removed, leaves the fuel assembly in a symmetric geometric configuration.
- 3) The void rods and void plates are always removed in sets. This allows five control mechanisms to move all of the fuel assembly's void rods and void plates.

Table 2.2 Fuel Assembly Fuel to Water Ratios

Void Rods and Void Plates Removed From Fuel Assembly	FTWR
None	1.25
3 void rods	1.19
7 void rods	1.11
3 short void plates	1.05
3 short void plates and 3 void rods	1.00
3 short void plates and 7 void rods	0.95
3 long void plates and 3 void rods	0.89
3 long void plates and 7 void rods	0.85
All void plates and one void rod	0.80
All void plates and void rods	0.75

A hex can encloses the fuel rods, void rods, and void plates. The hex can prevents the mixing of coolant from adjacent fuel assemblies. Separate coolant flowrates through each fuel assembly allow reactor cores with non-uniform power densities to have a uniform coolant enthalpy increase through each fuel assembly. The coolant enters the fuel assembly at the bottom and exits at the top.

2.3 Core Description

The fuel assemblies can be combined to form a reactor core approximately the same size as a PWR core. The reactor core is hexagonal and is composed of 91 fuel assemblies. There are five different fuel enrichment zones. A cross-section of the reactor core, which shows the five fuel enrichment zones, is shown in Fig. 2.3. Important core parameters are listed in Table 2.3




Figure 2.3 Conceptual Reactor Core Cross-Section

Table 2.3 Core Parameters

Core Diameter	116 in (2.95 m)
Core Height	120 in (3.05 m)
Core Volume	593 ft ³ (16.81 m ³)
Number of Fuel Assemblies	91
Number of Fuel Rods	33,579
Number of Void Rods	637
Number of Short Void Plates	273
Number of Long Void Plates	273

CHAPTER 3

THERMAL-HYDRAULIC ANALYSIS

3.1 General Description of the Thermal-Hydraulic Analysis

A steady-state thermal-hydraulic analysis of the fuel assembly described in Chapter 2 is presented in this chapter. Each fuel assembly is analyzed separately since the coolant flowrate through each fuel assembly differs. The heat transfer between adjacent fuel assemblies is assumed to be negligible. The entering coolant pressure and bulk temperature and the power density as a function of position must be known to begin the analysis. The coolant properties are calculated for each fuel assembly height increment, Δz , beginning at the coolant inlet and ending at the coolant exit. The properties calculated for coolant leaving one height increment are used as the coolant input properties of the next height increment. The coolant bulk temperature, the coolant pressure, and the cladding temperature are calculated at each Δz for every coolant channel. Heat transfer coefficients on both sides of each void wall and the temperature of the moderator in the void regions are also calculated.

The thermal-hydraulic analysis for each fuel assembly height increment can be divided into two parts. In the first part of the analysis, a heat balance is performed on each coolant channel to estimate the channel pressures and temperatures. In the second part of the analysis, a finite difference equation which recalculates the incremental coolant exit temperature is written for each coolant channel. The

resulting set of equations is solved and a new set of incremental coolant channel exit temperatures is obtained. The heat balance is repeated using the new channel exit temperature estimates. The analysis of this fuel assembly height increment continues until the difference between successive incremental coolant channel exit temperature estimates is acceptable.

3.2 General Heat Balance Description

For each fuel assembly height increment, a heat balance is performed on each coolant channel. The heat balance estimates the coolant bulk temperature, the cladding temperature, and the coolant pressure. Additional parameters calculated are the rate heat is absorbed by each coolant channel, the burnout heat flux, the departure from nucleate boiling ratio (DNBR), and the cladding film heat transfer coefficient. Coolant channels next to void regions, edge channels, require additional analysis if the void regions do not contain void rods or void plates. The void wall temperature, the heat transfer coefficient on each side of the void wall, and the pressure and temperature of the moderator in the void region must be calculated. The calculation of these coolant channel and void region parameters is described below.

Since this is a steady-state thermal-hydraulic analysis, the rate heat is transferred into each coolant channel equals the sum of the heat generation rates in the fuel rods bordering the coolant channel. The heat absorbed by each coolant channel depends on the coolant channel type. Interior coolant channels, i.e. type one, are adjacent to three fuel rods. Since six coolant channels surround each fuel rod, a type

one coolant channel removes the heat generated in 3/6, or 1/2, of a fuel rod. Coolant channels next to the convex surface of a void wall, type two, are adjacent to two fuel rods and remove the heat generated in 1/3 of a fuel rod. Coolant channels next to the concave surface of a void wall, type three, are adjacent to one fuel rod and remove the heat generated in 1/6 of a fuel rod. Figure 3.1 shows the three coolant channel types.

The power density is the power generated per unit volume in the fuel assembly. The heat generation rate of a coolant channel is calculated by multiplying the power density by the fuel assembly volume associated with the coolant channel. The fuel assembly volume associated with a coolant channel is the sum of the coolant channel volume and the fuel rod volume that transfers heat into the coolant channel. The rate heat is transferred into a coolant channel is given by:

$$\Delta Q_{\text{gen}} = P_d (A_c + A_{\text{rod}} N/6) \Delta z \quad (3.1)$$

where ΔQ_{gen} is the rate heat is transferred into the coolant channel,

P_d is the power density,

A_c is the coolant channel cross-sectional area,

A_{rod} is the fuel rod cross sectional area, and

N is the number of fuel rods adjacent to the coolant channel.

The pressure drop through Δz is calculated using a pressure drop model developed by Novendstern [5]. Novendstern's model predicts the pressure drop through a hexagonal fuel rod lattice that uses wire wrap spacers. The coolant velocity through each coolant channel type is calculated using an empirical flow distribution factor. The coolant




Figure 3.1 Coolant Channel Types

velocities calculated using this flow distribution factor give equal pressure drops through each coolant channel type. The pressure drop is estimated by increasing the pressure drop calculated for a straight smooth tube with a hydraulic diameter equal to that of the coolant channel by an empirical correction factor.

If the average coolant velocity through the fuel assembly, V_{bar} , is known, the coolant velocity through coolant channel type i is calculated using:

$$V_i = X_i V_{\text{bar}} \quad (3.2)$$

where V_i is the coolant velocity of coolant channel type i , and

X_i is Novendstern's flow distribution factor for coolant channel type i .

The flow distribution factor depends on the number of channels, the cross sectional area, and the hydraulic diameter of each coolant channel type. The flow distribution factor is given by:

$$X_i = \frac{A_t}{\sum_j N_j A_j \left[\frac{D_{ej}}{D_{ei}} \right]^{0.714}} \quad (1 \leq i \leq j) \quad (3.3)$$

where A_t is the total coolant flow area in the fuel assembly,

A_j is the cross sectional area of coolant channel type j ,

N_j is the number of type j coolant channels in the fuel assembly,

and,

D_{ej} is the hydraulic diameter of coolant channel type j .

The coolant pressure drop through Δz is given by:

$$\Delta P = \frac{M f_{sm} \Delta z \rho_i V_i^2}{2 D_{ei} g} \quad (3.4)$$

where ΔP is the estimated pressure drop,

f_{sm} is the friction factor for a smooth pipe,

ρ is the coolant density,

g is the gravitational acceleration, and

M is Novendstern's pressure drop correction factor.

The pressure drop through Δz is greater than the pressure drop through a smooth tube of equal hydraulic diameter primarily because of the wire wrap spacer. The pressure drop correction factor depends on the coolant channel Reynolds number, Re , the pitch to fuel rod diameter ratio, and the ratio of the wire wrap axial lead, H , to the fuel rod diameter. The pressure drop correction factor is calculated using:

$$M = \frac{1.034}{(P_t/D)^{0.124}} + \frac{29.7(P_t/D)^{6.94} Re^{0.086}}{(H/D)^{2.239}} \quad (3.5)$$

where P_t is the pitch of the fuel rod lattice and

D is the fuel rod outside diameter [5].

If the rate heat enters the coolant channel and the coolant flow-rate are known, the temperature of the coolant leaving Δz can be estimated. The incremental coolant exit temperature is estimated by assuming all of the heat entering the coolant channel is used to increase the coolant enthalpy. Assuming the specific heat remains constant through Δz , the incremental exit coolant temperature is estimated using:

$$T_{ei} = \frac{\Delta Q_{gen}}{C_p M_{dot}} + T_{ii} \quad (3.6)$$

where T_{ei} is the coolant temperature leaving Δz ,

T_{ii} is the coolant temperature entering Δz ,

M_{dot} is the coolant channel flowrate, and

C_p is the coolant specific heat at constant pressure.

Since Δz is assumed to be small, a simple average of entering and exiting incremental coolant bulk temperature and pressure is used to calculate the average bulk temperature, T_B , and pressure, P , in Δz . The average pressure and bulk temperature are used to recalculate the coolant thermodynamic and transport properties in Δz .

The pressure drop through Δz is recalculated using the new coolant properties. If the recalculated pressure drop differs greatly from the previous pressure drop estimate, the coolant properties are recalculated and the pressure drop check is repeated. The estimate of the bulk coolant temperature is not checked or refined until the finite difference equations are solved.

The film heat transfer coefficient from the clad is calculated to estimate the cladding temperature. The Dittus-Boelter equation is used to calculate the film heat transfer coefficient [6]. This equation assumes the coolant flow is turbulent and is valid for the conceptual fuel assembly used in this study if the coolant flowrate is greater than 30,000 lbm/hr-ft² (408 kg/s-m²).

$$h_c = C \left(\frac{K}{De} \right) Re^m Pr^n \quad (3.7)$$

where h_c is the cladding heat transfer coefficient in $\text{BTU}/\text{ft}^2\text{-s-}^\circ\text{R}$,

K is the coolant thermal conductivity in $\text{BTU}/\text{ft-s-}^\circ\text{R}$,

Pr is the Prandtl number, and

C , m , and n are empirical constants.

Recommended values for m and n are 0.8 and 0.333 respectively [6]. The value of C depends on the volume fraction of coolant in the fuel rod lattice. The value of C is calculated using:

$$C = 0.0333 \left(\frac{V_w}{V_w + V_F} \right) + 0.0127 \quad (3.8)$$

where V_w is the coolant volume of the fuel lattice and

V_F is the fuel volume of the fuel lattice.

The cladding temperature, T_c , can be calculated since the average bulk coolant temperature, the rate heat enters the coolant channel, and the cladding heat transfer coefficient are known. The cladding temperature is estimated using:

$$T_c = \frac{\Delta Q_{gen}}{Nh_c A} + T_B \quad (3.9)$$

where A is the fuel rod surface area adjacent to the coolant channel.

The cladding temperature calculated by Eq. 3.9 assumes the coolant is not undergoing nucleate boiling. If nucleate boiling occurs, the cladding temperature is given by the Jens and Lottes correlation [7].

$$T_c = \frac{60(q''/10^6)^{0.25}}{e^{P/900}} + T_{sat} \quad (3.10)$$

where q'' is the cladding heat flux in $\text{BTU}/\text{hr-ft}^2$, and

T_{sat} is the coolant saturation temperature in °F based on coolant pressure.

The cladding temperature is calculated using both Eq. 3.9 and Eq. 3.10. The lower of the two calculated cladding temperatures is assumed to be the actual cladding temperature. If the cladding temperature calculated by Eq. 3.10 is the lower of the two cladding temperatures, it is assumed that nucleate boiling occurs.

The burnout heat flux, the heat flux at which departure from nucleate boiling occurs, is required to calculate the DNBR. The DNBR is defined as,

$$DNBR = \frac{Q_{BO}}{q''} \quad (3.11)$$

where Q_{BO} is the burnout heat flux.

To prevent departure from nucleate boiling, the minimum allowed DNBR for a PWR is 1.3 [6]. The burnout heat flux is calculated using a burnout heat flux correlation developed for low coolant fraction fuel rod lattices [2].

$$\frac{Q_{BO}}{10^6} = A1 \left(\frac{D_e G}{h_z - h_i} \right)^{A2} + A3 \left(\frac{D_e G}{h_z - h_i} \frac{\partial h}{\partial z} \right)^{A4} (A5(\Delta H_s) + \frac{\partial h_f}{\partial P}(2000-P)) \quad (3.12)$$

where G is the mass flux in lbm/hr-ft^2 ,

h_z is the coolant enthalpy in dz in BTU/lbm,

h_i is the coolant enthalpy at the fuel assembly inlet in BTU/lbm,

$\frac{\partial h}{\partial z}$ is the enthalpy gradient in dz in BTU/lbm-in,

ΔH_s is the subcooling at the fuel assembly inlet in BTU/lbm,

$\frac{\partial h_f}{\partial P}$ is the slope of the saturated liquid enthalpy curve in BTU/lbm-psi (a constant value of 0.123 is used), and

A1-A5 are empirical constants [2].

The recommended constants for Eq. 3.12 are listed in Table 3.1 [2]. Once the burnout heat flux for a coolant channel is known, the DNBR is calculated using Eq. 3.11.

3.3 Edge Channel Heat Balance

If a void rod or void plate is removed, the edge channels bordering the void wall will transfer heat to the moderator in the void region. The void wall temperature, the water temperature in the void region, and the heat transfer coefficient on each side of the void wall are calculated when a heat balance is performed across the void wall.

The void wall temperature is initially estimated to be the average of the coolant temperature entering Δz and the average coolant bulk temperature in Δz . The film temperature is calculated by averaging the void wall temperature and the average coolant bulk temperature.

The heat transfer coefficient at the void wall is calculated assuming the flow through the coolant channel is turbulent. Equation 3.13 is used to calculate the heat transfer coefficient at the void wall [8].

$$h_{wi} = \frac{f_{sm} \rho C_p V_i}{8 Pr} \quad (3.13)$$

where h_{wi} is the heat transfer coefficient on the fuel rod side of the void wall.

Table 3.1 Recommended Constants for the
Burnout Heat Flux Correlation

<u>Constant</u>	<u>Value</u>
A1	2.8591
A2	0.51796
A3	0.023018
A4	0.63960
A5	1.2614

This equation is based on the Reynolds analogy which relates the friction loss in tube flow to the heat transfer rate. In Eq. 3.13, the coolant density and specific heat are evaluated at the average coolant bulk temperature, while the Prandtl number is evaluated at the film temperature.

Knowing the average coolant bulk temperature, the void wall temperature, and the void wall heat transfer coefficient, the rate heat is transferred to the void wall can be calculated. For steady-state heat transfer, this will equal the heat absorbed by the moderator in the void region. The temperature across the void wall is assumed to be constant.

The temperature of the moderator in the void region is found by equating the enthalpy rise of the water in the void region to the heat transferred to the void wall surrounding the void region. The void water temperature leaving Δz is found using:

$$T_{vwe} = \frac{Q_i}{M_{dot} C_p} + T_{vwi} \quad (3.14)$$

where Q_i is the heat transferred to the void wall surrounding the void region,

M_{dot} is the mass flowrate of water through the void region,

T_{vwe} is the water temperature leaving Δz , and

T_{vwi} is the water temperature entering Δz .

The average temperature of the water in the void region, T_{vwb} , is calculated by averaging the water temperature entering and leaving the

void region. The film temperature is again found by averaging the void wall temperature and the average water temperature in the void region.

The pressure drop through the void region can be calculated knowing the average water temperature and the void region flowrate. The Reynolds number, based on the hydraulic diameter of the void space, is used to determine whether the flow through the void space is laminar or turbulent. If the Reynolds number is greater than 2400, turbulent flow is assumed and the pressure drop is calculated using [9]:

$$\Delta P_{vi} = \frac{f_{sm} \rho \Delta z V_{vi}^2}{2 D_{evi} g} \quad (3.15)$$

where ΔP_{vi} is the pressure drop of the void region,

V_{vi} is the fluid velocity in the void region, and

D_{evi} is the equivalent diameter of the void region.

Equation 3.15 assumes the void walls are smooth. If the Reynolds number is less than 2400, indicating laminar flow, the pressure drop is calculated using [9]:

$$\Delta P_{vi} = \frac{128u \Delta z \dot{M}_{doti}}{\rho \pi D_{evi}^3} \quad (3.16)$$

where u is the dynamic viscosity.

The heat transfer coefficient on the void region side of the void wall is found using Eq. 3.13 if the flow through the void region is turbulent. If laminar flow exists in the void region, the heat transfer coefficient is calculated using [8]:

$$h_{wo} = 4.364K/D_{evi} \quad (3.17)$$

where h_{wo} is the heat transfer coefficient on the void region side of the void wall.

This equation can be derived using the definition of the convection heat transfer coefficient, the definition of the bulk temperature, and the parabolic velocity distribution for laminar tube flow.

A heat balance across the void wall is used to check the void wall temperature assumption. The heat transferred from the void wall into the void region is calculated using the void wall temperature, the average temperature of the water in the void region, and the void wall heat transfer coefficient, h_{wo} . If the amount of heat being transferred into the void region does not equal the heat being transferred to the void wall, the void wall temperature assumption is changed. All of the quantities used to perform the heat balance across the void wall are recalculated and the heat balance is repeated. This procedure continues until the energy transferred from the coolant channels, the energy transferred into the void region, and the energy used to increase the enthalpy of the water flowing through the void region are equal.

3.4 Description of the Finite Difference Equations

After the heat balance is completed for each coolant channel in Δz , the estimated exit temperatures from Δz for each coolant channel are substituted into a set of finite difference equations. Coolant cross-flow between adjacent coolant channels and heat transfer to the void walls are used by the finite difference equations to refine the coolant channel exit temperature estimates.

Coolant cross-flow, coolant flow between adjacent coolant channels, makes the temperature of each coolant channel dependent on the temperatures of the adjacent coolant. With a wire wrap spacer is used to separate adjacent fuel rods, the majority of the coolant cross-flow is caused by flow sweeping, which occurs when the wire wrap spacer winds from one coolant channel into another [10]. Coolant follows the wire wrap, leaving one channel and entering another.

The equation used to predict the cross-flow caused by flow sweeping is [10]:

$$W_{ij} = \frac{\dot{M} \pi t P_t a_f}{H A_c} \quad (3.18)$$

where W_{ij} is the mass flowrate from channel i to channel j ,

t is the wire wrap diameter, and

a_f is the fraction of the total channel area that is free flow area.

The factor a_f is set equal to one by neglecting the coolant boundary layer thickness next to the fuel rod. The accuracy of Eq. 3.18 is questionable because it assumes that the cross-flow follows the wire wrap exactly and that only the coolant impinging on the wire wrap is swept out of the coolant channel. However, cross-flow due to flow sweeping is so large that relatively accurate bulk temperature estimates can be made even if the cross-flow is not predicted extremely accurately [10].

An energy balance can be performed on each coolant channel in Δz to form a set of finite difference equations. Figure 3.2 shows a

general coolant channel and illustrates the physical meaning of the terms used in the finite difference equations.

Energy enters channel i from the adjacent coolant channels by coolant cross-flow and from the adjacent fuel rods by convective heat transfer. Energy leaves channel i by convective heat transfer to the void wall and by coolant cross-flow to adjacent coolant channels. Some of the energy entering the coolant channel is used to increase the coolant enthalpy as it passes through Δz . Equating the energy flow into the coolant channel to the sum of the energy used to increase the coolant enthalpy and the energy flow out of the coolant channel gives:

$$\begin{aligned} \Delta Q_{\text{gen}} + \sum_j W_{ji} C_{pj} T_{Bj} &= \sum_j W_{ij} C_{pi} T_{Bi} + h_{wi} A_i (T_{Bi} - T_w) \\ &+ M_{\text{dot}} C_{pi} [T_{ei} - T_{ii}]. \end{aligned} \quad (3.19)$$

Replacing each average coolant bulk temperature with its definition and rearranging so the known and unknown variables appear on different sides of the equation results in the general finite difference equation:

$$A = B T_{ei} + \sum_j C_j T_{je}, \quad (3.20)$$

where

$$\begin{aligned} A = \Delta Q_{\text{gen}} + \sum_j \frac{W_{ji} C_{pj} T_{ji}}{2} + [M_{\text{dot}} C_{pi} - \frac{h_{wi} A_i}{2} - \sum_j \frac{W_{ij} C_{pi}}{2}] T_{ii} \\ + h_{wi} A_i T_w, \end{aligned} \quad (3.20a)$$

$$B = M_{\text{dot}} C_{pi} + \frac{h_{wi} A_i}{2} + \sum_j \frac{W_{ij} C_{pi}}{2}, \quad (3.20b)$$

$$\text{and } C = -W_{ji} C_{pi} / 2. \quad (3.20c)$$




Figure 3.2 Finite Difference Equation Parameters

The set of equations generated from Eq. 3.20 is solved for a new set of coolant channel exit temperatures. If the new coolant channel incremental exit temperature estimates differ greatly from the old estimates, the fuel assembly heat balance is repeated using the new coolant channel incremental exit temperature estimates. This procedure is repeated until the temperature estimates of successive iterations do not differ appreciably.

When the temperature estimates from two successive iterations through the heat balance-finite difference equation procedure are nearly identical, the thermal-hydraulic calculations for Δz are finished. The coolant bulk temperature and pressure, the cladding temperature, and the cladding film heat transfer coefficient are known for each coolant channel in Δz . For edge channels, the void wall temperature and the heat transfer coefficient on each side of the void wall are known. Finally, the temperature and pressure of the moderator in the void regions are known.

The thermal-hydraulic analysis is continued by incrementing the fuel assembly axial position and repeating the thermal-hydraulic analysis on a new Δz . The outlet coolant pressures and temperatures of the previous Δz are used as the inlet pressures and temperatures for the new Δz . The thermal-hydraulic analysis is repeated for fuel assembly height increments of Δz until the top of the fuel assembly is reached.

CHAPTER 4

THE THERMAL-HYDRAULIC COMPUTER PROGRAM

4.1 General Program Description

A digital computer was used to perform the thermal-hydraulic calculations presented in Chapter 3. The computer program can be divided into three parts:

- 1) The dimensional parameters of the coolant channels must be defined before the thermal-hydraulic analysis can be performed. For each coolant channel, the position, the dimensions, and the adjacent coolant channels are determined. Additional parameters defined for edge channels are the type of void region the channel borders and if heat is transferred through the void wall.
- 2) The thermodynamic and transport properties of water were calculated using the WASP steam table subprogram. This subprogram was chosen because it is accurate and easy to use.
- 3) The thermal-hydraulic calculations are the smallest of the three program sections. These calculations have already been described in Chapter 3.

The program segments are performed in the following order: After reading the input data, the dimensional parameters of each coolant channel are assigned. The FTWR is used to determine which void rods and void plates are removed and which edge channels transfer heat into the void regions. The thermal-hydraulic calculations follow. Beginning

at the coolant inlet, the various pressures and temperatures throughout the fuel assembly are calculated for height increments of Δz . WASP is called during these calculations to provide coolant thermodynamic properties. When the thermal-hydraulic calculations are finished, the average exit enthalpy is calculated and the program results are printed. A program flow chart is presented in Appendix A and Appendix B and contains the program listing.

4.2 Assignment of Coolant Channel Parameters

Before coolant channel dimensional parameters can be assigned, each coolant channel must be identified. A set of three integers is used to identify each coolant channel. These coolant channel identification numbers (CIDN) are assigned based on the position of the coolant channel.

Each coolant channel can be associated with a fuel rod. A coolant channel's fuel rod determines the first two integers of its CIDN. The first integer is the row number of the fuel rod. The fuel rods are numbered consecutively in each row to obtain the second integer. Figure 4.1 shows how the fuel rods are numbered. The position of the coolant channel relative to its associated fuel rod determines the third integer of the CIDN. Figure 4.2 shows how the six coolant channels surrounding each fuel rod are numbered.

In addition to identifying the coolant channel, the CIDN is used to find the position of the coolant channel relative to the center of the fuel assembly. Using the row number, the position in the row, and the fuel rod lattice pitch, the distance a fuel rod is from the fuel




Figure 4.1 Fuel Rod Number Assignment




Figure 4.2 Coolant Channel Numbers

assembly center can be calculated. If the distance from the fuel assembly center to the reactor core centerline is known, the position of each fuel rod relative to the core centerline can be calculated. This distance must be known if any quantity used in the thermal-hydraulic analysis is radially space-dependent.

The coolant channel dimension, hydraulic diameter, cross sectional area, and the number of adjacent cooling channels depend on the coolant channel type. The coolant channel type also specifies whether a channel is an interior or an edge channel. The three types of coolant channels are shown in Fig. 3.1.

The coolant channel type is specified by the channel type number. The channel type number is a subscripted integer variable that is assigned a value of one, two, or three depending on whether a coolant channel is a type one, a type two, or a type three coolant channel. The channel type number also prevents a coolant channel from using more than one CIDN. Any of the fuel rods that border a coolant channel can be selected as the fuel rod associated with that coolant channel. After a coolant channel has been associated with a fuel rod and its CIDN assigned, any other CIDN that identifies the same channel is assigned a channel type number of four. Coolant channel identification numbers that have channel type numbers of four are ignored during the thermal-hydraulic analysis.

One set of three subscripted integer variables is used to specify each adjacent coolant channel. Each integer variable in a set equals one of the integers comprising the CIDN of an adjacent coolant channel.

The CIDN of the adjacent coolant channels are reconstructed from these sets of subscripted integer variables.

The parameters described above are defined for every coolant channel in the fuel assembly. Edge channels have two additional parameters. These parameters define the void region bordering the coolant channel and determine if heat is being transferred into that void region.

The type of void region adjacent to an edge channel, either a void rod, a short void plate, or a long void plate, is specified by another subscripted integer variable. This variable has a value of one if the adjacent void region is a short void plate, two if the adjacent void region is a long void plate, and three if the adjacent void region is a void rod.

The FTWR determines which edge channels border void regions containing water. The void wall heat transfer coefficient of these coolant channels is set equal to negative one. The void wall heat transfer coefficient of the remaining edge channels is set equal to zero. Negative void wall heat transfer coefficients are replaced during the thermal-hydraulic analysis.

4.3 Calculation of Coolant Properties

The WASP steam table subprogram is used to calculate the cooling water thermodynamic and transport properties. To calculate these properties, WASP uses an equation developed by Keyes, Keenan, Hill, and Moore which is valid from the triple point to a pressure of 14,500 psi (100 MPa) and to a temperature of 3150 F (1750 K) [11]. WASP calculates

any combination of temperature, pressure, density, entropy, enthalpy, specific heat at constant pressure, specific heat at constant volume, viscosity, sonic velocity, thermal conductivity, surface tension, and the Laplace constant, given any two of the variables temperature, pressure, and density. A complete explanation of WASP and its use may be found in reference 11.

The input parameters to WASP were assigned so the properties of saturated water were calculated using the water temperature and pressure as input properties. The properties calculated were the density, the viscosity, the thermal conductivity, and the specific heat at constant pressure.

The number of times WASP is called to calculate coolant properties is considerably fewer than the flow chart in Appendix A indicates. The program is written so WASP is not called unless the temperature difference between the present and the previous input temperatures is greater than 20°F (11°C). This reduces the program execution time considerably. The results of the thermal-hydraulic calculations are not significantly affected by this change because the properties calculated by WASP do not change greatly over a temperature range of 20°F (11°C).

CHAPTER 5
TEST CASE RESULTS

5.1 Test Case Procedure

The results from three test cases are used to determine the thermal-hydraulic characteristics of the reactor core presented in Chapter 2. The test case results are used to draw conclusions about the particular core used in the analysis and about mechanical spectral shift reactor cores in general. Each test case consisted of analyzing one fuel assembly from each of the five fuel enrichment zones. For each fuel assembly, the coolant flowrate, the inlet pressure, the outlet pressure, and the enthalpy gain through the fuel assembly were determined.

For each test case, equal coolant enthalpy gains through the fuel assemblies were obtained by adjusting the coolant flowrates. The inlet pressure of the fuel assemblies was selected so the fuel assembly outlet pressures were equal. Each test case was analyzed using FTWR's of 1.25, 0.95, and 0.75 to find how changing the FTWR affects the coolant outlet conditions. The flowrates through the void regions were selected to be 18 lbm/hr (0.002 Kg/s).

The following procedure was used to analyze each test case:

- 1) The average power density in each of the five fuel enrichment zones was determined using the computer code, RFD-1.
- 2) The coolant flowrate through each fuel assembly was adjusted until the desired enthalpy gain was achieved. By selecting

the coolant flowrates, the pressure drop through each fuel assembly is specified.

- 3) The core pressure drop equals the pressure drop through the fuel assembly with the greatest power density and flowrate. The inlet pressures of the remaining fuel assemblies were selected so the calculated outlet pressures of all the fuel assemblies are equal.

5.2 Test Case 1

The first test case uses U-235 fuel enrichments of 2.7%, 2.2%, 2.0%, 1.8%, and 1.6%. The fuel distribution selected has the greatest enrichment in the central fuel enrichment zone with each subsequent enrichment zone being less highly enriched. This fuel distribution produces a high power density in the core center and a low power density at the core edge. The power density ranges from 16,030 BTU/s-ft³ (597 W/cm³) to 258 BTU/s-ft³ (9.6 W/cm³). The reactor power is 1800 MW_{th}. The input data and the thermal-hydraulic results are shown in Table 5.1. The program printout for a FTWR of 0.95 and a fuel enrichment of 2.7% is presented in Appendix D.

5.3 Test Case 2

The second test case uses a U-235 enrichment of 2.1% in each fuel enrichment zone. The power densities range from 4,530 BTU/s-ft³ (169 W/cm³) in the central enrichment zone to 1,320 BTU/s-ft³ (49.2 W/cm³) in the outer enrichment zone. The reactor power is 1800 MW_{th}. Table

5.2 contains the input data and the results of the thermal-hydraulic analysis.

5.4 Test Case 3

The third test case uses low fuel enrichments at the core center and higher fuel enrichments at the core edge. The fuel enrichments used are 1.6%, 1.8%, 2.0%, 2.2%, and 2.7% U-235. The power density ranges from 3330 BTU/s-ft^3 (124 W/cm^3) in the outer enrichment zone to 497 BTU/s-ft^3 (18.5 W/cm^3) in the central enrichment zone. Again, the reactor power is $1800 \text{ MW}_{\text{th}}$. The results of the thermal-hydraulic analysis and the input data are presented in Table 5.3.

5.5 Summary and Discussion of Results

The test case results show that the fuel assembly enthalpy gains can be equalized by adjusting the coolant flowrate through each fuel assembly. The results also show that changing the FTWR does affect the coolant outlet conditions. Some thermal-hydraulic characteristics of the fuel assembly used for the test cases can be determined from the results.

To achieve a given enthalpy increase through a reactor core, a wider variety of fuel distributions may be used if the coolant flowrates can be varied through each fuel assembly. The flowrate through each fuel assembly may be chosen so the average enthalpy gain through the core equals the enthalpy gain through each fuel assembly. The results show that this can be done even for fuel distributions producing a wide range of power densities. This results in a large average

Table 5.1a Results From Test Case One (English Units)

Fuel Enrichment Zone	1	2	3	4	5
Fuel Enrichment (% U-235)	2.7	2.2	2.0	1.8	1.6
Power Density (BTU/s-ft ³)	16,030.	7,870.	3,030.	960.	260.
Coolant Flowrate (lbm/hr-ft ² -10 ⁶)	13.8	6.79	2.62	0.83	0.22
Inlet Pressure (psia)	2,400.	2,143.7	2,066.3	2,051.7	2,049.9
Outlet Pressure (psia)	2,049.7	2,049.7	2,049.7	2,049.7	2,049.7
Pressure Drop (psi)	350.3	94.2	16.6	2.08	0.18
Enthalpy Gain for a FTWR of 1.25 (BTU/lbm)	120.5	120.4	119.8	119.9	127.0
Enthalpy Gain for a FTWR of 0.95 (BTU/lbm)	120.5	120.3	119.7	119.8	119.6
Enthalpy Gain for a FTWR of 0.75 (BTU/lbm)	120.4	120.2	118.5	119.7	120.1

Table 5.1b Results From Test Case One (Metric Units)

Fuel Enrichment Zone	1	2	3	4	5
Fuel Enrichment (% U-235)	2.7	2.2	2.0	1.8	1.6
Power Density ($W/m^3 \cdot 10^6$)	597.	293.	113.	35.8	9.7
Coolant Flowrate ($kg/s \cdot m^2$)	18,750.	9,228.	3,561.	1,128.	299.
Inlet Pressure (kPa)	16,540.	14,770.	14,240.	14,140.	14,125.
Outlet Pressure (kPa)	14,120.	14,120.	14,120.	14,120.	14,120.
Pressure Drop (kPa)	2,420.	650.	120.	20.	5.
Enthalpy Gain for a FTWR of 1.25 (KJ/Kg)	280.3	280.0	278.6	278.9	295.4
Enthalpy Gain for a FTWR of 0.95 (KJ/Kg)	280.3	279.8	278.4	278.6	278.2
Enthalpy Gain for a FTWR of 0.75 (KJ/Kg)	280.0	279.6	275.6	278.4	279.4

Table 5.2a Results From Test Cast Two (English Units)

Fuel Enrichment Zone	1	2	3	4	5
Fuel Enrichment (% U-235)	2.1	2.1	2.1	2.1	2.1
Power Density (BTU/s-ft ³)	4530.	4130.	3380.	2390.	1321.
Coolant Flowrate (lbm/hr-ft ² -10 ⁶)	3.93	3.58	2.93	2.07	1.15
Inlet Pressure (psia)	2200.	2194.6	2185.7	2176.2	2169.0
Outlet Pressure (psia)	2165.3	2165.3	2165.3	2165.3	2165.3
Pressure Drop (psi)	34.7	29.3	20.4	10.9	3.7
Enthalpy Gain for a FTWR of 1.25 (BTU/lbm)	118.8	118.8	118.7	118.6	119.6
Enthalpy Gain for a FTWR of 0.95 (BTU/lbm)	118.8	118.7	118.6	118.5	119.4
Enthalpy Gain for a FTWR of 0.75 (BTU/lbm)	116.6	116.6	116.5	116.3	116.0

Table 5.2b Results From Test Case Two (Metric Units)

Fuel Enrichment Zone	1	2	3	4	5
Fuel Enrichment (% U-235)	2.1	2.1	2.1	2.1	2.1
Power Density ($W/m^3 \cdot 10^6$)	168.7	153.8	125.9	89.0	49.2
Coolant Flowrate ($Kg/s \cdot m^2$)	5,340.	4,865.	3,982.	2,810.	1,563.
Inlet Pressure (kPa)	15,160.	15,120.	15,060.	14,990.	14,940.
Outlet Pressure (kPa)	14,920.	14,920.	14,920.	14,920.	14,920.
Pressure Drop (kPa)	240.	200.	140.	70.	20.
Enthalpy Gain for a FTWR of 1.25 (KJ/Kg)	276.3	276.3	276.1	275.9	278.2
Enthalpy Gain for a FTWR of 0.95 (KJ/Kg)	276.3	276.1	275.9	275.6	277.7
Enthalpy Gain for a FTWR of 0.75 (KJ/Kg)	271.2	271.2	271.0	270.3	269.8

Table 5.3a Results From Test Case Three (English Units)

Fuel Enrichment Zone	1	2	3	4	5
Fuel Enrichment (% U-235)	1.6	1.8	2.0	2.2	2.7
Power Density (BTU/s-ft ³)	500.	880.	1710.	2820.	3330.
Coolant Flowrate (lbm/hr-ft ² -10 ⁶)	0.43	0.77	1.48	2.44	2.89
Inlet Pressure (psia)	2181.0	2182.1	2186.2	2194.9	2200.
Outlet Pressure (psia)	2180.3	2180.3	2180.3	2180.3	2180.3
Pressure Drop (psi)	0.7	1.8	5.9	14.6	19.7
Enthalpy Gain for a FTWR of 1.25 (BTU/lbm)	119.4	119.5	118.6	118.7	118.8
Enthalpy Gain for a FTWR of 0.95 (BTU/lbm)	118.1	119.1	118.4	118.6	118.7
Enthalpy Gain for a FTWR of 0.75 (BTU/lbm)	118.4	115.7	116.2	116.4	116.5

Table 5.3b Results From Test Case Three (Metric Units)

Fuel Enrichment Zone	1	2	3	4	5
Fuel Enrichment (% U-235)	1.6	1.8	2.0	2.2	2.7
Power Density ($W/m^3 \cdot 10^6$)	18.6	32.7	63.7	105.0	124.0
Coolant Flowrate ($Kg/s \cdot m^2$)	584.	1,046.	2,010.	3,316.	3,928.
Inlet Pressure (kPa)	15,030.	15,035.	15,060.	15,120.	15,160.
Outlet Pressure (kPa)	15,020.	15,020.	15,020.	15,020.	15,020.
Pressure Drop (kPa)	10.	15.	40.	100.	140.
Enthalpy Gain for a FTWR of 1.25 (KJ/Kg)	277.7	278.0	275.9	276.1	276.3
Enthalpy Gain for a FTWR of 0.95 (KJ/Kg)	274.7	277.0	275.4	275.9	276.1
Enthalpy Gain for a FTWR of 0.75 (KJ/Kg)	275.4	269.1	270.3	270.7	271.0

enthalpy gain through the core. To achieve a similar enthalpy gain, a reactor core in which the coolant mixes freely between fuel assemblies must use a fuel distribution with a relatively even power density.

Changing the FTWR does affect the outlet conditions of the coolant. The outlet enthalpy decreases by approximately 2.0 BTU/lbm (4.7 KJ/Kg) as the FTWR decrease from 1.25 to 0.75. This decrease is not surprising since the outlet temperature of the water in the void regions is considerably less than the reactor coolant outlet temperature. The change in the enthalpy gain as the FTWR varies increases as the coolant flowrate decreases. The change in the outlet enthalpy caused by varying the FTWR may be reduced if the flowrates through the void regions are reduced. The low exit temperature of the water in the void regions indicates that little heat is transferred into these regions.

The maximum fuel assembly power density increases as the variation between the fuel assembly power densities increases. To achieve an equal enthalpy increase through each fuel assembly, the coolant flowrate through each fuel assembly must be proportional to the fuel assembly power density. Since the maximum fuel assembly coolant flowrate determines the core pressure drop, the pressure drop increases as the variation between the fuel assembly power densities increases.

Some thermal-hydraulic characteristics of the fuel assembly used in the test cases are shown in Figs. 5.1 and 5.2. Figure 5.1 shows how the fuel assembly pressure drop varies with the coolant flowrate. Since the pressure drop depends on the square of the coolant velocity, the rapid increase of pressure drop with coolant flowrate is expected.




Figure 5.1 Fuel Assembly Pressure Drop




Figure 5.2 Fuel Assembly Enthalpy Increase

If an upper limit is placed on the allowed pressure drop, the maximum coolant flowrate can be found using Fig. 5.1. A reasonable value to select for the maximum pressure drop is 60 psi (414 kPa). The flowrate corresponding to this pressure drop is 5.9×10^6 lbm/hr-ft² (69.1 Kg/s-m²).

If the fuel assembly is at steady-state conditions and if the heat transferred to the void regions is negligible, the ratio of the power density to the coolant flowrate is proportional to the fuel assembly enthalpy gain. This linear relationship is shown in Fig. 5.2. Figure 5.2 can be used to determine the coolant flowrate required to give a desired fuel assembly enthalpy gain if the power density is known. For the given coolant inlet conditions, the maximum fuel assembly enthalpy gain is approximately 130 BTU/lbm (302 KJ/Kg). Using this value and the maximum coolant flowrate determined from Fig. 5.1, the greatest power density that can be used in this fuel assembly is 7410 BTU/hr-ft³ (276 W/m²).

CHAPTER 6

CONCLUSIONS AND RECOMMENDATIONS

A computer program that performs a steady-state thermal hydraulic analysis of a mechanical spectral shift reactor core has been written. The program input contains the coolant flowrates, the coolant inlet conditions, the FTWR, and the fuel assembly power density. The program calculates the coolant pressures and temperatures, the cladding temperatures, and the void region pressures and temperatures throughout one fuel assembly.

A conceptual mechanical spectral shift core design was analyzed for three different fuel distributions. Two general conclusions based on the test case results are:

- 1) Equal coolant enthalpy increases through the fuel assemblies can be obtained by selecting the proper coolant flowrate through each fuel assembly. The test case results show that this can be done even if large variations exist between the fuel assembly power densities. The maximum allowable pressure drop through the core limits the range of power densities that can be used.
- 2) The coolant outlet conditions are affected by changing the FTWR, even though the flowrates through the void regions is very low. This indicates that very little heat is transferred into the void regions.

The program presented in this thesis is the first step toward obtaining a general thermal-hydraulic computer program for analyzing mechanical spectral shift reactor cores, however many changes are needed if the program is to be made more general and useful. Some recommended improvements are:


- 1) The program input needs to be changed so the coolant channel parameters can be defined easily and quickly for a large variety of fuel assemblies. This would allow the effects of changing the fuel rod lattice or the fuel assembly dimensions to be examined.
- 2) The accuracy of the calculated coolant cross-flow rates is questionable. If a fuel rod lattice for which experimental cross-flow data was available was being analyzed, a more accurate cross-flow prediction could be made.
- 3) The program results are only valid if the coolant remains subcooled or undergoes nucleate boiling. The program would be more versatile if it could calculate the coolant conditions and the cladding temperature during bulk coolant boiling and annular flow.


The suggested changes are needed if the present computer program is to be made more useful. Certainly many more improvements than the three listed above could be made. The advantages of mechanical spectral shift reactor cores make this reactor type an interesting alternative to the present PWR. A thermal-hydraulic computer code that would easily analyze any proposed mechanical spectral shift core design would be useful in the development of this reactor type.


REFERENCES


1. Edlund, M. C., "Physics of Spectral Shift Reactors," Ph.D. Dissertation, Ann Arbor, Mi., 1966.
2. V. O. Uotinen, et al., "Technical Feasibility of a Pressurized Water Reactor Design with a Low Water Volume Fraction Lattice," Final Report, EPRI NP-1833, 1981.
3. Sherman, R. L., "RFD-1: A 1-D, 4-Group Code to Calculate Burnup Cycles Using Mechanical Spectral Shift," Master's Thesis, Blacksburg, Va., 1982.
4. Edlund, M. C., "High Conversion Ratio Plutonium Recycle in Pressurized Water Reactors," Annals of Nuclear Energy, 2, 801-807 (1975).
5. Novendstern, E. H., "Turbulent Flow Pressure Drop Model for Fuel Rod Assemblies Using a Helical Wire-Wrap Spacer System," Nuclear Engineering and Design, 22, 19-27, (1972).
6. Lamarsh, J. R., Introduction to Nuclear Engineering, Addison-Wesley Publishing Company, Reading, Mass., 1975.
7. Jens, W. H., and D. A. Lottes, "Analysis of Heat Transfer, Burnout, Pressure Drop, and Density Data for High Pressure Water," ANL-4627, Argonne Natl. Laboratory, Chicago, Ill., 1951.
8. Holman, J. P., Heat Transfer, Fourth Edition, McGraw-Hill Book Company, New York, 1972.
9. Fox, R. W., and A. T. McDonald, Introduction to Fluid Mechanics, Second Edition, John Wiley and Sons, New York, 1973.
10. Rogers, J. T., and N. E. Todreas, "Coolant Interchannel Mixing in Reactor Fuel Rod Bundles Single-Phase Coolants," Heat Transfer in Rod Bundles, ASME, New York, 1968, 1-57.
11. Hendricks, R. C., I. C. Peller, and A. K. Baron, "WASP - A Flexible Fortran IV Computer Code for Calculating Water and Steam Properties," NASA TN D-7391, Lewis Research Center, Cleveland, O., 1973.


APPENDIX A
Program Flow Chart























APPENDIX B
Program Listing

C

```

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
DIMENSION X(23,23),Y(23,23),R(23,23),TBAR(23,23,6),PBAR(23,23,6)
DIMENSION N(23,23,6),H(23,23,6),NITPIC(23,23,6),T(23,23,6)
DIMENSION V(23,23,6),QGEN(23,23,6),P(23,23,6),TE(23,23,6)
DIMENSION DE(23,23,6),AC(23,23,6),PE(23,23,6),HW(23,23,6)
DIMENSION HCLAD(23,23,6),TC(23,23,6),TVWB(23,23,6),TW(23,23,6)
DIMENSION TVWBI(23,23,6),TVWBE(23,23,6),PWRIN(23,23,6)
DIMENSION PWROUT(23,23,6),K1(23,23,6),K2(23,23,6),K3(23,23,6)
DIMENSION L1(23,23,6),L2(23,23,6),L3(23,23,6),M1(23,23,6)
DIMENSION M2(23,23,6),M3(23,23,6),W1(23,23,6),W2(23,23,6)
DIMENSION W3(23,23,6),CPP(23,23,6)
COMMON/FRUIT/NITPIC,N,K1,K2,K3,L1,L2,L3,M1,M2,M3,H
COMMON/JING/T,P
COMMON/HICK/TE,PE,TC,TVWB,PWROUT
READ(5,*)TIN,PIN,ZMAX,DZ,NNN,ENR,PDENS
READ(5,*) PITCH,CLADOD,XLEAD
READ(5,*)PWRIN1,PWRIN2,PWRIN3
READ(5,*)MDOT,XMDOT1,XMDOT2,XMDOT3
DZ=DZ/12.
PITCH=PITCH/12.
CLADOD=CLADOD/12.
XLEAD=XLEAD/12.
I=1
J=1
IF(NNN.EQ.1)FW=1.25
IF(NNN.EQ.2)FW=1.19
IF(NNN.EQ.3)FW=1.11
IF(NNN.EQ.4)FW=1.05
IF(NNN.EQ.5)FW=1.00
IF(NNN.EQ.6)FW=0.95
IF(NNN.EQ.7)FW=0.89
IF(NNN.EQ.8)FW=0.85
IF(NNN.EQ.9)FW=0.80
IF(NNN.EQ.10)FW=0.75

```

C

C *** DEFINE FLOW CHANNEL TYPES ***

C

```

ZMAX=ZMAX/12.
DNBR1=1.0D+10
Z=0.0
PIN1=PWRIN1
PIN2=PWRIN2
PIN3=PWRIN3
TFRIG=0.0
CALL TYPEC(NNN,I,J,TIN,PIN)

```

C

C *** DEFINE ADJACENT FLOW CHANNELS ***

C

```

CALL ADJC(I,J)

```

C

```

C *** DEFINE WHICH VOID REGIONS ARE REMOVED ***
C
C   CALL VRGN(NNN)
C
C *** DEFINE WHICH TYPE OF VOID REGION A FLOW CHANNEL IS NEXT TO ***
C
C   CALL VOIT(I,J)
C
C *** BEGIN THERMAL-HYDRAULIC CALCULATIONS ***
C
C   NUMNIT=0
C
C *** FIND INLET ENTHALPY ***
C
C   CALL FRIG(TIN,PIN,D,HIN,TFRIG)
C
C *** FIND INLET SATURATION PROPERTIES ***
C
C   CALL SATP(PIN,TSATIN)
C   TFRIG=0.0
C   PX=PIN+100.
C   CALL FRIG(TSATIN,PX,D,HF,TFRIG)
2017 CONTINUE
C   NX=0
C   NUMNUT=0
2018 CONTINUE
C   NX=NX+1
C   NFLAG1=0.0
C   NFLAG2=0.0
C   NFLAG3=0.0
C   DO 262 KK=1,23
C   IF(KK.LE.12)LMAX=KK+11
C   IF(KK.GT.12)LMAX=(24-KK)+11
C   DO 262 L=1,LMAX
C   DO 262 M=1,6
C   NN=N(KK,L,M)
C   IF(NN.EQ.4)GO TO 262
C   NITPIK=NITPIC(KK,L,M)
C   TT=T(KK,L,M)
C   PP=P(KK,L,M)
C   HH=H(KK,L,M)
C
C *** CALCULATE THE CHANNEL POSITION,THE CHANNEL FLOW AREA,THE ***
C *** EQUIVALENT DIAMETER,AND THE CHANNEL HEAT GENERATION RATE ***
C
C   CALL SPINK(I,J, KK,L,M,MDOT,NN,TT,PP,VV,Z,DZ,QQGEN,DDE,AAC,TFRIG,
C   1D,PDENS,ZMAX,HZ)
C
C *** ESTIMATE THE EXIT TEMP. AND PRESSURE FOR DELTZ ***
C
C   CALL ZICK(TT,PP,AAC,DDE,VV,DZ,QQGEN,PITCH,CLADOD,XLEAD,PPE,TTE,
C   1TFRIG,D,HZ)
C   IF((KK.NE.1).AND.(L.NE.1).AND.(M.NE.1))PPE=PFOUND
C   IF(NX.NE.1)TTE=TE(KK,L,M)
C

```

```

C *** CALCULATE THE AVERAGE TEMPERATURES AND PRESSURES ***
C
C 277 CONTINUE
    TTBAR=(TT+TTE)/2.
    PPBAR=(PP+PPE)/2.
    PC=CP
C
C *** ESTIMATE THE CLADDING TEMPERATURES ***
C
C    CALL CLADT(PPBAR,TTBAR,FW,DDE,VV,HHCLAD,HZ,D,QQGEN,TTC,NN,TFRIG,
    1DZ)
C 263 CONTINUE
C
C *** CALCULATE THE CLADDING HEAT TRANSFER COEFFICIENT ***
C
C    CALL CLADH(PPBAR,TTBAR,FW,DDE,VV,HZ,HHCLAD,D,TFRIG)
C
C *** CHECK THE ESTIMATED VALUE OF THE CLADDING TEMPERATURE ***
C
C    IF(NN.EQ.1)DEE=0.38*3.1416*DZ/(12.*2.)
C    IF(NN.EQ.2)DEE=0.38*3.1416*DZ/(12.*3.)
C    IF(NN.EQ.3)DEE=0.38*3.1416*DZ/(12.*6.)
C    QGENP=HHCLAD*(TTC-TTBAR)*DEE
C    DELTQ1=DABS(QGENP-QQGEN)
C    IF(DELTQ1.LE.0.05)GO TO 264
C    DELTQ=QGENP-QQGEN
C    IF(DELTQ.GT.0.0)GO TO 265
C    TTC=DELTQ1/(2.*HHCLAD)+TTC
C    GO TO 263
C 265 TTC=TTC-DELTQ1/(2.*HHCLAD)
C    GO TO 263
C 264 CONTINUE
C
C *** CHECK FOR BOILING HEAT TRANSFER ***
C
C *** FIND THE SATURATION TEMPERATURE FOR THE AVERAGE PRESSURE ***
C
C    CALL SATP(PPBAR,TSAT)
C    QDP=QQGEN*3600./DEE
C    DTSUB=TSAT-TTBAR
C
C *** CALCULATE THE CLADDING TEMPERATURE AT WHICH LOCAL BOILING ***
C *** WOULD OCCUR ***
C
C    TCLB=60.*(QDP/1.0D+06)**0.25/DEXP(PPBAR/900.)+TSAT
C    IF(TCLB.GT.TTC)GO TO 272
C    TTC=TCLB
C 272 CONTINUE
C
C *** CALCULATE BURN-OUT HEAT FLUX ***
C
C    G=VV*D*3600.
C    A1=2.8591
C    A2=0.51796
C    A3=0.023018

```

```

A4=0.6396
A5=1.2614
CALL FRIG(TTBAR, PPBAR, D, HZ, TFRIG)
SPURT=TTE-TT
IF(SPURT.LE.0.0)SPURT=1.0
DHDZ=CP*SPURT/(DZ*12.)
IF(NUMNIT.EQ.0)HZ=HIN+1.
BOB=HZ-HIN
IF(BOB.LE.0.0)HZ=HIN+1.
Q1=A1*(DDE*G*DHDZ*12./BOB)**A2
Q2=A3*(DDE*G*DHDZ*12./BOB)**A4
Q3=A5*(HF-HIN)+0.123*(2000.-PIN)
QBO=(Q1+Q2+Q3)*1.0D*06
C   IF(DTSUB.LT.0.0)WRITE(6,*)KK,L,M,TTBAR,PPBAR,TSAT,Z
C
C   *** CALCULATE THE DNBR ***
C
C   DNBR=QBO/QDP
C
C   *** CHECK THE ESTIMATED PRESSURE DROP ***
C
C   IF((KK.EQ.1).AND.(L.EQ.1).AND.(M.EQ.1))GO TO 275
C   GO TO 276
275 CALL ZICK1(TT,PP,PPBAR,TTBAR,AAC,DDE,VV,DZ,QQGEN,PITCH,CLADOD,
1XLEAD,PENEW,TX,TFRIG,D)
C   DELP=PENEW-PPE
C   DELPP=DABS(DELP)
C   IF(DELPP.LE.0.2)GO TO 278
C   IF(DELP.GT.0.1)PPE=PPE+0.5*DELPP
C   IF(DELP.LT.-0.1)PPE=PPE-0.5*DELPP
C   GO TO 277
276 CONTINUE
C   PFOUND=PPE
278 CONTINUE
C
C   *** CHECK IF THE CHANNEL IS NEXT TO A WATER REGION ***
C
C   IF(NN.EQ.1)GO TO 2000
C   IF(HH.GT.-.01)GO TO 2000
C
C   *** ASSUME A WALL TEMPERATURE ***
C
C   TTW=(TTBAR+TT)/2.
1400 CONTINUE
C
C   *** CALCULATE THE INNER VOID-WALL FILM TEMPERATURE ***
C
C   TFP=(TTBAR+TTW)/2.0
C
C   *** CALCULATE THE INNER VOID-WALL HEAT TRANSFER COEFFICIENT ***
C
C   CALL WALLH(PPBAR,TTBAR,TFP,DDE,VV,HH,TFRIG,D)
C
C   *** CALCULATE THE HEAT TRANSFERRED TO THE WALL ***
C

```

```

IF(NN.EQ.2)A=3.1416*(0.38/12.)/6.0*DZ
IF(NN.EQ.3)A=3.1416*(0.46/12.)/6.*DZ
QPRIM=HH*A*(TTBAR-TTW)

```

```

C
C *** CHECK IF THIS IS THE FIRST CHANNEL NEXT TO THE VOID SPACE ***
C

```

```

IF(NUMNIT.EQ.0)T1I=TIN
IF(NUMNIT.EQ.0)T2I=TIN
IF(NUMNIT.EQ.0)T3I=TIN
GO TO (1507,1508,1509),NITPIK
1507 NFLAG1=NFLAG1+1
IF(NFLAG1.EQ.1)GO TO 1510
GO TO 1520
1508 NFLAG2=NFLAG2+1
IF(NFLAG2.EQ.1)GO TO 1510
GO TO 1520
1509 NFLAG3=NFLAG3+1
IF(NFLAG3.EQ.1)GO TO 1510
GO TO 1520
1510 CONTINUE

```

```

C
C *** ASSUME AN EXIT WATER ROD WATER TEMPERATURE ***
C

```

```

TTVWBE=TTW-(TTBAR-TT)
GO TO (1516,1517,1518),NITPIK
1516 TTVWBI=T1I
PPWRIN=PWRIN1
AX=1.605/144.
TTVWB=(TTVWBE+TTVWBI)/2.0
CALL KICK(XMDOT1,XMDOT2,XMDOT3,PPWRIN,PPWROU,
1TTVWB,NITPIK,DZ,DEW,VR,TFRIG,D)
PW=(PPWRIN+PPWROU)/2.0
CALL FRIG(TTVWB,PW,D,HY,TFRIG)
VX=XMDOT1/(D*AX)
XXV=14.
GO TO 1519
1517 TTVWBI=T2I
PPWRIN=PWRIN2
AX=2.96/144.
TTVWB=(TTVWBE+TTVWBI)/2.0
CALL KICK(XMDOT1,XMDOT2,XMDOT3,PPWRIN,PPWROU,
1TTVWB,NITPIK,DZ,DEW,VR,TFRIG,D)
PW=(PPWRIN+PPWROU)/2.0
CALL FRIG(TTVWB,PW,D,HY,TFRIG)
VX=XMDOT2/(D*AX)
XXV=34.
GO TO 1519
1518 TTVWBI=T3I
PPWRIN=PWRIN3
AX=.4474/144.
TTVWB=(TTVWBE+TTVWBI)/2.0
CALL KICK(XMDOT1,XMDOT2,XMDOT3,PPWRIN,PPWROU,
1TTVWB,NITPIK,DZ,DEW,VR,TFRIG,D)
PW=(PPWRIN+PPWROU)/2.0
CALL FRIG(TTVWB,PW,D,HY,TFRIG)

```

```

      VX=XMDOT3/(D*AX)
      XXV=18.
1519 CONTINUE
1511 CONTINUE
C
C *** CHECK THE WATER ROD TEMPERATURE ASSUMPTION
C
      TEP=XXV*QPRIM/(VX*D*AX*CP)+TTVWBI
      DELTVD=TEP-TTVWBE
      ADELTA=DABS(DELTVD)
      IF(ADELTA.LT.0.1)GO TO 1609
      IF(DELTVD.LT.0.0)TTVWBE=TTVWBE-0.5*ADELTA
      IF(DELTVD.GT.0.0)TTVWBE=TTVWBE+0.5*ADELTA
      GO TO 1511
1609 CONTINUE
      GO TO(1610,1611,1612),NITPIK
1610 TVWBE1=TTVWBE
      POUT1=PPWROU
      GO TO 1520
1611 TVWBE2=TTVWBE
      POUT2=PPWROU
      GO TO 1520
1612 TVWBE3=TTVWBE
      POUT3=PPWROU
1520 CONTINUE
      GO TO (1512,1513,1514),NITPIK
1512 TTVWBE=TVWBE1
      PPWROU=POUT1
      PPWRIN=PWRIN1
      TTVWBI=T1I
      AX=1.605/144.
      VR=XMDOT1/(D*AX)
      DEW=0.0645
      GO TO 1515
1513 TTVWBE=TVWBE2
      PPWROU=POUT2
      PPWRIN=PWRIN2
      TTVWBI=T2I
      AX=2.96/144.
      VR=XMDOT2/(D*AX)
      DEW=0.0655
      GO TO 1515
1514 TTVWBE=TVWBE3
      PPWROU=POUT3
      PPWRIN=PWRIN3
      TTVWBI=T3I
      AX=0.4474/144.
      VR=XMDOT3/(D*AX)
      DEW=0.03
1515 CONTINUE
      TTVWB=(TTVWBE+TTVWBI)/2.0
C
C *** CALCULATE THE WATER ROD FILM TEMPERATURE ***
C
      TFDP=(TTVWB+TTW)/2.0

```

```

      PW=(PPWRIN+PPWROU)/2.0
C
C *** CALCULATE THE HEAT TRANSFER COEFFICIENT OF WATER REGION ***
C
      CALL WALLH(PW,TTVWB,TFDP,DEW,VR,HHW,TFRIG,D)
C
C *** CHECK THE WALL TEMPERATURE ASSUMPTION ***
C
      IF(NITPIK.LE.2)ATRIP=DZ*0.23/12.
      IF((NITPIK.EQ.3).AND.(NN.EQ.2))ATRIP=DZ*0.01440
      IF((NITPIK.EQ.3).AND.(NN.EQ.3))ATRIP=DZ*0.02356
      QTRIP=ATRIP*HHW*(TTW-TTVWB)
      DELWQ=QTRIP-QPRIM
      DELG=DABS(DELWQ)
      IF(DELG.LT.0.01)GO TO 1999
      GX=A*HH*TTBAR+ATRIP*HHW*TTVWB
      GXX=ATRIP*HHW*A*HH
      TTTW=GX/GXX
      TTW=(TTW+TTTW)/2.
      IF((NFLAG1.EQ.1).AND.(NITPIK.EQ.1))NFLAG1=NFLAG1-1
      IF((NFLAG2.EQ.1).AND.(NITPIK.EQ.2))NFLAG2=NFLAG2-1
      IF((NFLAG3.EQ.1).AND.(NITPIK.EQ.3))NFLAG3=NFLAG3-1
      GO TO 1400
1999 TW(KK,L,M)=TTW
      H(KK,L,M)=HH
      PWRIN(KK,L,M)=PPWRIN
      TVWBI(KK,L,M)=TTVWBI
      TVWB(KK,L,M)=TTVWB
      TVWBE(KK,L,M)=TTVWBE
      PWROUT(KK,L,M)=PPWROU
      HW(KK,L,M)=HHW
2000 CONTINUE
      IF(DNBR.LT.DNBR1)DNBR1=DNBR
      V(KK,L,M)=VV
      QGEN(KK,L,M)=QGEN
      PE(KK,L,M)=PPE
      TE(KK,L,M)=TTE
      TC(KK,L,M)=TTC
      HCLAD(KK,L,M)=HHCLAD
      CPP(KK,L,M)=PC
      TBAR(KK,L,M)=TTBAR
      PBAR(KK,L,M)=PPBAR
      AC(KK,L,M)=AAC
262 CONTINUE
C
C *** CALCULATE THE CHANNEL CROSS-FLOW RATES ***
C
      DO 2151 KK=1,23
      IF(KK.LE.12)LMAX=KK+11
      IF(KK.GT.12)LMAX=(24-KK)+11
      DO 2151 L=1,LMAX
      DO 2151 M=1,6
      IF(N(KK,L,M).EQ.4)GO TO 2151
      CALL SPUD(TBAR(KK,L,M),PBAR(KK,L,M),TFRIG,PITCH,XLEAD,CLADOD,
      W1(KK,L,M),W2(KK,L,M),W3(KK,L,M),V(KK,L,M),N(KK,L,M),D)

```

```

      IF(N(KK,L,M).NE.2)GO TO 2151
      IF(N(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)).EQ.3)GO TO 2110
2100 CONTINUE
      IF(N(K2(KK,L,M),L2(KK,L,M),M2(KK,L,M)).EQ.3)GO TO 2115
2105 CONTINUE
      IF(N(K3(KK,L,M),L3(KK,L,M),M3(KK,L,M)).EQ.3)GO TO 2120
      GO TO 2151
2110 CALL SPID(TBAR(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M))),PBAR(K1(KK,L,M),
      1L1(KK,L,M),M1(KK,L,M)),TFRIG,PITCH,XLEAD,CLADOD,W1(KK,L,M),
      2V(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)),D)
      GO TO 2100
2115 CALL SPID(TBAR(K2(KK,L,M),L2(KK,L,M),M2(KK,L,M))),PBAR(K2(KK,L,M),
      1L2(KK,L,M),M2(KK,L,M)),TFRIG,PITCH,XLEAD,CLADOD,W2(KK,L,M),
      2V(K2(KK,L,M),L2(KK,L,M),M2(KK,L,M)),D)
      GO TO 2105
2120 CALL SPID(TBAR(K3(KK,L,M),L3(KK,L,M),M3(KK,L,M))),PBAR(K3(KK,L,M),
      1L3(KK,L,M),M3(KK,L,M)),TFRIG,PITCH,XLEAD,CLADOD,W3(KK,L,M),
      2V(K3(KK,L,M),L3(KK,L,M),M3(KK,L,M)),D)
2151 CONTINUE
C
C *** PERFORM GAUSS-SEIDEL ITERATION ON THE CHANNEL EXIT TEMPERATURES **
C
      NNT=0
      CPV=CP
      DO 4060 KK=1,23
      IF(KK.LE.12)LMAX=KK+11
      IF(KK.GT.12)LMAX=(24-KK)+11
      DO 4060 L=1,LMAX
      DO 4060 M=1,6
      IF(N(KK,L,M).EQ.4) GO TO 4060
      CP=CPP(KK,L,M)
      IF(N(KK,L,M).EQ.1)GO TO 4010
      IF(N(KK,L,M).EQ.2)GO TO 4015
      IF(H(KK,L,M).LT.0.0000001)GO TO 4016
C
C *** CALCULATE CONSTANTS FOR CHANNEL TYPE 3 ***
C
      A=3.14159*0.46*DZ/72.
      ATRIP=0.23*DZ/12.
      IF(NITPIC(KK,L,M).EQ.3)ATRIP=DZ*0.02356
      XMDOT=V(KK,L,M)*D*AC(KK,L,M)
      G=H(KK,L,M)*A+HW(KK,L,M)*ATRIP
      G2=((W1(KK,L,M)+W2(KK,L,M))*DZ*CP+H(KK,L,M)*A)/2.0
      G3=G2+XMDOT*CP-((H(KK,L,M)*A)**2)/(2.*G)
      G4=H(KK,L,M)*A*HW(KK,L,M)*ATRIP*TVWB(KK,L,M)/G
      G5=W1(KK,L,M)*DZ*CP*T(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M))/2.0
      G6=W2(KK,L,M)*DZ*CP*T(K2(KK,L,M),L2(KK,L,M),M2(KK,L,M))/2.0
      G7=(((H(KK,L,M)*A)**2)/(2.*G)+XMDOT*CP-G2)*T(KK,L,M)
      B=QGEN(KK,L,M)+G5+G6+G7+G4
      AA=G3
      A1=-W1(KK,L,M)*DZ*CP/2.0
      A2=-W2(KK,L,M)*DZ*CP/2.0
      GO TO 4030
C
C *** CALCULATE CONSTANTS FOR CHANNEL TYPE 1 ***

```


C

```

4010 A=3.14159*0.38*DZ/72.
      XMDOT=V(KK,L,M)*D*AC(KK,L,M)
      G=(XMDOT-3.*W1(KK,L,M)*DZ/2.0)*CP*T(KK,L,M)
      G2=(T(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)))+T(K2(KK,L,M),L2(KK,L,M),
1M2(KK,L,M))+T(K3(KK,L,M),L3(KK,L,M),M3(KK,L,M)))*CP*DZ*
2W1(KK,L,M)/2.0
      B=QGEN(KK,L,M)+G2+G
      AA=(XMDOT+3.0*W1(KK,L,M)*DZ/2.0)*CP
      A1=-W1(KK,L,M)*DZ*CP/2.0
      A2=A1
      A3=A1
      GO TO 4020

```

C

C *** CALCULATE CONSTANTS FOR CHANNEL TYPE 2 ***

C

```

4015 IF(H(KK,L,M).LT.0.0000001)GO TO 4017
      A=3.14159*0.38*DZ/72.
      ATRIP=0.23*DZ/12.
      IF(NITPIC(KK,L,M).EQ.3)ATRIP=0.0144*DZ
      XMDOT=V(KK,L,M)*D*AC(KK,L,M)
      G=H(KK,L,M)*A+HW(KK,L,M)*ATRIP
      G2=(W1(KK,L,M)*W2(KK,L,M)+W3(KK,L,M))*DZ*CP+H(KK,L,M)*A
      G3=XMDOT*CP-((H(KK,L,M)*A)**2)/(G*2.)+G2/2.0
      G4=H(KK,L,M)*A*HW(KK,L,M)*ATRIP*TVWB(KK,L,M)/G
      G5=W1(KK,L,M)*DZ*CP*T(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)))/2.
      G6=W2(KK,L,M)*DZ*CP*T(K2(KK,L,M),L2(KK,L,M),M2(KK,L,M)))/2.
      G7=W3(KK,L,M)*DZ*CP*T(K3(KK,L,M),L3(KK,L,M),M3(KK,L,M)))/2.
      G8=((H(KK,L,M)*A)**2)/(2.*G)+XMDOT*CP
      G9=((W1(KK,L,M)+W2(KK,L,M)+W3(KK,L,M))*DZ*CP+H(KK,L,M)*A)/2.0
      G10=(G8-G9)*T(KK,L,M)
      B=QGEN(KK,L,M)+G5+G6+G7+G10+G4
      AA=G3
      A1=-W1(KK,L,M)*DZ*CP/2.
      A2=-W2(KK,L,M)*DZ*CP/2.
      A3=-W3(KK,L,M)*DZ*CP/2.
      GO TO 4020

```

C

C *** CALCULATE CONSTANTS FOR CHANNEL TYPE 3 W/INSULATED WALLS ***

C

```

4016 XMDOT=V(KK,L,M)*D*AC(KK,L,M)
      G=(XMDOT-(W1(KK,L,M)+W2(KK,L,M))*DZ/2.)*CP*T(KK,L,M)
      G2=(W1(KK,L,M)*T(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)))+W2(KK,L,M)*
1T(K2(KK,L,M),L2(KK,L,M),M2(KK,L,M)))*DZ*CP/2.
      B=QGEN(KK,L,M)+G2+G
      AA=(XMDOT+(W1(KK,L,M)+W2(KK,L,M))*DZ/2.0)*CP
      A1=-W1(KK,L,M)*DZ*CP/2.0
      A2=-W2(KK,L,M)*DZ*CP/2.0
      GO TO 4030

```

C

C *** CALCULATE CONSTANTS FOR CHANNEL TYPE 2 W/INSULATED WALLS ***

C

```

4017 XMDOT=V(KK,L,M)*D*AC(KK,L,M)
      G=(XMDOT-(W1(KK,L,M)+W2(KK,L,M)+W3(KK,L,M))*DZ/2.)*CP*T(KK,L,M)
      G2=(W1(KK,L,M)*T(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)))+W2(KK,L,M)*

```

```

1T(K2(KK,L,M),L2(KK,L,M),M2(KK,L,M))*W3(KK,L,M)*T(K3(KK,L,M),
2L3(KK,L,M),M3(KK,L,M))*DZ*CP/2.0
B=QGEN(KK,L,M)*G2+G
AA=(XMDOT*(W1(KK,L,M)*W2(KK,L,M)*W3(KK,L,M))*DZ/2.0)*CP
A1=-W1(KK,L,M)*CP*DZ/2.0
A2=-W2(KK,L,M)*CP*DZ/2.0
A3=-W3(KK,L,M)*CP*DZ/2.0
4020 CONTINUE
C
C *** CALCULATE NEW EXIT TEMP. FOR CHANNEL TYPES 1 AND 2 ***
C
TENEW=(B-A1*TE(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)))-A2*TE(K2(KK,L,M),
1L2(KK,L,M),M2(KK,L,M)))-A3*TE(K3(KK,L,M),L3(KK,L,M),M3(KK,L,M)))/AA
GO TO 4040
C
C *** CALCULATE NEW EXIT TEMP. FOR CHANNEL TYPE 3 ***
C
4030 TENEW=(B-A1*TE(K1(KK,L,M),L1(KK,L,M),M1(KK,L,M)))-A2*TE(K2(KK,L,M),
1L2(KK,L,M),M2(KK,L,M)))/AA
C
C *** CHECK DIFFERENCE BETWEEN NEW AND OLD EXIT TEMPERATURES ***
C
4040 DELT=DABS(TENEW-TE(KK,L,M))
IF(DELT.GT.5.)NNT=NNT+1
TE(KK,L,M)=1.87*TENEW-.87*TE(KK,L,M)
4060 CONTINUE
CP=CPV
NUMNUT=NUMNUT+1
IF(NNT.GT.0)GO TO 2018
C
C *** CHECK IF Z EQUALS ZMAX ***
C
DELZ=DABS(ZMAX-Z-DZ)
C
C *** RESET INITIAL VALUES ***
C
Z=Z+DZ
NUMNIT=NUMNIT+1
NFLAG1=0
NFLAG2=0
NFLAG3=0
DO 2040 KK=1,23
IF(KK.LE.12)LMAX=KK+11
IF(KK.GT.12)LMAX=(24-KK)+11
DO 2040 L=1,LMAX
DO 2040 M=1,6
IF(N(KK,L,M).EQ.4)GO TO 2040
P(KK,L,M)=PE(KK,L,M)
T(KK,L,M)=TE(KK,L,M)
IF(H(KK,L,M).LE..000001)GO TO 2040
IF(NITPIC(KK,L,M).EQ.1)GO TO 2027
IF(NITPIC(KK,L,M).EQ.2)GO TO 2028
IF(NITPIC(KK,L,M).EQ.3)GO TO 2029
2027 NFLAG1=NFLAG1+1
IF(NFLAG1.EQ.1)GO TO 2030

```

```

GO TO 2040
2028 NFLAG2=NFLAG2+1
      IF(NFLAG2.EQ.1)GO TO 2030
      GO TO 2040
2029 NFLAG3=NFLAG3+1
      IF(NFLAG3.EQ.1)GO TO 2030
      GO TO 2040
2030 CONTINUE
      IF(NITPIC(KK,L,M).EQ.1)T11=TVWBE(KK,L,M)
      IF(NITPIC(KK,L,M).EQ.2)T21=TVWBE(KK,L,M)
      IF(NITPIC(KK,L,M).EQ.3)T31=TVWBE(KK,L,M)
      IF(NITPIC(KK,L,M).EQ.1)PWRIN1=PWROUT(KK,L,M)
      IF(NITPIC(KK,L,M).EQ.2)PWRIN2=PWROUT(KK,L,M)
      IF(NITPIC(KK,L,M).EQ.3)PWRIN3=PWROUT(KK,L,M)
2040 CONTINUE
      IF(DELZ.LE.0.001)GO TO 2050
      GO TO 2017
C
C *** AVERAGE THE CORE ENTHALPY AT THE CORE EXIT CONDITIONS ***
C
2050 XMTOT=0.0
      TFRIG=0.0
      HTOT=0.0
      DO 2051 KK=1,23
      IF(KK.LE.12)LMAX=KK+11
      IF(KK.GT.12)LMAX=(24-KK)+11
      DO 2051 L=1,LMAX
      DO 2051 M=1,6
      IF(N(KK,L,M).EQ.4)GO TO 2051
      CALL FRIG(TE(KK,L,M),PE(KK,L,M),D,HP,TFRIG)
      XMDOT=V(KK,L,M)*AC(KK,L,M)*D
      HTOT=HTOT+XMDOT*HP
      XMTOT=XMTOT+XMDOT
2051 CONTINUE
      TFRIG=0.0
      CALL FRIG(T11,PWRIN1,D1,HO1,TFRIG)
      TFRIG=0.0
      CALL FRIG(T21,PWRIN2,D2,HO2,TFRIG)
      TFRIG=0.0
      CALL FRIG(T31,PWRIN3,D3,HO3,TFRIG)
      XN1=0.0
      XN2=0.0
      XN3=0.0
      IF(NNN.EQ.1)GO TO 2058
      IF(NNN.EQ.2)XN3=3.
      IF(NNN.EQ.3)XN3=7.
      IF(NNN.EQ.4)XN1=3.
      IF(NNN.EQ.5)GO TO 2052
      IF(NNN.EQ.6)GO TO 2053
      IF(NNN.EQ.7)GO TO 2054
      IF(NNN.EQ.8)GO TO 2055
      IF(NNN.EQ.9)GO TO 2056
      IF(NNN.EQ.10)GO TO 2057
      GO TO 2058
2052 XN3=3.

```

```

      XN1=3.
      GO TO 2058
2053  XN3=7.
      XN1=3.
      GO TO 2058
2054  XN2=3.
      XN3=3.
      GO TO 2058
2055  XN2=3.
      XN3=7.
      GO TO 2058
2056  XN2=3.
      XN1=3.
      XN3=1.
      GO TO 2058
2057  XN1=3.
      XN2=3.
      XN3=7.
2058  HTOT=HTOT+XMDOT1*XN1*HO1+XMDOT2*XN2*HO2+XMDOT3*XN3*HO3
      XMTOT=XMTOT+XMDOT1*XN1+XMDOT2*XN2+XMDOT3*XN3
      HEXIT=HTOT/XMTOT
      DELH=HEXIT-HIN
      DELP=PIN-PE(2,5,2)

```

C

C *** WRITE EXIT TEMPERATURES AND PRESSURES ***

C

```

      ZMAX=ZMAX*12.
      WRITE(6,9050)
9050  FORMAT(1H1,////,50X,'***** FUEL ASSEMBLY DATA *****',/)
      WRITE(6,9051)ZMAX,ENR,MDOT
9051  FORMAT(5X,'THE HEIGHT IS ',F5.1,' INCHES. THE ENRICHMENT IS ',
1F5.2,'% URANIUM-235. THE FLOWRATE THROUGH THE FUEL RODS IS ',
2F7.2,' LBM/S',/)
      WRITE(6,9052)XMDOT3,XMDOT1
9052  FORMAT(5X,'THE FLOWRATE THROUGH THE VOID RODS IS ',F6.2,' LBM/S.
1THE FLOWRATE THROUGH THE SHORT VOID PLATES IS ',F6.2,' LBM/S',/)
      WRITE(6,9053)XMDOT2
9053  FORMAT(5X,'THE FLOWRATE THROUGH THE LONG VOID PLATES IS ',F6.2,
1' LBM/S',/)
      WRITE(6,9054)FW
9054  FORMAT(5X,'THE FUEL TO WATER RATIO IS ',F4.2,/)
      WRITE(6,9068)DNBR1
9068  FORMAT(5X,'THE MINIMUM DNBR IS ',F10.2,/)
      WRITE(6,9069)PDENS
9069  FORMAT(5X,'THE POWER DENSITY IS ',F10.3,' W/CM**3',/)
      WRITE(6,9055)
9055  FORMAT(51X,'***** INLET CONDITIONS *****',/)
      WRITE(6,9056)TIN
9056  FORMAT(5X,'THE INLET TEMPERATURE IS ',F6.2,' DEGREES F',/)
      WRITE(6,9057)PIN
9057  FORMAT(5X,'THE PRESSURE AT THE INLET TO THE FUEL RODS IS ',F7.2,
1' PSIA',/)
      WRITE(6,9058)PIN3,PIN1
9058  FORMAT(5X,'THE PRESSURE AT THE INLET TO THE VOID RODS IS ',F7.2,
1' PSIA. THE PRESSURE AT THE INLET TO THE SHORT VOID PLATES IS ',

```

```

2F7.2,' PSIA',/)
WRITE(6,9059)PIN2
9059 FORMAT(5X,'THE PRESSURE AT THE INLET TO THE LONG VOID PLATES IS ',
1F7.2,' PSIA',/)
WRITE(6,9060)HIN
9060 FORMAT(5X,'THE INLET ENTHALPY IS ',F7.2,' BTU/LBM',///)
WRITE(6,9061)
9061 FORMAT(49X,'***** OUTLET CONDITIONS *****',/)
WRITE(6,9062)PE(2,5,2)
9062 FORMAT(5X,'THE PRESSURE AT THE FUEL ROD EXIT IS ',F7.2,' PSIA',/
1)
WRITE(6,9063)PWRIN3,PWRIN1
9063 FORMAT(5X,'THE PRESSURE AT THE EXIT OF THE VOID RODS IS ',F7.2,
1' PSIA THE PRESSURE AT THE EXIT OF THE SHORT VOID PLATES IS ',
2F7.2,' PSIA',/)
WRITE(6,9064)PWRIN2
9064 FORMAT(5X,'THE PRESSURE AT THE EXIT OF THE LONG VOID PLATES IS ',
1F7.2,' PSIA',/)
WRITE(6,9065)HEXIT
9065 FORMAT(5X,'THE EXIT ENTHALPY IS ',F7.2,' BTU/LBM',/)
WRITE(6,9066)DELH
9066 FORMAT(5X,'THE ENTHALPY INCREASE THROUGH THE ASSEMBLY IS ',F7.2,
1' BTU/LBM',/)
WRITE(6,9067)DELP
9067 FORMAT(5X,'THE PRESSURE DROP THROUGH THE ASSEMBLY IS ',F7.2,' PSI'
1)
C
C *** PRINT EXIT VALUES FOR THE INDIVIDUAL CHANNELS ***
C
CALL PPRINT(TIN,PIN,Z)
STOP
END
C
C
C
C
C
C
C
SUBROUTINE FRIG(T,P,D,H,TFRIG)
C
C *** THIS SUBROUTINE USES WASP4 TO CALCULATE THE THERMODYNAMIC ***
C *** PROPERTIES OF SATURATED WATER AT THE GIVEN PRESSURE AND ***
C *** TEMPERATURE. THE TEMPERATURE IS INPUT IN DEGREES F AND THE ***
C *** PRESSURE IS INPUT IN PSIA. THE RETURNED OUTPUT IS; ***
C *** ENTHALPY IN BTU/LBM
C *** DENSITY IN LBM/FT**3
C *** ENTROPY IN BTU/LBM-R
C *** CV IN BTU/LBM-R
C *** CP IN BTU/LBM-R
C *** GAMMA (NO UNITS)
C *** C IN FT/S
C *** VISCOSITY IN LBM/FT-S
C *** THERMAL CONDUCTIVITY IN BTU/FT-S-R
C

```



```

C
C      COMPUTE THE STATE RELATIONS AND THERMODYNAMIC AND TRANSPORT
C      PROPERTIES OF WATER GIVEN TEMPERATURE TT, PRESSURE P,
C      DENSITY D, OR ENTHALPY H, OR ENTROPY S. STATE RELATIONS ARE
C      SPECIFIED BY KS. THERMODYNAMIC AND TRANSPORT PROPERTIES
C      ARE SPECIFIED BY KP. IF KR IS RETURNED OR SPECIFIED AS 1,
C      PROPERTIES ARE COMPUTED AT SATURATION.
C      TAU IS THE TEMPERATURE PARAMETER USED IN THE EQUATION OF STATE
C      TAU IS EQUIVALENT TO T IN THIS SUBROUTINE
C
C      COMMON/CHECKS/DCH1,DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,
C      1HSCH1,HSCH2
C      COMMON/PARTLS/ PTV1,PDT1
C      COMMON/DERIV/PDT,PTV,PDTL,PDTV,PTVL,PTVV
C      COMMON /CONV1/DCONV(5)
C      COMMON /CONV3/PCONV(5)
C      COMMON/TDEG /TDEGF,TDEGC
C      DIMENSION TCON(5)
C
C      DATA IN ALL 'DATA' STATEMENTS CHANGED TO DOUBLE PRECISION
C      FORMAT (6/30/82, RCL)
C
C      DATA TCON/1.0D00,1.0D00,1.8D00,1.0D00,1.0D00/
C      KTR=0
C      TCONS=0.0
C
C      THESE TWO STATEMENTS LOCK WASP INTO UNITS OF DEGREES KELVIN
C
C      TDEGF=-1.0D00
C      TDEGC=-1.0D00
C
C      IF (TDEGF.GT..9) TCONS=459.67
C      IF(TDEGC.GT..9) TCONS=273.15
C      T=TT
C      IF (TT.GT.0.) T=1000./TT
C      IF ( TCONS.GT.0.0 .AND. TT.NE.0.0 ) T=1000./(TT+TCONS)
C      GO TO (10,20,30,40,45),KS
C
C      COMPUTE DENSITY
C      10 CALL DENS(KU,T,P,D,DL,DV,KR)
C      IF ( TT .EQ. 0.0) TT=1000./T - TCONS
C      GO TO 50
C
C      COMPUTE PRESSURE
C      20 CALL PRESS(KU,T,D,P,KR)
C      GO TO 50
C
C      THESE THREE CONTINUE STATEMENTS REPLACE CALLING STATEMENTS TO
C      THE DELETED SUBROUTINES TEMP, TEMPPH, AND TEMPPS, RESPECTIVELY.
C
C      30 CONTINUE
C      40 CONTINUE
C      45 CONTINUE
C
C      50 IF (KR.NE.1.OR.(KS.EQ.1.OR.KS.GT.3)) GO TO 55

```

```

C
C OBTAIN SATURATION DENSITIES DL AND DV FOR KS=2 AND KS=3 CALLS WHEN
C   KR=1
C   CALL DENS(KU,T,P,D,DL,DV,1)
C
55  CONTINUE
    KTRA=KP/2**KTR
    IF(KTRA.EQ.0) RETURN
    KTR=KTR+1
    IF(MOD(KTRA,2).EQ.0) GOTO 55
    GOTO (60,100,130,160,180,240),KTR

C
C   COMPUTE ENTHALPY
C   * 60 IF (KR.EQ.1) GO TO 65
C       CALL ENTH(KU,T,D,H,KR)
C       GO TO 70
C   65 CALL ENTH(KU,T,DL,HL,KR)
C       CALL ENTH (KU,T,DV,HV,KR)
C   70 GOTO 55

C
C   COMPUTE ENTROPY
C   100 IF (KR.EQ.1) GO TO 105
C       CALL ENT(KU,T,D,S,KR)
C       GO TO 110
C   105 CALL ENT (KU,T,DL,SL,KR)
C       CALL ENT(KU,T,DV,SV,KR)
C   110 GOTO 55

C
C   COMPUTE SPECIFIC HEATS AND GAMMA AND SONIC VELOCITY
C   130 IF (KR.NE.1) GO TO 135

C   THE PARAMETER 'KR' WAS ADDED TO THE PARAMETER LIST IN ALL
C   CALLS TO SUBROUTINE CPPRL.
C
    CALL CPPRL(KU,KR,T,DL,CPL,CVL,GAMMAL,CL)
    PTVL=PTV1*PCONV(KU)/TCON (KU)
    PDTL=PDT1*PCONV(KU)/DCONV(KU)
    CALL CPPRL(KU,KR,T,DV,CPV,CVV,GAMMAV,CVP)
    PDTV=PDT1*PCONV(KU)/DCONV(KU)
    PTVV=PTV1*PCONV(KU)/TCON (KU)
    GO TO 140
C   135 CALL CPPRL(KU,KR,T,D,CP,CV,GAMMA,C)
C       PTV =PTV1*PCONV(KU)/TCON (KU)
C       PDT =PDT1*PCONV(KU)/DCONV(KU)
C   140 GOTO 55

C
C   COMPUTE VISCOSITY
C   160 IF (KR.NE.1) GO TO 165
C       CALL VISC(KU,KR,T,P,DL,MUL)
C       CALL VISC(KU,KR,T,P,DV,MUV)
C       GO TO 170
C   165 CALL VISC(KU,KR,T,P,D,MU)
C   170 GOTO 55
C

```



```

C      COMPUTE THERMAL CONDUCTIVITY
180 IF (KR.NE.1) GO TO 220
      CALL THERM (KU,KR,P,T,DL,EXCL,KL)
      CALL THERM (KU,KR,P,T,DV,EXCV,KV)
      GO TO 190
220 CALL THERM (KU,KR,P,T,D,EXCESK,K)
190 GOTO 55
C      COMPUTE SURFACE TENSION
240 CALL SURF (KU,KR,T,SIGMA)
      RETURN
      END
C      -----AUGUST 1, 1973 VERSION-----
C
BLOCK DATA
IMPLICIT REAL*8 (A-H,O-Z)
DIMENSION A1(10),A2(10),A3(10),A4(10),A5(10),A6(10),A7(10)
COMMON /CODE/ MESSAG(24)
COMMON /COF/ A(10,7)
COMMON /CRIT/ RHOCRT,PCRT,TCRT
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E,R
COMMON/CHECKS/DCH1,DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,
1HSCH1,HSCH2
EQUIVALENCE (A1(1),A(1,1)),(A2(1),A(1,2)),(A3(1),A(1,3)),(A4(1),A(
11,4)),(A5(1),A(1,5)),(A6(1),A(1,6)),(A7(1),A(1,7))
C
COMMON/COSAT/CPS1,CPS2,CPS3,CPS4,CPS5,CPS6,CPS7
COMMON /SICOF/ SIC1,SIC2,SIC3,SIC4,SIC5
COMMON /CONV1/DCONV(5)
COMMON /CONV2/TCONV(5)
COMMON /CONV3/PCONV(5)
COMMON /CONV4/SCONV(5)
COMMON /CONV5/CCONV(5)
COMMON /CONV6/HCONV(5)
COMMON /CONV7/MCONV(5)
COMMON /CONV8/KCONV(5)
COMMON /CONV9/STCONV(5)
COMMON /CONV10/ALCONV(5)
REAL*8 MCONV,KCONV
DATA A1/29.492937,-132.13917,274.64632,-360.93828,342.18431,
1 -244.50042,155.18535,5.9728487,-410.30848,-416.05860 /
DATA A2/ -5.1985860,7.7779182,-33.301902,-16.254622,-177.31074,
1 127.48742,137.416153,155.97836,337.31180,-209.88866/
DATA A3/ 6.8335354,-26.149751,65.326396,-26.181978,4*0.0D00,
1-137.46618,-733.96848 /
DATA A4/ -0.1564104,-0.72546108,-9.2734289,4.3125840,4*0.0D00,
1 6.7874983,10.401717 /
DATA A5/ -6.3972405,26.409282,-47.740374,56.323130,4*0.0D00,
1 136.87317,645.81880 /
DATA A6/ -3.9661401,15.453061,-29.142470,29.568796,4*0.0D00,
1 79.847970,399.17570 /
DATA A7/ -.69048554,2.7407416,-5.1028070,3.9636085,4*0.0D00,
1 13.041253,71.531353 /
DATA CPS1,CPS2,CPS3,CPS4,CPS5,CPS6,CPS7/
1 0.29304370D+01,-0.23095789D+04,0.34522497D-01,
2 -.13621289D-03,0.25878044D-06,-.24709162D-09,

```

```

3      0.95937646D-13 /
      DATA DCH1,DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,
      1HSCH1,HSCH2/0.0D00,1.04539D00,0.000611D00,22.089D00,100.01D00,0.55
      2555556,1.5449120,3.6609D00,0.8D00,400.0D00,0.0D00,6052.2D00 /
      DATA MESSAG / 4H THE,4HRMOD,4HYNAM,4HIC A,4HND T,4HRANS,4HPORT,4H
      1PRO,4HPERT,4HIES ,4HFOR ,4HWATE,4HRPC=,4H218.,4H07AT,4HM,TC,4H= 64
      2,4H7.29,4H K,R,4HOC=.,4H317 ,4HG/CC,4H ,4H /
      DATA RHOCRT,PCRT,TCRT/0.317D00, 22.089D00, 647.286D00 /
      DATA SIC1,SIC2,SIC3,SIC4,SIC5/1855.3865, 3.2786420,
      1-0.00037903, 46.174D00, -1.02117D00 /
      DATA TAUC,RHOA,RHOB,TAUA,E,R/ 1.5449120,0.634D00,1.0D00,2.5D00,4.8
      1D00,0.46151D00 /
      DATA TCONV/1.0D00,1.00D00,.55555555D00,1.0D00,1.0D00/
      DATA PCONV/1.0D00,9.8692327,145.038243,1.D06,1.0D00/
      DATA DCONV/2*1.0D00,62.4283D00,1000.0D00,1.0D00/
      DATA SCONV/2*1.0D00,.238849D00,1000.0D00,1.0D00/
      DATA CCONV/2*1.0D00,.0328084D00,0.01D00,1.0D00/
      DATA HCONV/2*1.0D00,.429929D00,1000.0D00,1.0D00/
      DATA MCONV/2*1.0D00,.67196899D-01,0.1D00 ,1.0D00/
      DATA KCONV/2*1.0D-02,1.60644D-04,1.0D00,0.1D00/
      DATA STCONV/2*1.0D00,6.8521766D-5,.001D00,1.0D00/
      DATA ALCONV/2*0.1D00,.328084D-02,0.001D00,1.0D00/
      COMMON/XMINUS/XM1(7)
      DATA XM1/1.0D00,2.0D00,3.0D00,4.0D00,5.0D00,6.0D00,7.0D00/
      END

```

```

C -----VERSION MARCH 1,1972-----
C

```

```

FUNCTION CHECK(KU,KR,T)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON/CONV1/DCONV(5)
COMMON/CONV2/TCONV(5)
COMMON/CONV3/PCONV(5)
COMMON/IERROR/ IROUT
COMMON/CHECKS/DCH1,DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,
1HSCH1,HSCH2
DIMENSION FM1(13),FM2(13),FM3(13),FMT(13),ROUT(11)

```

```

C THE OLD DATA STATEMENTS FOR FM1, FM2, AND FM3 WERE NOT COMPATIBLE
C WITH THE VPISU SYSTEM, SO THEY WERE MADE INTO COMMENTS AND
C REPLACED WITH THE THREE 'DUMMY' DATA STATEMENTS WHICH WILL STILL
C INDICATE THAT AN ERROR HAS OCCURRED BUT NOT QUITE AS ELEGANTLY.
C

```

```

C DATA FM1 /52H(1H ,G12.4 ,31HIS OUT OF RANGE FOR T IN SUB.-,A6 )
C 1 /

```

```

DATA FM1 /13*4HTOUT/

```

```

DATA FM2 /13*4HPOUT/

```

```

DATA FM3 /13*4HDOUT/

```

```

C DATA FM2 /52H(1H ,G12.4 ,31HIS OUT OF RANGE FOR P IN SUB.-,A6 )
C 1 /

```

```

C DATA FM3 /52H(1H ,G12.4 ,31HIS OUT OF RANGE FOR D IN SUB.-,A6 )
C 1 /

```

```

C DATA ROUT /4HDENS,5HPRESS,4HTEMP ,4HENTH,3HENT ,6HTEMPPH,6HTEMPPS
1,5HCPPRL,4HVISC,5HTHERM,4HSURF/
C

```

```

C      CONVERT TEMPERATURE T TO DEGREES KELVIN AND CHECK
C      FOR OUT OF RANGE.  UNITS ARE SPECIFIED BY KU.  IF KR
C      IS SPECIFIED AS 1, T IS CHECKED FOR OUT OF SATURATION
C      RANGE.
C
C      ENTRY  TCHECK (KU, KR, T)
C      CHECK=1000.*TCONV(KU)/T
C      CH1=1000./TCH3
C      CH2=1000./TCH2
C      CH3=1000./TCH1
C      KODE=1
C      DO 1 J=1, 13
1     FMT(J)=FM1(J)
C      GO TO 10
C
C      CONVERT PRESSURE TO MN/M**2 AND CHECK
C      FOR OUT OF RANGE.  UNITS ARE SPECIFIED BY KU.  IF KR IS
C      SPECIFIED AS 1, P IS CHECKED FOR OUT OF SATURATION
C
C      ENTRY  PCHECK(KU, KR, P)
C      CHECK=P/PCONV(KU)
C      CH1= PCH1
C      CH2= PCH2
C      CH3= PCH3
C      KODE=0
C      DO 2 J=1, 13
2     FMT(J)=FM2(J)
C      GO TO 10
C
C      CONVERT DENSITY TO G/CC AND CHECK
C      FOR OUT OF RANGE.  UNITS ARE SPECIFIED BY KU.
C
C      ENTRY  DCHECK(KU, D)
C      CHECK =D/DCONV(KU)
C      CH1=DCH1
C      CH3=DCH2
C      KODE=0
C      DO 3 J=1, 13
3     FMT(J)=FM3(J)
C      GO TO 20
10    IF(KR.EQ.1) GO TO 30
20    IF(CHECK.LT.CH1) GO TO 40
C      IF(CHECK.GT.CH3) GO TO 40
25    IF (KODE.EQ.1) CHECK=T/TCONV(KU)
C      RETURN
30    IF(CHECK.LT.CH1) GO TO 40
C      IF(CHECK.LE.CH2) GO TO 25
40    WRITE(6,FMT) CHECK,ROUT(ROUT)
C      GO TO 25
C      END
C
C      -----VERSION MARCH 1,1972-----
C      THIS SUBROUTINE RETURNS THE FOLLOWING TO WASP IN USERS UNITS.
C      SPECIFIC HEAT AT CONSTANT PRESSURE =CP
C      SPECIFIC HEAT AT CONSTANT VOLUME  =CV
C      SPECIFIC HEAT RATIO                 =GAMMA
C      SONIC VELOCITY                      = C

```

C THE PARTIALS PTV AND PDT EXPLAINED BELOW ARE RETURNED IN COMMON.
 C
 C THE PARAMETER 'KR' WAS ADDED TO THE INPUT LIST (6/30/82, RCL)
 C

```
SUBROUTINE CPPRL(KU, KR, T, D, CP, CV, GAMMA, C)
  IMPLICIT REAL*8 (A-H, O-Z)
  COMMON/COCPO/ COC1, COC2, COC3
  COMMON/SICOF/ C1, C2, C3, C4, C5
  COMMON /PARTLS/ PTV, PDT
  COMMON/CONSTS/ TAUC, RHOA, RHOB, TAUA, E, R
  COMMON/CONV4/SCONV(5)
  COMMON/CONV5/CCONV(5)
  COMMON/IERROR/IROUT
```

```
  IROUT=8
```

```
  TS=TCHECK(KU, KR, T)
```

```
  TT=1000./TS
```

```
  DS= DCHECK(KU, D)
```

```
  CALL QMUST(DS)
```

```
  CALL QMUST2(TS)
```

```
  CQ2T2D=Q2T2D(TS)
```

```
  CQCALC=QCALC(TS)
```

```
  CQDT=QDT(DS, TS)
```

```
  CQTD=QTD(TS)
```

```
  CQ2DT=Q2DT(DS, TS)
```

```
  CQ2D2T=Q2D2T(DS, TS)
```

```
  CV = -2.*C3*TT+C4/TT-C5- R*DS*TS*TS*CQ2T2D
```

```
C--- PTV IS PARTIAL OF P BY T (NOT TAU)
```

```
C--- PDT IS PARTIAL OF P BY RHO
```

```
  PTV=R*DS*(1.+DS*(CQCALC+DS*CQDT-TS*(CQTD+DS*CQ2DT)))
```

```
  PDT=R*TT*(1.+DS*(2.*CQCALC+DS*(4.*CQDT+DS*CQ2D2T)))
```

```
  DHDT=-2.*C3*TT+C4/TT-C5+R*(1.+DS*(CQCALC+DS*CQDT-TS*(DS*CQ2DT+
  1CQTD+TS*CQ2T2D)))
```

```
  DHDD=R*(TT*CQCALC+1000.*CQTD+DS*(TT*(3.*CQDT+DS*CQ2D2T)+1000.*
  1CQ2DT))
```

```
  CP = DHDT-DHDD*(PTV/PDT)
```

```
  GAMMA=CP/CV
```

```
  CP=CP*SCONV(KU)
```

```
  CV=CV*SCONV(KU)
```

```
  GAMMAP=GAMMA * 10.* PDT
```

```
  CS=0.0
```

```
  IF ( GAMMAP.GT. 0.0) CS=1000.*DSQRT(GAMMAP)
```

```
  C= CS*CCONV(KU)
```

```
  RETURN
```

```
  END
```

```
C -----VERSION MARCH 1, 1972-----
```

```
C CHANGE 28 APRIL 1975 RCH
```

```
C COMPUTE DENSITY D GIVEN TEMPERATURE T AND PRESSURE P.
```

```
C UNITS ARE SPECIFIED BY KU. IF KR IS RETURNED OR
```

```
C SPECIFIED AS 1, THE SATURATED LIQUID AND VAPOR DENSITIES,
```

```
C DL AND DV RESPECTIVELY, ARE COMPUTED AS A FUNCTION
```

```
C OF T OR P. THE OTHER VALUE MUST BE INPUT AS 0.0 .
```

```
C
```

```
  SUBROUTINE DENS(KU, T, P, D, DL, DV, KR)
```

```
  IMPLICIT REAL*8 (A-H, O-Z)
```

```
  COMMON /CHECK1/NI
```

```
COMMON /CONV1/DCONV(5)
COMMON/CONV2/TCONV(5)
COMMON/CONV3 /PCONV(5)
COMMON/IERROR/IROUT
COMMON /CRIT/ RHOCRT,PCRT,TCRT
COMMON/ PSICON/ SIC1,SIC2,SIC3,SIC4,SIC5
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E ,R
COMMON/CHECKS/DCH1,DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,
1HSCH1,HSCH2
COMMON/TPARAM/TS
COMMON /PRHOT/PS,DS,TT
EXTERNAL DSF,DDSF
IROUT=1
IF (KR.EQ.1) GO TO 70
TS=TCHECK(KU,KR,T)
TT = TS
CALL QMUST2(TS)
GO TO 5
70 IF (T.GT.0.0) GO TO 75
PS=PCHECK(KU,KR,P)
TS=TSS(PS)
TT = TS
IF (T.LE.0.) T=TS *TCONV(KU)
CALL QMUST2(TS)
GO TO 5
75 TS = TCHECK (KU,KR,T)
TT = TS
CALL QMUST2(TS)
CALL PSSS(PS)
IF (P.LE.0.) P=PS *PCONV(KU)

C
C
C      DETERMINE REGION

5 IF (KR-1) 10,80,10
10 PS=PCHECK(KU,KR,P)
   IF (PS-PCH2)110,110,100
100 IF (TS-TCH2)130,130,120
120 KR=2
   EST1 = 1.0455
   EST2 = RHOCRT
   TEST = 1000./TS - 273.15
   IF ( TEST .GT. 100.) EST1 = 1.0107054
   IF ( TEST .GT. 180.0) GO TO 121
   IF (TEST.LT.40.) TEST=40.
   EST2=(TEST*(TEST*(TEST*(TEST*.12476711D-09-.52277795D-07)
1 * .54790571D-05)-.69617325D-03)*1.0220277 )
121 CALL ROOT (EST1,EST2,0.D0,DSF,DS)
   GO TO 150
130 KR=3
   EST=RHOCRT*3.
   CALL ROOT(EST,DCH1,0.D0,DSF,DS)
   GO TO 150
110 IF (TS-TCH2) 50,50,20
20 CALL PSSS(PSS)
   IF (DABS((PSS-PS)/PSS)-1.D-4) 60,30,30
```

```

30 IF (PS-PSS) 50,60,40
40 KR=2
41 DS=.71854566
   IF ( TS .GT. 1.7447439) DS = .822368
   IF(TS .GT. 1.9487479) DS = .8474576
   IF ( TS .GT. 2.0277805) DS = .907441
   IF ( TS .GT. 2.3086690) DS=.961538
   IF ( TS .GT. 2.6798874) DS = 1.001001
   IF ( KR .EQ. 1) GO TO 81
   GO TO 90
50 KR=3
   DS = PS*TS/(1000.*R)
   GO TO 90
C
C       REGION 1
C
60 KR=1
80 CONTINUE
   GO TO 41
81 CONTINUE
   IF(TCH2/TS.GT..9995) DS=1.151*RHOVRT
   DSL=SOLVE(DS,DSF,DDSF)
   IF(DSL.LT.RHOVRT.OR.1000./TS.GE.647.08)DSL=.118*DSQRT(DABS((647.36
1-1000./TS)**2-0.0041))+.317+2.64D-4
   DS = PS*TS/(1000.*R)
   IF (TCH2/TS.GT..985)DS=.65*RHOVRT
   IF (TCH2/TS.GT..995) DS=.75*RHOVRT
   IF (TCH2/TS.GT..999) DS=.85*RHOVRT
   IF (TCH2/TS.GT..9995) DS=.90*RHOVRT
   DSV=SOLVE(DS,DSF,DDSF)
C   THE CORRECTION ADDED TO DSL CAN BE ADDED TO DSV; HOWEVER
C   THE VAPOR LOCUS DISPLAYS A SMALL CUSP WHICH MATCHES CURRENT
C   THEORY AND SO THE CHANGE WILL NOT BE ADDED AT THIS TIME
C   PREVIOUS COEFFICIENTS FOR DL AND DV WERE -.0036 INSTEAD OF
C   .0041 AND -.098 AND .0225 INSTEAD OF -.098 AND .0269
C   THE FORMER WERE BASED ON 647.3=TC AND NOW ON 647.286=TC
C   THE ADDITIONS TO DSL AND DSV (2.64E-4AND1.2E-3) TO MATCH WASP
C ADDITIONS OF DSL AND DSV (2.64E-4&1.2E-3) TO MATCH WASP;.098 TO .11 AL
   IF((1000./TS).GT.647.15)DSV=-.11*DSQRT(DABS((647.45-1000./TS)
1**2-.0269))+.317 +1.2D-3
C
   DL=DSL*DCONV(KU)
   DV=DSV*DCONV(KU)
   RRR=.9*RHOVRT
   IF(DSV .LT. 0.) CALL ROOT(RRR,.01D0,0.D0,DSF,DSV)
   RETURN
C
C       REGIONS 2 AND 3
C
90 DS=SOLVE(DS,DSF,DDSF)
150 D=DS*DCONV(KU)
   RETURN
   END
C -----VERSION MARCH 1,1972-----
C--- PARTIAL DER OF Q --- PQ/PRHO

```

```

C
FUNCTION QDTA(TAU)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /QAUX/ RBDIF(8),RADIF(8),ER,ED,TADIF(7)
COMMON /COF/ A(10,7)
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E,R
COMMON/XMINUS/XM1(7)
COMMON/QS2/SUMI(7)
EQUIVALENCE (SUMI(1),SUM)
1 TSUM=0.0
DO 2 J=2,7
2 TSUM=TSUM+TADIF(J)*SUMI(J)
QDTA=SUM*(TAU-TAUC)*TSUM
RETURN
ENTRY QDT(D,TAU)
SUM=0.0
DO 10 I=2,8
10 SUM=SUM+XM1(I-1)*A(I,1)*RADIF(I-1)
SUM=SUM+ER*(A(10,1)-E*(A(9,1)+A(10,1)*D))
DO 15 J=2,7
SUMI(J)=0.0
DO 12 I=2,8
12 SUMI(J)=SUMI(J)+XM1(I-1)*A(I,J)*RBDIF(I-1)
SUMI(J)=SUMI(J)+ER*(A(10,J)-E*(A(9,J)+A(10,J)*D))
15 CONTINUE
GO TO 1
END

C -----AUGUST 1, 1973 VERSION-----
C FUNCTION USED TO SOLVE FOR DENSITY D GIVEN TEMPERATURE
C AND PRESSURE
C
FUNCTION DSF(D )
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E ,R
COMMON /PRHOT/ PS,DS,TS
CALL QMUST(D )
PSTATE=1000.*R*D /TS*(1.+D *(QCALC(TS)+D *QDT(D ,TS)))
DSF=PSTATE-PS
RETURN

C
ENTRY DDSF(D )
CALL QMUST(D)
DSF=1000.*R/TS*(1.+D*(2.0*QCALC(TS)+4.0*D*QDT(D,TS)+D*D*Q2D2T(D,
1TS)))
RETURN
END

C -----AUGUST 1, 1973 VERSION-----
C MODIFIED RCH 30 MAY 1975
C CALCULATE THE VISCOSITY GIVEN TAU,P,AND D IN USER-S UNITS KU.
C ANSWER RETURNED IN USER-UNITS IN SVISC.
C
SUBROUTINE VISC(KU,KR,TIN,PIN,DIN,SVISC)
IMPLICIT REAL*8 (A-H,O-Z)
DIMENSION AVO(4),DT(6),DD(5),BV(6,5)
DIMENSION BV1(6),BV2(6),BV3(6),BV4(6),BV5(6)

```

```

EQUIVALENCE (BV1(1),BV(1,1)),(BV2(1),BV(1,2)),(BV3(1),BV(1,3))
1,(BV4(1),BV(1,4)),(BV5(1),BV(1,5))
COMMON/IERROR/IROUT
COMMON/CRIT/ RHOCRT,PCRT,TCRT
COMMON /TPARAM/ TIN1
COMMON/CONV7/MCONV(5)
COMMON/TESTMU/UNITMU
REAL*8 MCONV
DATA AVO/1.81583D-2,1.77624D-2,1.05287D-2,-3.6744D-3/
DATA RHOS,TSTR/.317763D00,647.27D00/
DATABV1/0.5019380,0.1628880,-0.1303560,0.9079190,-0.5511190,0.1465
143D00/
DATABV2/0.235622D00,0.789393D00, 0.673665D00,1.207552D00, 0.067066
15D00,-0.084337D00/
DATABV3/-0.274637D00,-0.743539D00,-0.959456D00,-0.687343D00,-0.497
1089D00,0.195286D00/
DATABV4/0.145831D00,0.263129D00,0.347247D00,0.213486D00,0.100754D0
10,-0.032932D00/
DATABV5/-0.0270448,-0.0253093,-0.0267758,-0.0822904,0.0602253,-0.0
1202595/
IROUT=9
TIN1=TIN
C---
C---TK IS DEG K, T IS DEG C, TR IS REDUCED TEMP
TK=1000./TCHECK(KU,KR,TIN)
T = TK- 273.15
TR=TK/TCRT
C---P IS BARS, PMN IS MEGA NEWTONS/M*M ,PR IS REDUCED PRESSURE
PMN=PCHECK(KU,KR ,PIN)
P = 10.0*PMN
PR=PMN/PCRT
C--- DS IS G/CC, SPVR IS REDUCED SPECIFIC VOLUME.
DS=DCHECK(KU,DIN)
SPVR= RHOCRT/DS
C
C CHECK FOR OUT OF RANGE ON P AND T
C
IF ( P .LT. .99 .OR. P .GT. 1000.01) WRITE(6,100) T,P
IF ( T .GT. 900.0 .OR. T .LT. 0.0 ) WRITE(6,100) T,P
100 FORMAT(1H ,48H OUT OF RANGE. VISCOSITY EXTRAPOLATED FOR T=
1,F12.4, 4H P= ,F12.4)
C
C CALCULATE VISCOSITY FOR ALL REGIONS TO 900 CENT AND 1000 BAR
C
TST=TSTR/TK-1.
DT(1)=1.
DT(2)=TST
DT(3)=TST*DT(2)
DT(4)=TST*DT(3)
DT(5)=TST*DT(4)
DT(6)=TST*DT(5)
DR=DS/RHOS
DELD=DR-1.
DD(1)=1.
DD(2)=DELD

```



```

DD(3)=DELD*DD(2)
DD(4)=DELD*DD(3)
DD(5)=DELD*DD(4)
SUM=0.
101 DO 103 I=1,6
DO 103 J=1,5
103 SUM=SUM+BV(I,J)*DT(1)*DD(J)
DELMU=DEXP(DR*SUM)
102 TSR=TSTR/TK
AMUO=DSQRT(TK/TSTR)/(((TSR*AVO(4)+AVO(3))*TSR+AVO(2))*TSR+AVO(1))
SVISC=DELMU*AMUO*1.D-5 *MCONV(KU)
RETURN
END
C -----VERSION MARCH 1,1972-----
C THIS ROUTINE COMPUTES ENTROPY GIVEN THE TEMPERATURE PARAMETER
TT
C AND THE DENSITY D. I/O UNITS ARE SPECIFIED BY KU.
C IF SATURATION VALUES ARE NEEDED,THIS ROUTINE MUST BE CALLED TWICE
C WITH DL AND DV INPUT AS D.
C ENTROPY IS RETURNED IN S.
C
SUBROUTINE ENT(KU,TT,D,S,KR)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON/SICOF / PS11,PSI2,PSI3,PSI4,PSI5
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E ,R
COMMON/IERROR/IROUT
COMMON/CONV4/SCONV(5)
IROUT=5
TS=TCHECK(KU,KR,TT)
DS=DCHECK(KU,D)
CALL QMUST(DS)
CALL QMUST2(TS)
T=1000./TS
PSIT=2.*PSI3*T +PSI2+PSI4/T +PSI5*(1.*DLOG(T ))
SSS=-R*(DLOG(DS)+DS*(QCALC(TS)-TS*QTD(TS)))-PSIT
S=SSS*SCONV(KU)
RETURN
END
C -----VERSION MARCH 1,1972-----
C THIS ROUTINE COMPUTES ENTHALPY GIVEN THE TEMPERATURE PARAMETER
TT
C AND THE DENSITY D. I/O UNITS ARE SPECIFIED BY KU.
C IF SATURATION VALUES ARE NEEDED,THIS ROUTINE MUST BE CALLED TWICE
C WITH DL AND DV INPUT AS D.
C ENTHALPY IS RETURNED IN H.
C
SUBROUTINE ENTH(KU,TT,D,H,KR)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON/IERROR/IROUT
COMMON/CONV6/HCONV(5)
COMMON/SICOF / PS11,PSI2,PSI3,PSI4,PSI5
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E ,R
IROUT=4
TS=TCHECK(KU,KR,TT)
DS=DCHECK(KU,D)
CALL QMUST(DS)
CALL QMUST2(TS)

```

```

T=1000./TS
PSIO= (PSI3*T+PSI2)*T+PSI1+(PSI4+PSI5*T)*DLOG(T)
PSIT=2.*PSI3*T +PSI2+PSI4/T +PSI5*(1.+DLOG(T ))
H1= PSIO-T*PSIT
H2=1000.*R/TS*(1.+DS*(QCALC(TS)+TS*QTD(TS)+DS*QDT(DS,TS)))
H=(H1+H2)*HCONV(KU)
RETURN
END

```

```

C -----VERSION MARCH 1,1972-----
C COMPUTE PRESSURE P GIVEN TEMPERATURE T AND DENSITY D.
C UNITS ARE SPECIFIED BY KU. IF KR IS RETURNED OR
C SPECIFIED AS 1, P IS COMPUTED AT SATURATION AS A
C FUNCTION OF T ONLY.

```

```

SUBROUTINE PRESS(KU,T,D,P,KR)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /CONV3/PCONV(5)
COMMON/TPARAM/TS
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E ,R
COMMON/CHECKS/DCH1,DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,
1HSCH1,HSCH2
COMMON/IERROR/IROUT
IROUT=2
TS=TCHECK(KU,KR,T)

```

```

C DETERMINE REGION
C
C

```

```

IF (KR-1) 10,70,10
10 DS=DCHECK(KU,D)
IF ( KR .GT. 1) GO TO 80
IF (TS-TCH2) 50,50,20
20 CALL DENS(1,TS,ZE,ZE,DSL,DSV,1)
IF (DS-DSL) 30,60,40
30 IF (DS-DSV) 50,60,60
40 KR=2
GO TO 80
50 KR=3
GO TO 80

```

```

C REGION 1
C
C

```

```

60 KR=1
70 CALL PSSS(PS)
GO TO 90

```

```

C REGIONS 2 AND 3
C
C

```

```

80 CALL QMUST(DS)
CALL QMUST2(TS)
PS=1000.*R*DS/TS*(1.+DS*(QCALC(TS)+DS*QDT(DS,TS)))
90 P=PS*PCONV(KU)
RETURN
END

```

```

C -----VERSION MARCH 1,1972-----
C COMPUTE SATURATION PRESSURE PSSS IN BARS AS A FUNCTION OF T IN DEGREES

```

```

C          C AND RETURN ANSWER IN PSS IN MN/M**2
C
SUBROUTINE PSSS(PSS)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON/COSAT/ CPS1 ,CPS2,CPS3,CPS4,CPS5,CPS6,CPS7
C--- THE T IN THE COMMON TPARAM IS REALLY TAU
COMMON/TPARAM/T
DIMENSION CTIPS(6)
DATA CTIPS / .31602383D-03 , 1.00044775, -0.46487771D-05,
1 0.69431852D-08, 0.15621197D-12 , 1.00043357 /
TSC = 1000./T -273.15
C---CONVERT TSC(THERMODYNAMIC CELSIUS TO INT.PRACTICAL SCALE (C) WHICH
C-----IS USED IN SATURATION EQUATION
IF (TSC .GE. 9.996) GO TO 9
TS = CTIPS(6) * TSC
GO TO 10
9 TS = (((CTIPS(5)*TSC+CTIPS(4))*TSC + CTIPS(3))*TSC +CTIPS(2))
1 *TSC + CTIPS(1)
10 TS=TS+273.15
PSS=10.**((((((CPS7*TS+CPS6)*TS+CPS5)*TS+CPS4)*TS+CPS3)*TS+CPS2/TS+
1CPS1)
PSS=PSS/10.0
RETURN
END
-----VERSION 2/1/72-----
C          SAME AS ROOTX - NEEDED TO PREVENT RECURSION
C          SOLVE FOR X1 SUCH THAT FUNC(X1) = FOFX, WHERE X1 LIES
C          BETWEEN X0 AND X2
C
SUBROUTINE ROOT (X0,X2,FOFX,FUNC,X1)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /CHECK1/KOUNT
TOL=1.D-5
XX0 = X0
XX2 = X2
F0 = FUNC(XX0)
F2 = FUNC(XX2)
A=(FOFX-F0)/(F2-F0)
IF (A) 1007,120,120
120 IF (A-1.) 130,130,1008
130 IF (FOFX-0.) 80,70,80
70 ASSIGN 100 TO JUMP
GO TO 90
80 ASSIGN 110 TO JUMP
90 X = (XX0+XX2)/2.
KOUNT = 0
150 X1 = X
KOUNT = KOUNT + 1
A = FOFX - F2
FX = FUNC(X)
FXL=F0+(X-XX0)*(F2-F0)/(XX2-XX0)
B=DABS((FX-FXL)/(F2-F0))
IF (A*(FX-FOFX) .LT. 0.) GO TO 1001
XX0 = X
F0=FX

```

```

      IF (B-.3) 10,20,20
20  X = (X+XX2)/2.
      GO TO 40
1001 XX2 = X
      F2 = FX
      IF (B-.3) 10,30,30
30  X = (XX0+X)/2.
      GO TO 40
10  X=XX0+(FOFX-F0)*(XX2-XX0)/(F2-F0)
40  IF (DABS((X-X1)/X)-TOL ) 50,1000,1000
50  GO TO JUMP,(100,110)
100 IF (DABS(FUNC(X))-TOL*10. )60,1000,1000
110 IF (DABS((FOFX-FUNC(X))/FOFX)-TOL ) 60,1000,1000
1000 IF (KOUNT.GT.40) TOL=TOL*10.
      IF (KOUNT.GT.60) TOL=TOL*10.
      IF (KOUNT.GT.80) TOL=TOL*10.
      IF (KOUNT.LT.100) GO TO 150
160 WRITE (6,170) X1,X
170 FORMAT (1HL,79HAN ITERATION HAS BEEN TERMINATED AT 100 ITERATIONS.
      1 THE LAST TWO VALUES WERE ,3G15.5)
60  X1=X
      RETURN
1007 X1 = X0
      GO TO 140
1008 X1 = X2
140 WRITE(6,141)
141 FORMAT(1H0,24H SOLUTION OUT OF RANGE )
      RETURN
      END

```

```

C -----VERSION 2/1/72-----
C SOLVE FOR X1 SUCH THAT FUNC(X1) = FOFX, WHERE X1 LIES
C BETWEEN X0 AND X2
C

```

```

SUBROUTINE ROOTX(X0,X2,FOFX,FUNC,X1)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /CHECK2/KOUNT
TOL=1.D-5
XX0 = X0
XX2 = X2
F0 = FUNC(XX0)
F2 = FUNC(XX2)
A=(FOFX-F0)/(F2-F0)
IF (A) 1007,120,120
120 IF (A-1.) 130,130,1008
130 IF (FOFX-0.) 80,70,80
70 ASSIGN 100 TO JUMP
GO TO 90
80 ASSIGN 110 TO JUMP
90 X = (XX0+XX2)/2.
KOUNT = 0
150 X1 = X
KOUNT = KOUNT + 1
A = FOFX - F2
FX = FUNC(X)
FXL=F0+(X-XX0)*(F2-F0)/(XX2-XX0)

```

```

      B=DABS((FX-FXL)/(F2-F0))
      IF (A*(FX-FOFX) .LT. 0.) GO TO 1001
      XX0 = X
      F0=FX
      IF (B-.3) 10,20,20
20    X = (X+XX2)/2.
      GO TO 40
1001  XX2 = X
      F2 = FX
      IF (B-.3) 10,30,30
30    X = (XX0+X)/2.
      GO TO 40
      10 X=XX0+(FOFX-F0)*(XX2-XX0)/(F2-F0)
      40 IF (DABS((X-X1)/X)-TOL ) 50,1000,1000
      50 GO TO JUMP,(100,110)
      100 IF (DABS(FUNC(X))-TOL*10. )60,1000,1000
      110 IF (DABS((FOFX-FUNC(X))/FOFX)-TOL ) 60,1000,1000
1000  IF (KOUNT.GT.40) TOL=TOL*10.
      IF (KOUNT.GT.60) TOL=TOL*10.
      IF (KOUNT.GT.80) TOL=TOL*10.
      IF (KOUNT.LT.100) GO TO 150
160  WRITE (6,170) X1,X
170  FORMAT (1HL,79HAN ITERATION HAS BEEN TERMINATED AT 100 ITERATIONS.
      1 THE LAST TWO VALUES WERE ,3G15.5)
60   X1=X
      RETURN
1007  X1 = X0
      GO TO 140
1008  X1 = X2
140  WRITE(6,141)
141  FORMAT(1H0,24H SOLUTION OUT OF RANGE      )
      RETURN
      END
C     -----VERSION 2/1/72-----
C     MODIFIED FOR 1106   30 MAY 1975
C     NEWTON-RAPHSON ITERATION GIVEN AN INITIAL ESTIMATE X1
C     AND THE FUNCTIONS F AND DF
C
      FUNCTION SOLVE(XI,F,DF)
      IMPLICIT REAL*8 (A-H,O-Z)
      COMMON /CHECK1/NI
      TOL=1.D-5
      NI=0
      XO=XI
      XN=XI
10   XOO=XO
      XO=XN
C     XN=XO-F(XO)/DF(XO)
      A=F(XO)
      B=DF(XO)
      XN=XO-A/B
      NI=NI+1
      IF (DABS((XN-XO)/XN)-TOL ) 70,20,20
20   IF (NI.GT.40) TOL=TOL*10.
      IF (NI.GT.60) TOL=TOL*10.

```

```

      IF (NI.GT.80) TOL=TOL*10.
      IF (NI-100) 30,50,50
30  IF (DABS((XN-XOO)/XN)-TOL ) 40,10,10
40  XN=(XO+XN)/2.
      GO TO 10
50  WRITE (6,60) XOO,XO,XN
60  FORMAT (1HL,81HAN ITERATION HAS BEEN TERMINATED AT 100 ITERATIONS.
      1 THE LAST THREE VALUES WERE ,3G15.5)
70  SOLVE=XN
      RETURN
      END

```

C -----VERSION MARCH 1,1972-----

C--- THE FUNCTION Q(RHO,TAU)

C

```

      FUNCTION QCALC(TAU)
      IMPLICIT REAL*8 (A-H,O-Z)
      COMMON/CHECKS/DCH1,DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,
      1HSCH1,HSCH2
      COMMON /QAUX/ RBDIF(8), RADIF(8),ER,ED, TADIF(7)
      COMMON /COF / A(10,7)
      COMMON/QS1/SUMI(7)
      TSUM = 0.0
      DO 4 J=2,7
4  TSUM=TSUM+TADIF(J)*SUMI(J)
      QCALC=SUMI(1)+(TAU-TCH2)*TSUM
      RETURN
      END

```

C -----VERSION MARCH 1,1972-----

C

```

      SUBROUTINE QMUST(D)
      IMPLICIT REAL*8 (A-H,O-Z)
      COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E ,R
      COMMON /QAUX / RBDIF(8),RADIF(8),ER,ED,TADIF(7)
      COMMON /COF/ A(10,7)
      COMMON/QS1/SUMI(7)
      RADIF (1)= 1.0
      RADIF (2) = D- RHOA
      RBDIF (1) = 1.0
      RBDIF (2) = D- RHOB
      DO 1 I= 3,8
      RBDIF (I) = RBDIF (I-1)* RBDIF(2)
1  RADIF (I)= RADIF (I-1) *RADIF(2)
      ED = E*D
      ER= 1.0/ DEXP(ED)
      SUMI(1)=0.0
      DO 4 I=1,8
4  SUMI(1)=SUMI(1)+A(I,1)*RADIF(I)
      SUMI(1)=SUMI(1)+ER*(A(9,1)+A(10,1)*D)
      DO 6 J=2,7
      SUMI(J)=0.0
      DO 5 I=1,8
5  SUMI(J)=SUMI(J)+A(I,J)*RBDIF(I)
      SUMI(J)=SUMI(J)+ER*(A(9,J)+A(10,J)*D)
6  CONTINUE
      RETURN

```

```

ENTRY QMUST2(TAU)
TADIF (1) = 0.0
TADIF (2) = 1.0
TADIF (3) = TAU-TAUA
DO 2 I= 4,7
2 TADIF (I)= TADIF(I-1)* TADIF(3)
RETURN
END

```

C -----VERSION MARCH 1,1972-----

C--- PARTIAL DER OF Q --- PQ/PTAU

C

```

DOUBLE PRECISION FUNCTION QTD(TAU)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /QAUX/RBDIF(8),RADIF(8),ER,ED,TADIF(7)
COMMON /COF/ A(10,7)
COMMON /CONSTS/TAUC,RHOA,RHOB,TAUA,E,R
COMMON/QS1/SUMI(7)
COMMON/XMINUS/XM1(7)
TSUM1 = 0.0
TSUM2 = 0.0
DO 18 J=3,7
TSUM1=TSUM1+XM1(J-2)*TADIF(J-1)*SUMI(J)
18 TSUM2=TSUM2+TADIF(J)*SUMI(J)
TSUM2=TSUM2+SUMI(2)
QTD=TSUM2*(TAU-TAUC)*TSUM1
RETURN
END

```

C -----VERSION MARCH 1,1972-----

C--- PARTIAL DER OF Q --- P2Q/PRHO-PTAU

C

```

DOUBLE PRECISION FUNCTION Q2DTA(TAU)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /QAUX/ RBDIF(8),RADIF(8),ER,ED,TADIF(7)
COMMON /COF/ A(10,7)
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E ,R
COMMON/QS3/SUM(6)
COMMON/XMINUS/XM1(7)
1 TSUM1=0.0
TSUM2=0.0
DO 10 J=3,7
TSUM1=TSUM1+XM1(J-2)*TADIF(J-1)*SUM(J-1)
10 TSUM2=TSUM2+TADIF(J)*SUM(J-1)
TSUM2=TSUM2+SUM(1)
TSUM1=TSUM1*(TAU-TAUC)
Q2DTA=TSUM1+TSUM2
RETURN
ENTRY Q2DT(D,TAU)
DO 20 J=2,7
SUM(J-1)=0.
DO 15 I=2,8
15 SUM(J-1)=SUM(J-1)+XM1(I-1)*A(I,J)*RBDIF(I-1)
SUM(J-1)=SUM(J-1)+ER*(A(10,J)-E*(A(9,J)+A(10,J)*D))
20 CONTINUE
GO TO 1
END

```

C -----VERSION MARCH 1,1972-----
 C---PARTIAL DER OF Q --- P2Q/PTAU2

C

```

DOUBLE PRECISION FUNCTION Q2T2D(TAU)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /QAUX/ RBDIF(8),RADIF(8),ER,ED,TADIF(7)
COMMON /COF/ A(10,7)
COMMON /CONSTS/ TAUC,RHOA,RHOB,TAUA,E,R
COMMON/QS1/SUMI(7)
COMMON/XMINUS/XM1(7)
TSUM1 = 0.0
TSUM2 = 0.0
DO 2 J=3,7
TSUM1=TSUM1+XM1(J-2)*TADIF(J-1)*SUMI(J)
IF (J.EQ.3) GO TO 2
TSUM2=TSUM2+XM1(J-2)* XM1(J-3)*TADIF(J-2)*SUMI(J)
2 CONTINUE
Q2T2D=2.0*TSUM1+(TAU-TAUC)*TSUM2
RETURN
END
```

C -----VERSION MARCH 1,1972-----
 C--- PARTIAL DER OF Q --- P2Q/PRHO2

C

```

DOUBLE PRECISION FUNCTION Q2D2TA(TAU)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON /QAUX/ RBDIF(8),RADIF(8),ER,ED,TADIF(7)
COMMON /COF/ A(10,7)
COMMON /CONSTS/ TAUC, RHOA, RHOB, TAUA, E, R
COMMON/QS4/SUMI(7)
COMMON/XMINUS/XM1(7)
1 TSUM=0.0
DO 5 J=2,7
5 TSUM=TSUM+TADIF(J)*SUMI(J)
Q2D2TA=SUMI(1)+(TAU-TAUC)*TSUM
RETURN
ENTRY Q2D2T(D,TAU)
SUMI(1)=0.0
DO 3 I=3,8
3 SUMI(1)=SUMI(1)+XM1(I-1)*XM1(I-2)*A(I,1)*RADIF(I-2)
SUMI(1)=SUMI(1)+ER*(-E*A(10,1)*(2.0-ED)+E*E*A(9,1))
DO 10 J=2,7
SUMI(J)=0.0
DO 8 I=3,8
8 SUMI(J)=SUMI(J)+XM1(I-1)*XM1(I-2)*A(I,J)*RBDIF(I-2)
SUMI(J)=SUMI(J)+ER*(-E* A(10,J)*(2.0-ED)+E*E*A(9,J))
10 CONTINUE
GO TO 1
END
```

C -----AUGUST 1, 1973 VERSION-----

C REVISED OCT 75 , MAY 76 RCH
 C THIS ROUTINE CALCULATES THE SURFACE TENSION OF LIQUID WATER AND
 C THE LAPLACE CONSTANT

C

```

SUBROUTINE SURF(KU,KR,TIN,SURFT)
IMPLICIT REAL*8 (A-H,O-Z)
```



```

COMMON/IERROR/IROUT
COMMON /CONV1/DCONV(5)
COMMON/CONV9/STCONV(5)
COMMON/CONV10/ALCONV(5)
COMMON /LAPLAC/ ALC
C---UNITS OF G - M/S**2
  DATA G ,TK/9.80665D00,647.15D00/
  IROUT=11
C---T IS DEG K
  TAU=TCHECK(KU, KR, TIN)
  T = 1000./TAU
  SURFT=0.0
  ALC=0.0
  IF (T.GT.TK) RETURN
C--- UNITS OF SURFT MUST BE DYNE/CM
C--- UNITS OF ALC IS MM.
  TR=T/TK
  R=DABS(1.-TR)
  SURFT=235.8 *R**1.256*(1.-.625*R)
  IF (TR.GT. .998) GO TO 2
  CALL DENS(KU,TIN,ZE,ZE,DL,DV,1)
  ALC = DSQRT (SURFT/ (G* DABS(DL-DV) ))
C---CONVERSION FACTOR FOR RESULTS TO BE IN MM AS IN THE TABLES
  2 ALC=ALC*ALCONV(KU)*DSQRT(DCONV(KU))
  SURFT=SURFT*STCONV(KU)
  RETURN
  END
C -----VERSION MARCH 1,1972-----
C CHANGE 10 MAY 1975 RCH
C THE YATA MINAMIYAMA FORM FOR THERM COND IS NOT NECESSARILY
C THE FORM ACCEPTABLE TO IAPS BUT ADDED HERE BECAUSE OF ITS
C SIMPLICITY AND ACCURACY RCH 5 JULY 1977
C SUBROUTINE CALCULATES THE THERMAL CONDUCTIVITY IN INTERNAL
C UNITS OF W/CM-K AND CONVERTS TO USERS UNITS
C EQUATIONS ARE THE INTERNATIONALLY AGREED UPON ONES IN REGIONS
C WHERE SAME ARE AVAILABLE AND ARE PROPOSED EQUATIONS IN OTHER
C REGIONS.
C THE NEAR SUBCRITICAL REGION IS THE AUTHORS FIT
C
SUBROUTINE THERM(KU, KR, PIN, TIN, DIN, EXCESK, TCOND)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON/CONV8/KCONV(5)
COMMON/IERROR/IROUT
COMMON/ITERAT/TR, T0, T1, T2, T3, T4, T5, T6, T7, T8
REAL*8 KCONV
COMMON /CRIT/ RHOCRT, PCRT, TCRT
COMMON/TPARAM/TAU
IROUT=10
PMN=PCHECK(KU, KR, PIN)
TAU=TCHECK(KU, KR, TIN)
DS=DCHECK(KU, DIN)
C CONVERT TAU AND PMN TO VARIOUS UNITS
TK=1000./TAU
TR = TK/TCRT
T = TK-273.15

```

```

PBAR = PMN*10.
PR=PMN/PCRT
C---OUT OF RANGE CHECK ON PRESS AND TEMP.
IF (PBAR.LT. .01 .OR. PBAR.GT.1000.) WRITE(6,151) TIN,PIN
IF (T.LT.0.0.OR.T.GT.800.) WRITE(6,151) TIN,PIN
151 FORMAT (1H0, 5H T =,F12.4,8H OR P =,F12.4, 64HIS OUT OF RANGE,
1RETURNED THERMAL CONDUCTIVITY IS EXTRAPOLATED )
DATA A0,A1,A2,A3/1.02811D-2,2.99621D-2,1.56146D-2,-4.22464D-3/
DATA TC,DC/647.3D00,.3177D00/
DATA C1,C2,C3,C4,C5,C6/.642857D00,-4.11717D00,-6.17937D00,3.08976D
1-03,8.22994D-02,10.0932D00/
DATA Q1,Q2,Q3,Q4/7.01309D-2,1.1852D-2,1.69937D-3,-1.02D00/
T=TK
TR=T/TC
D=DS
R=D/DC
SUM1=DSQRT(TR)*(((A3*TR+A2)*TR+A1)*TR+A0)
SUM2=-.39707*.400302*R+1.06*DEXP(-.171587*(R+2.39219)**2)
DELT2=DABS(TR-1.)*C4
A=2.*C5/DELT2**.6
B=1.+A
D2=1./DELT2
IF(TR.LT.1.) D2=C6/DELT2**.6
ZZ=C2*TR**1.5+C3/R**5
IF(ZZ.LE.-60.)GO TO 301
ZZZ=DEXP(ZZ)
GO TO 302
301 ZZZ=0.0
302 CONTINUE
SUM4=(Q1/TR**10+Q2)*R**1.8*DEXP(C1*(1.-R**2.8))
1+Q3*D2*R**A*DEXP(A*(1.-R**B)/B) + Q4*ZZZ
ANS=SUM1+SUM2+SUM4
TCOND=ANS*KCONV(KU)
RETURN
END
FUNCTION TSS(PS)
IMPLICIT REAL*8 (A-H,O-Z)
COMMON/CHECKS/DCH1(1),DCH2,PCH1,PCH2,PCH3,TCH1,TCH2,TCH3,DST,TST,H
1SCH1,HSCH2
COMMON/COSAT/ CPS1 ,CPS2,CPS3,CPS4,CPS5,CPS6,CPS7
COMMON/BEND9/A1,A2,A3,A4,A5
DIMENSION CTT(6)
DATA CTT /-.30733645D-03, 0.99955209,0.46490458D-05,-.69336443D-08
1,-0.18086305D-12 , .99956709 /
EXTERNAL TSSF,DTSSF
PS1=PS*10.0
A1=CPS1-DLOG10(PS1)
A2=5.*CPS7
A3=4.*CPS6
A4=3.*CPS5
A5=2.*CPS4
TESTM =(1000./TCH2 -20.0 )
TSS=SOLVE(TESTM,TSSF,DTSSF)
IF (PS1.LT..085) CALL ROOT(273.15D0,316.D0,0.D0,TSSF,TSS)
TSS=TSS-273.15

```

C---CONVERT THE CALCULATED SATURATION TEMP. FROM INT. PRACTCAL SCALE
 C-----C) TO THERMODYNAMIC CELSIUS SCALE

```

    TSIP=TSS
    IF (TSS .GT. 10.) GO TO 9
    TSS = CTT(6)* TSS
    GO TO 10
  9 TSS = (((CTT(5)*TSS + CTT(4))*TSS + CTT(3))*TSS + CTT(2))*TSS +
  1   CTT(1)
  10 TSS = 1000./((TSS+273.15)
    RETURN
    END
    FUNCTION TSSF(TSS)
    IMPLICIT REAL*8 (A-H,O-Z)
    COMMON/COSAT/ CPS1 , CPS2,CPS3,CPS4,CPS5,CPS6,CPS7
    COMMON/BEND9/A1,A2,A3,A4,A5
    TSSF=(((CPS7*TSS+CPS6)*TSS+CPS5)*TSS+CPS4)*TSS+CPS3)*TSS+CPS2/
  1TSS+A1
    RETURN
    ENTRY DTSSF(TSS)
  
```

C
 C
 C
 C

DERIVATIVE OF FUNCTION USED TO SOLVE FOR SATURATION
 TEMPERATURE TSS GIVEN PRESSURE

```

    TSSF=(((A2*TSS+A3)*TSS+A4)*TSS+A5)*TSS+CPS3-CPS2/((TSS*TSS)
    RETURN
    END
  
```

C
 C
 C

SUBROUTINE CLADH(P,TB,FW,DE,V,HY,H,D,TFRIG)

C
 C
 C
 C
 C

*** THIS SUBROUTINE CALCULATES THE CLADDING HEAT TRANSFER COEFFICIENT
 THE UNITS USED ARE; P IN PSIA,TBULK IN F,DE IN FT, V IN FT/S
 H IS RETURNED IN BTU/FT**2-S-R.

```

    IMPLICIT REAL*8(A-H,O-Z)
    REAL*8 MU,MUL,MUV,K,KL,KV
    COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
  1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
  2KU
    AF=0.3277
    CC=0.0333*(AF/(AF*FW+AF))+0.0127
    XM=0.8
    XN=0.33333
    CALL FRIG(TB,P,D,HY,TFRIG)
    RE=DE*V*D/MU
    PR=CP*MU/K
    H=CC*K/DE*(RE**XM)*(PR**XN)
    RETURN
    END
  
```

C
 C
 C
 C

SUBROUTINE WALLH(P,TB,TF,DE,V,H,TFRIG,D)

```

C *** THIS SUBROUTINE CALCULATES THE WALL HEAT TRANSFER COEFFICIENT ***
C THE UNITS USED ARE;P IN PSIA,TB IN F,TF IN F,DE IN FT,
C V IN FT/S,H IS RETURNED IN BTU/FT**2-S-R
C

```

```

      IMPLICIT REAL*8(A-H,O-Z)
      REAL*8 MU,MUL,MUV,K,KL,KV
      COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
      CALL FRIG(TB,P,D,HY,TFRIG)
      REB=D*V*DE/MU
      IF(REB.GT.2400.)GO TO 1
      H=4.364*K/DE
      GO TO 2
1 CALL FRIG(TF,P,D,HY,TFRIG)
      REF=D*V*DE/MU
      PRF=CP*MU/K
      G=DLOG10(16.76/REF)
      GG=2.*DLOG10(-5.08/REF*G)
      F=GG*GG
      FS=1./F
      CALL FRIG(TB,P,D,HY,TFRIG)
      H=D*CP*V*FS/(8.*PRF**1.3)
2 CONTINUE
      RETURN
      END

```

```

C
C
C

```

```

      SUBROUTINE SPONGE(ID,J,KK,L,M,X,Y,R)

```

```

C
C
C
C
C
C

```

```

      THIS SUBROUTINE CALCULATES THE POSITION OF EACH FUEL ROD
      GIVEN THE COORDINATES KK,&L. THE RETURNED POSITION IS GIVEN
      IN X-Y COORDINATES AND THE RADIUS FROM THE CORE CENTER IS ALSO
      RETURNED. ALL DIMENSIONS ARE IN

```

```

      IMPLICIT REAL*8(A-H,O-Z)
      REAL*8 MU,MUL,MUV,K,KL,KV
      YCAP=9.49275
      XCAP=5.4806
      I=ID-1
      XIV=FLOAT(I)
      IB=I/2*2
      IF(I.EQ.IB)GO TO 1005
      J1=(I+1)/2
      XJV=FLOAT(J)
      RCX=2.*(XJV-1.)*XCAP+XCAP
      RCY=YCAP*XIV
      IF(J.GT.J1)RCX=0.0
      IF(J.GT.J1)RCY=0.0
      GO TO 1010
1005 J1=(I+2)/2
      XJV=FLOAT(J)
      RCX=2.*XCAP*(XJV-1.)
      RCY=YCAP*XIV

```

```

IF(J.GT.J1)RCX=0.0
IF(J.GT.J1)RCY=0.0
1010 CONTINUE
XK=FLOAT(KK)
YP=0.398372*(12.-XK)
XL=FLOAT(L)
IF(KK.LE.12)XLMAX=XK+11.
IF(KK.GT.12)XLMAX=(24.-XK)+11.
IF(KK.LE.12)XPMAX=YP*0.57735+(XK-1.)*0.46
IF(KK.GT.12)XPMAX=DABS(YP)*0.57735+(23.-XK)*0.46
XP=XPMAX-(XL-1.)*0.46
XPP=-YP*0.5+XP*0.866
YPP=XP*0.5+YP*0.866
AXP=DABS(XP)
IF(AXP.GT.XPMAX)XPP=0.0
IF(AXP.GT.XPMAX)YPP=0.0
X=(RCX+XPP)/12.
Y=(RCY+YPP)/12.
R=DSQRT(X**2+Y**2)
RETURN
END

```

C
C
C

```

SUBROUTINE SPINK(I,J,KK,L,M,MDOT,N,T,P,V,Z,DZ,QGEN,DE,AC,TFRIG,D,
1PDENS,ZMAX,HT)

```

C
C
C
C
C
C
C
C
C

```

*** THIS SUBROUTINE IDENTIFIES THE CHANNEL TYPE GIVEN KK,L,&M.
GIVEN MDOT IN LBM/S,T IN F,P IN PSIA,Z IN FT, AND DZ IN FT IT
CALCULATES THE CHANNEL AREA AND RETURNS THE EQUIVALENT DIAMETER
THE CHANNEL VELOCITY IN FT/S AND THE RATE OF HEAT GENERATION
IN BTU/S.

```

```

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
AF=3.14159*((0.38/12.)**2)/4.+5.4512D-04
IF((N.EQ.1).OR.(N.EQ.2))GO TO 2
IF(N.EQ.3)GO TO 3
IF(N.EQ.4)WRITE(6,1)
1 FORMAT(1H1,20X,'N EQUALS 4, THIS IS N.G.')
```

GO TO 4

```

2 AC=0.0324/144.
DEE=0.723/12.
DE=4.*AC/DEE
X1=1.017
XGD=2.
IF(N.EQ.2)XGD=3.
AG=AC+AF/XGD
GO TO 4
3 AC=0.00628/144.
DEE=0.480/12.

```

```

DE=4.*AC/DEE
X1=0.45
XGD=6.
AG=AC*AF/XGD
4 CONTINUE
AT=(125.*0.0324/144.+19.*0.00628/144.)*6.
CALL FRIG(T,P,D,HT,TFRIG)
VBAR=MDOT/(AT*D)
V=VBAR*X1

```

```

C
C *** FIND LOCATION OF CHANNEL ***
C

```

```

CALL SPONGE(I,J,KK,L,M,XX,YY,R)
ABZ=DABS((0.51873*ZMAX-Z)*3.14159/(1.19385*ZMAX))
QGEN=PDENS*AG*DZ*26.84*DCOS(ABZ)
RETURN
END

```

```

C
C
C
C
C SUBROUTINE ZICK(T,P,AC,DE,V,DZ,Q,PITCH,CLADOD,XLEAD,PE,TE,TFRIG,D,
1H)

```

```

C
C THIS SUBROUTINE ESTIMATES VALUES OF EXIT TEMPERATURE IN DEGREES
C F AND EXIT PRESSURE IN PSIA GIVEN INLET TEMPERATURE IN DEGREES F
C GIVEN
C INLET PRESSURE IN PSIA, CHANNEL AREA IN FT**2, EQUIVALENT DIAMETER
C IN FT, COOLANT VELOCITY IN FT/S, CHANNEL HEAT GENERATION RATE IN
C BTU/S, FUEL PIN PITCH IN FT, CLADDING DIAMETER IN FT, AND THE WIRE
C WRAP LEAD IN FT.
C
C

```

```

C
C IMPLICIT REAL*8(A-H,O-Z)
C REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
C COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
C CALL FRIG(T,P,D,H,TFRIG)
C MDOT=V*AC*D
C TE=Q/(CP*MDOT)+T
C RE=DE*V*D/MU
C PR=CP*MU/K
C G=DLOG10(16.76/RE)
C GG=2.*DLOG10(-5.08/RE*G)
C F=GG*GG
C FS=1./F
C E=PITCH/CLADOD
C EE=E**6.94
C EEE=E**0.124
C E4=(XLEAD/CLADOD)**2.239
C E5=(29.7*EE*RE**0.086)/E4
C XM=1.034/EEE+E5
C PE=- (XM*FS*DZ*D*V**2)/(DE*2.*32.2*144.)+P
C RETURN
C END

```

C
C
C
C

SUBROUTINE CLADT(P,T,FW,DE,V,HY,H,D,Q,TC,N,TFRIG,DZ)

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
IF(N.EQ.1)A=DZ*3.1416*0.38/(12.*2.)
IF(N.EQ.2)A=DZ*3.1416*0.38/(12.*3.)
IF(N.EQ.3)A=DZ*3.1416*0.38/(12.*6.)
CALL CLADH(P,T,FW,DE,V,H,HY,D,TFRIG)
TC=Q/(HY*A)+T
RETURN
END

SUBROUTINE SATP(P,TSAT)

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
DIMENSION PT(30),TT(30)
DATA PT /750.D+00,800.D+00,850.D+00,900.D+00,
1950.D+00,1000.D+00,1050.D+00,1100.D+00,1150.D+00,1200.D+00,
21250.D+00,1300.D+00,1350.D+00,1400.D+00,1450.D+00,1500.D+00,
31550.D+00,1600.D+00,1650.D+00,1700.D+00,1750.D+00,1800.D+00,
41850.D+00,1900.D+00,1950.D+00,2000.D+00,2100.D+00,2200.D+00,
52300.D+00,2400.D+00/
DATA TT /510.84D+00,518.21D+00,525.24D+00,531.95D+00,
1538.39D+00,544.58D+00,550.53D+00,556.28D+00,561.82D+00,
2567.19D+00,572.38D+00,577.42D+00,582.32D+00,587.07D+00,
3591.70D+00,596.20D+00,600.59D+00,604.87D+00,609.05D+00,613.13D+00,
4617.12D+00,621.02D+00,624.83D+00,628.56D+00,632.22D+00,635.80D+00,
5642.76D+00,649.45D+00,655.89D+00,662.11D+00/
NN=0
DO 11=1,30
G=P-PT(I)
NN=NN+1
IF(G.LE.0.0)GO TO 2
1 CONTINUE
2 TSAT=TT(NN)-((PT(NN)-P)*(TT(NN)-TT(NN-1)))/(PT(NN)-PT(NN-1))
RETURN
END

C
C
C
C
C

SUBROUTINE KICK(XMDOT1,XMDOT2,XMDOT3,PWRIN,PWROUT,T,NITPIC,DZ,
1DE,V,TFRIG,D)

C
C
C
C
C
C

*** THIS SUBROUTINE CALCULATES THE PRESSURE DROP OF THE WATER ***
*** REGIONS IN PSIA GIVEN THE CHANNEL FLOWRATE IN LBM/SEC THE ***
*** THE CHANNEL PRESSURE IN PSIA,AND THE CHANNEL TEMPERATURE ***
*** IN DEGREES F.

C

```

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
CALL FRIG(T,PWRIN,D,HY,TFRIG)
IF(NITPIC.EQ.1)GO TO 1
IF(NITPIC.EQ.2)GO TO 2
IF(NITPIC.EQ.3)GO TO 3
1 A=1.605/144.
MDOT=XMDOT1
DE=0.0645
GO TO 4
2 A=2.96/144.
MDOT=XMDOT2
DE=0.0655
GO TO 4
3 A=0.4474/144.
MDOT=XMDOT3
DE=0.03
4 CONTINUE
V=MDOT/(D*A)
RE=D*V*DE/MU
IF(RE.LT.2400.)GO TO 5
PR=CP*MU/K
G=DLOG10(16.76/RE)
GG=2.*DLOG10(-5.08/RE*G)
F=GG*GG
FS=1./F
PWROUT=PWRIN-((FS*DZ*D**2)/(DE*64.4))
GO TO 6
5 PWROUT=PWRIN-MU*DZ*MDOT/(113.804*DE**4)
6 CONTINUE
RETURN
END

```

C
C
C
C

```

SUBROUTINE ZICK1(T,P,PBAR,TBAR,AC,DE,V,DZ,Q,PITCH,CLADOD,XLEAD,PE,
1TE,TFRIG,D)

```

C
C
C
C
C
C
C
C
C
C

```

THIS SUBROUTINE ESTIMATES VALUES OF EXIT TEMPERATURE IN DEGREES
F AND EXIT PRESSURE IN PSIA GIVEN INLET TEMPERATURE IN DEGREES F
GIVEN AVERAGE TEMPERATURE IN DEGREES F,AVERAGE PRESSURE IN PSIA,
INLET PRESSURE IN PSIA,CHANNEL AREA IN FT**2,EQUIVALENT DIAMETER
IN FT,COOLANT VELOCITY IN FT/S,CHANNEL HEAT GENERATION RATE IN
BTU/S,FUEL PIN PITCH IN FT,CLADDING DIAMETER IN FT,AND THE WIRE
WRAP LEAD IN FT.

```

```

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,

```



```

1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
CALL FRIG(TBAR,PBAR,D,H,TFRIG)
MDOT=V*AC*D
TE=Q/(CP*MDOT)+T
RE=DE*V*D/MU
PR=CP*MU/K
G=DLOG10(16.76/RE)
GG=2.*DLOG10(-5.08/RE*G)
F=GG*GG
FS=1./F
E=PITCH/CLADOD
EE=E**6.94
EEE=E**0.124
E4=(XLEAD/CLADOD)**2.239
E5=(29.7*EE*RE**0.086)/E4
XM=1.034/EEE+E5
PE=-(XM*FS*DZ*D*V**2)/(DE*2.*32.2*144.)+P
RETURN
END

```

C
C
C
C
C
C
C
C
C
C

```

SUBROUTINE SPUD(T,P,TFRIG,PITCH,XLEAD,CLADOD,W1,W2,W3,V,NN,D)

```

```

THIS SUBROUTINE CALCULATES THE CROSS-FLOW RATES IN LBM/S-FT
GIVEN THE AVERAGE CHANNEL TEMP. IN DEGREES F, THE AVERAGE
CHANNEL PRESSURE IN PSIA, THE FUEL ROD PITCH IN FT, THE
FUEL ROD DIAMETER IN FT, THE AXIAL PITCH OF THE WIRE WRAP IN
FT, THE CHANNEL COOLANT VELOCITY IN FT/S, AND THE CHANNEL TYPE.

```

```

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
CALL FRIG(T,P,D,H,TFRIG)
G=V*D
XM=3.14159*PITCH/XLEAD
W1=XM*G*(PITCH-CLADOD)
W2=W1
IF(NN.EQ.3)GO TO 1
W3=W1
1 CONTINUE
RETURN
END

```

C
C
C

```

SUBROUTINE SPID(T,P,TFRIG,PITCH,XLEAD,CLADOD,W,V,D)

```

```

THIS SUBROUTINE CALCULATES THE CROSS-FLOW RATES FOR TYPE 3
CHANNELS. VARIABLE DEFINITIONS AND UNITS ARE THE SAME AS
THOSE OF SUBROUTINE SPUD

```

C
C
C
C

C
C

```

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
COMMON/PROPTY/DL,DV,HL,HV,S,SL,SV,CV,CVL,CVV,CP,CPL,CPV,GAMMA,
1GAMMAL,GAMMAV,C,CL,CVP,MU,MUL,MUV,K,KL,KV,SIGMA,EXCESK,EXCL,EXCV,
2KU
CALL FRIG(T,P,D,H,TFRIG)
G=V*D
XM=3.14159*PITCH/XLEAD
W=XM*G*(PITCH-CLADOD)
RETURN
END

```

C
C
C
C
C
C

```

SUBROUTINE TYPEC(NN,I,J,TIN,PIN)

```

```

THIS SUBROUTINE DEFINES THE CHANNEL TYPE OF EACH CHANNEL

```

```

IMPLICIT REAL*8(A-H,O-Z)
DIMENSION NITPIC(23,23,6),N(23,23,6),K1(23,23,6),K2(23,23,6)
DIMENSION K3(23,23,6),L1(23,23,6),L2(23,23,6),L3(23,23,6)
DIMENSION M1(23,23,6),M2(23,23,6),M3(23,23,6),H(23,23,6)
DIMENSION T(23,23,6),P(23,23,6)
COMMON/FRUIT/NITPIC,N,K1,K2,K3,L1,L2,L3,M1,M2,M3,H
COMMON/JING/T,P
DO 900 KK=1,23
IF(KK.LE.12)LMAX=KK+11
IF(KK.GT.12)LMAX=(24-KK)+11
DO 900 L=1,LMAX
DO 900 M=1,6
T(KK,L,M)=TIN
P(KK,L,M)=PIN
NITPIC(KK,L,M)=0
IF(KK.GT.12)GO TO 102
IF(KK.NE.1)GO TO 101
IF(L.NE.12)GO TO 104
IF((M.LE.3).OR.(M.EQ.6))N(KK,L,M)=2
IF(M.LE.2)N(KK,L,M)=1
N(KK,L,4)=3
N(KK,L,5)=3
GO TO 900

```

C

```

104 IF(M.LE.5)N(KK,L,M)=3
IF(M.LE.2)N(KK,L,M)=1
N(KK,L,3)=4
N(KK,L,4)=4
N(KK,L,6)=2
N(1,1,6)=3
N(1,1,1)=2
GO TO 900

```

C

```

101 CONTINUE
IF(L.EQ.1)GO TO 106

```

```

IF(L.LT.LMAX)GO TO 105
IF(M.LE.2)N(KK,L,M)=1
N(KK,L,4)=3
IF(M.GE.5)N(KK,L,M)=4
N(KK,L,3)=2
N(12,L,3)=3
N(12,L,2)=2
GO TO 900
C
105 IF(M.GE.3)N(KK,L,M)=4
IF(M.LE.2)N(KK,L,M)=1
GO TO 900
C
106 IF(M.LE.5)N(KK,L,M)=4
IF(M.LE.2)N(KK,L,M)=1
N(KK,L,1)=2
N(12,L,1)=3
IF(M.EQ.6)N(KK,L,M)=3
N(12,L,2)=2
GO TO 900
C
102 CONTINUE
IF(L.LT.LMAX)GO TO 107
IF(M.LE.6)N(KK,L,M)=4
N(KK,L,1)=1
N(KK,L,2)=2
N(KK,L,3)=3
N(23,L,2)=3
N(23,L,1)=2
GO TO 900
C
107 IF(M.LE.6)N(KK,L,M)=4
IF(L.EQ.1)GO TO 108
IF(M.LE.2)N(KK,L,M)=1
N(23,L,1)=2
N(23,L,2)=3
GO TO 900
C
108 IF(M.LE.6)N(KK,L,M)=4
N(KK,L,1)=3
N(KK,L,2)=2
N(23,L,2)=3
900 CONTINUE
C
DO 901 KK=1,23
IF(KK.LE.12)LMAX=KK+11
IF(KK.GT.12)LMAX=(24-KK)+11
DO 901 L=1,LMAX
DO 901 M=1,6
KK1=KK-3
KK2=KK-9
KK3=KK-15
GO TO(119,120,121,122),KK1
GO TO(118,123,124,125,117),KK2
GO TO(116,126,127,128,129),KK3

```

GO TO 901

C

116 N(KK,7,2)=2
N(KK,8,1)=2
N(KK,8,2)=2
N(KK,13,2)=2
N(KK,14,1)=2
N(KK,14,2)=2
GO TO 901

C

117 N(KK,5,5)=2
N(KK,5,4)=2
N(KK,11,5)=2
N(KK,11,4)=2
N(KK,17,5)=2
N(KK,17,4)=2
GO TO 901

C

118 N(KK,5,2)=2
N(KK,6,1)=2
N(KK,6,2)=2
N(KK,11,2)=2
N(KK,12,1)=2
N(KK,12,2)=2
N(KK,17,2)=2
N(KK,18,1)=2
N(KK,18,2)=2
GO TO 901

C

119 N(KK,5,2)=2
N(KK,6,1)=2
N(KK,6,2)=2
N(KK,11,2)=2
N(KK,12,1)=2
N(KK,12,2)=2
GO TO 901

C

120 N(KK,5,1)=2
N(KK,4,2)=2
N(KK,5,2)=3
N(KK,5,3)=3
N(KK,6,2)=4
N(KK,6,1)=4
N(KK,7,1)=2
N(KK,10,2)=2
N(KK,11,1)=2
N(KK,11,2)=3
N(KK,11,3)=3
N(KK,12,1)=4
N(KK,12,2)=4
N(KK,13,1)=2
GO TO 901

C

121 N(KK,5,1)=4
N(KK,5,2)=4

N(KK,4,3)=2
 N(KK,6,1)=4
 N(KK,6,2)=4
 N(KK,7,1)=3
 N(KK,7,6)=3
 N(KK,7,2)=2
 N(KK,10,3)=2
 N(KK,11,1)=4
 N(KK,11,2)=4
 N(KK,12,1)=4
 N(KK,12,2)=4
 N(KK,13,1)=3
 N(KK,13,2)=2
 N(KK,13,6)=3
 GO TO 901

C

122 N(KK,5,4)=2
 N(KK,6,4)=3
 N(KK,6,5)=3
 N(KK,6,3)=2
 N(KK,7,1)=4
 N(KK,7,2)=4
 N(KK,8,1)=2
 N(KK,11,4)=2
 N(KK,12,4)=3
 N(KK,12,5)=3
 N(KK,12,3)=2
 N(KK,13,1)=4
 N(KK,13,2)=4
 N(KK,14,1)=2
 N(8,8,6)=2
 N(8,14,6)=2
 GO TO 901

C

123 N(KK,4,2)=2
 N(KK,5,2)=3
 N(KK,5,3)=3
 N(KK,5,1)=2
 N(KK,6,1)=4
 N(KK,6,2)=4
 N(KK,7,1)=2
 N(KK,10,2)=2
 N(KK,11,2)=3
 N(KK,11,3)=3
 N(KK,11,1)=2
 N(KK,12,1)=4
 N(KK,12,2)=4
 N(KK,13,1)=2
 N(KK,13,6)=4
 N(KK,16,2)=2
 N(KK,17,2)=3
 N(KK,17,3)=3
 N(KK,17,1)=2
 N(KK,18,1)=4
 N(KK,18,2)=4

N(KK,19,1)=2
GO TO 901

C

124 N(KK,6,1)=4
N(KK,4,3)=2
N(KK,5,1)=4
N(KK,5,2)=4
N(KK,6,2)=4
N(KK,7,1)=3
N(KK,7,6)=3
N(KK,7,2)=2
N(KK,10,3)=2
N(KK,11,1)=4
N(KK,11,2)=4
N(KK,12,1)=4
N(KK,12,2)=4
N(KK,13,1)=3
N(KK,13,6)=3
N(KK,13,2)=2
N(KK,16,3)=2
N(KK,17,1)=4
N(KK,17,2)=4
N(KK,18,1)=4
N(KK,18,2)=4
N(KK,19,1)=3
N(KK,19,2)=2
N(KK,19,6)=3
GO TO 901

C

125 N(KK,4,4)=2
N(KK,5,4)=3
N(KK,5,5)=3
N(KK,6,1)=4
N(KK,6,2)=4
N(KK,7,1)=2
N(KK,10,4)=2
N(KK,11,4)=3
N(KK,11,5)=3
N(KK,12,1)=4
N(KK,12,2)=4
N(KK,13,1)=2
N(KK,16,4)=2
N(KK,17,4)=3
N(KK,17,5)=3
N(KK,18,1)=4
N(KK,18,2)=4
N(KK,19,1)=2
GO TO 901

C

126 N(KK,5,2)=2
N(KK,6,1)=2
N(KK,6,2)=3
N(KK,6,3)=3
N(KK,7,1)=4
N(KK,7,2)=4

```

N(KK,8,1)=2
N(KK,11,2)=2
N(KK,12,1)=2
N(KK,12,2)=3
N(KK,12,3)=3
N(KK,13,1)=4
N(KK,13,2)=4
N(KK,14,1)=2
GO TO 901

```

```

C
127 N(KK,4,3)=2
    N(KK,5,1)=4
    N(KK,5,2)=4
    N(KK,6,1)=4
    N(KK,6,2)=4
    N(KK,7,1)=3
    N(KK,7,6)=3
    N(KK,10,3)=2
    N(KK,11,1)=4
    N(KK,11,2)=4
    N(KK,12,1)=4
    N(KK,12,2)=4
    N(KK,13,1)=3
    N(KK,13,2)=2
    N(KK,13,6)=3
GO TO 901

```

```

C
128 N(KK,4,4)=2
    N(KK,5,3)=2
    N(KK,5,4)=3
    N(KK,5,5)=3
    N(KK,6,1)=4
    N(KK,6,2)=4
    N(KK,7,1)=2
    N(KK,7,6)=4
    N(KK,10,5)=4
    N(KK,10,4)=2
    N(KK,11,3)=2
    N(KK,11,4)=3
    N(KK,11,5)=3
    N(KK,12,1)=4
    N(KK,12,2)=4
    N(KK,13,1)=2
    N(KK,13,6)=4
GO TO 901
129 N(KK,5,4)=2
    N(KK,11,4)=2
901 CONTINUE
    RETURN
    END

```

```

C
C

```

```

SUBROUTINE ADJC(I,J)

```

```

C
C

```

```

THIS SUBROUTINE DEFINES WHICH CHANNELS ARE ADJACIENT TO THE

```

C GIVEN CHANNEL
C

```

IMPLICIT REAL*8(A-H,O-Z)
DIMENSION NITPIC(23,23,6),N(23,23,6),K1(23,23,6),K2(23,23,6)
DIMENSION K3(23,23,6),L1(23,23,6),L2(23,23,6),L3(23,23,6)
DIMENSION M3(23,23,6),M1(23,23,6),M2(23,23,6),H(23,23,6)
COMMON/FRUIT/NITPIC,N,K1,K2,K3,L1,L2,L3,M1,M2,M3,H
DO 3040 KK=1,23
IF(KK.LE.12)LMAX=KK+11
IF(KK.GT.12)LMAX=(24-KK)+11
DO 3040 L=1,LMAX
DO 3040 M=1,6
IF(N(KK,L,M).EQ.4)GO TO 3040
IF(N(KK,L,M).EQ.1)GO TO 3000
IF((KK.EQ.1).AND.(M.GE.5))GO TO 3010
IF((KK.LE.12).AND.(L.EQ.1))GO TO 3020
IF((KK.LE.12).AND.(L.EQ.LMAX))GO TO 3025
IF(KK.GE.12)GO TO 3030
IF(N(KK,L,M).EQ.2)GO TO 3000
GO TO 3040
3000 IF(KK.LE.12)GO TO 3002
IF(M.GT.2)GO TO 3040
IF(M.EQ.1)GO TO 3001
IF(L.EQ.LMAX)GO TO 3007
K1(KK,L,M)=KK
K2(KK,L,M)=KK
K3(KK,L,M)=KK+1
L1(KK,L,M)=L
L2(KK,L,M)=L+1
L3(KK,L,M)=L
M1(KK,L,M)=1
M2(KK,L,M)=1
M3(KK,L,M)=1
GO TO 3040
3001 K1(KK,L,M)=KK-1
K2(KK,L,M)=KK
K3(KK,L,M)=KK
L1(KK,L,M)=L
L2(KK,L,M)=L-1
L3(KK,L,M)=L
M1(KK,L,M)=2
M2(KK,L,M)=2
M3(KK,L,M)=2
GO TO 3040
3002 IF(M.GT.2)GO TO 3040
IF(M.EQ.1)GO TO 3003
IF(L.EQ.LMAX)GO TO 3006
IF(L.EQ.LMAX)GO TO 3006
K1(KK,L,M)=KK
K2(KK,L,M)=KK
K3(KK,L,M)=KK+1
L1(KK,L,M)=L
L2(KK,L,M)=L+1
L3(KK,L,M)=L+1
M1(KK,L,M)=1

```



```
M2(KK,L,M)=1
M3(KK,L,M)=1
GO TO 3040
3003 IF(KK.EQ.1)GO TO 3004
K1(KK,L,M)=KK-1
K2(KK,L,M)=KK
K3(KK,L,M)=KK
L1(KK,L,M)=L-1
L2(KK,L,M)=L-1
L3(KK,L,M)=L
M1(KK,L,M)=2
M2(KK,L,M)=2
M3(KK,L,M)=2
GO TO 3040
3004 K1(KK,L,M)=1
K2(KK,L,M)=1
K3(KK,L,M)=1
L1(KK,L,M)=L
L2(KK,L,M)=L
L3(KK,L,M)=L-1
M1(KK,L,M)=6
M2(KK,L,M)=2
M3(KK,L,M)=2
GO TO 3040
3006 K1(KK,L,M)=KK
K2(KK,L,M)=KK
K3(KK,L,M)=KK+1
L1(KK,L,M)=L
L2(KK,L,M)=L
L3(KK,L,M)=L+1
M1(KK,L,M)=3
M2(KK,L,M)=1
M3(KK,L,M)=1
IF(KK.EQ.12)GO TO 3008
GO TO 3040
3007 K1(KK,L,M)=KK
K2(KK,L,M)=KK
K3(KK,L,M)=KK+1
L1(KK,L,M)=L
L2(KK,L,M)=L
L3(KK,L,M)=L-1
M1(KK,L,M)=3
M2(KK,L,M)=1
M3(KK,L,M)=3
GO TO 3040
3008 L3(KK,L,M)=L-1
M3(KK,L,M)=3
GO TO 3040
3010 IF(M.EQ.6)GO TO 3015
K1(KK,L,M)=1
K2(KK,L,M)=1
L1(KK,L,M)=L
L2(KK,L,M)=L+1
M1(KK,L,M)=6
M2(KK,L,M)=6
```

```
GO TO 3040
3015 IF(L.EQ.1)GO TO 3016
      K1(KK,L,M)=1
      K2(KK,L,M)=1
      K3(KK,L,M)=1
      L1(KK,L,M)=L-1
      L2(KK,L,M)=L
      L3(KK,L,M)=L
      M1(KK,L,M)=5
      M2(KK,L,M)=5
      M3(KK,L,M)=1
      GO TO 3040
3016 K1(KK,L,M)=1
      K2(KK,L,M)=1
      L1(KK,L,M)=L
      L2(KK,L,M)=1
      M1(KK,L,M)=5
      M2(KK,L,M)=1
      GO TO 3040
3020 IF(M.EQ.1)GO TO 3021
      IF(M.NE.6)GO TO 3040
      K1(KK,L,M)=KK
      K2(KK,L,M)=KK-1
      L1(KK,L,M)=1
      L2(KK,L,M)=1
      M1(KK,L,M)=1
      M2(KK,L,M)=1
      GO TO 3040
3021 IF(KK.EQ.12)GO TO 3040
      K1(KK,L,M)=KK
      K2(KK,L,M)=KK
      K3(KK,L,M)=KK+1
      L1(KK,L,M)=1
      L2(KK,L,M)=1
      L3(KK,L,M)=1
      M1(KK,L,M)=2
      M2(KK,L,M)=6
      M3(KK,L,M)=6
      GO TO 3040
3025 IF(M.EQ.4)GO TO 3026
      IF(M.EQ.2)GO TO 3006
      IF(M.NE.3)GO TO 3040
      IF(KK.EQ.12)GO TO 3027
      K1(KK,L,M)=KK
      K2(KK,L,M)=KK
      K3(KK,L,M)=KK+1
      L1(KK,L,M)=L
      L2(KK,L,M)=L
      L3(KK,L,M)=L+1
      M1(KK,L,M)=2
      M2(KK,L,M)=4
      M3(KK,L,M)=4
      GO TO 3040
3026 IF(KK.EQ.12)GO TO 3040
      K1(KK,L,M)=KK
```

```

      K2(KK,L,M)=KK-1
      L1(KK,L,M)=L
      L2(KK,L,M)=L-1
      M1(KK,L,M)=3
      M2(KK,L,M)=3
      GO TO 3040
3027  K1(KK,L,M)=KK
      K2(KK,L,M)=KK
      L1(KK,L,M)=L
      L2(KK,L,M)=L
      M1(KK,L,M)=2
      M2(KK,L,M)=4
      GO TO 3040
3030  IF((L.EQ.1).AND.(M.EQ.1))GO TO 3033
      IF(L.EQ.LMAX)GO TO 3031
      IF((KK.EQ.12).AND.(N(KK,L,M).EQ.2))GO TO 3000
      IF((KK.NE.23).AND.(N(KK,L,M).EQ.2))GO TO 3000
      IF(KK.NE.23)GO TO 3040
      IF((L.EQ.1).AND.(M.EQ.1))GO TO 3040
      IF((KK.EQ.23).AND.(M.EQ.1))GO TO 3000
      IF(M.NE.2)GO TO 3040
      K1(KK,L,M)=23
      K2(KK,L,M)=23
      L1(KK,L,M)=L
      L2(KK,L,M)=L+1
      M1(KK,L,M)=1
      M2(KK,L,M)=1
      GO TO 3040
3031  IF(KK.EQ.12)GO TO 3040
      IF(M.GT.3)GO TO 3040
      IF(M.EQ.1)GO TO 3000
      IF(M.EQ.2)GO TO 3032
      K1(KK,L,M)=KK
      K2(KK,L,M)=KK-1
      L1(KK,L,M)=L
      L2(KK,L,M)=L+1
      M1(KK,L,M)=2
      M2(KK,L,M)=2
      GO TO 3040
3032  K1(KK,L,M)=KK
      K2(KK,L,M)=KK
      K3(KK,L,M)=KK+1
      L1(KK,L,M)=L
      L2(KK,L,M)=L
      L3(KK,L,M)=L-1
      M1(KK,L,M)=1
      M2(KK,L,M)=3
      M3(KK,L,M)=3
      GO TO 3040
3033  K1(KK,L,M)=KK
      K2(KK,L,M)=KK-1
      L1(KK,L,M)=1
      L2(KK,L,M)=1
      M1(KK,L,M)=2
      M2(KK,L,M)=2

```

3040 CONTINUE
K1(1,12,5)=1
K2(1,12,5)=1
L1(1,12,5)=12
L2(1,12,5)=12
M1(1,12,5)=6
M2(1,12,5)=4
K1(1,12,4)=1
K2(1,12,4)=1
L1(1,12,4)=12
L2(1,12,4)=12
M1(1,12,4)=5
M2(1,12,4)=3
K1(1,12,3)=1
K2(1,12,3)=1
K3(1,12,3)=2
L1(1,12,3)=12
L2(1,12,3)=12
L3(1,12,3)=13
M1(1,12,3)=4
M2(1,12,3)=2
M3(1,12,3)=4
K1(4,5,2)=4
K2(4,5,2)=4
K3(4,5,2)=5
L1(4,5,2)=5
L2(4,5,2)=6
L3(4,5,2)=5
M1(4,5,2)=1
M2(4,5,2)=1
M3(4,5,2)=3
K1(4,11,2)=4
K2(4,11,2)=4
K3(4,11,2)=5
L1(4,11,2)=11
L2(4,11,2)=12
L3(4,11,2)=11
M1(4,11,2)=1
M2(4,11,2)=1
M3(4,11,2)=3
K1(5,5,2)=5
K2(5,5,2)=5
L1(5,5,2)=5
L2(5,5,2)=5
M1(5,5,2)=1
M2(5,5,2)=3
K1(5,5,3)=5
K2(5,5,3)=4
L1(5,5,3)=5
L2(5,5,3)=5
M1(5,5,3)=2
M2(5,5,3)=2
K1(5,4,2)=5
K2(5,4,2)=5
K3(5,4,2)=6

L1(5,4,2)=4
L2(5,4,2)=5
L3(5,4,2)=4
M1(5,4,2)=1
M2(5,4,2)=1
M3(5,4,2)=3
K1(5,7,1)=4
K2(5,7,1)=5
K3(5,7,1)=6
L1(5,7,1)=6
L2(5,7,1)=7
L3(5,7,1)=7
M1(5,7,1)=2
M2(5,7,1)=2
M3(5,7,1)=6
K1(5,10,2)=5
K2(5,10,2)=5
K3(5,10,2)=6
L1(5,10,2)=10
L2(5,10,2)=11
L3(5,10,2)=10
M1(5,10,2)=1
M2(5,10,2)=1
M3(5,10,2)=3
K1(5,11,2)=5
K2(5,11,2)=5
L1(5,11,2)=11
L2(5,11,2)=11
M1(5,11,2)=1
M2(5,11,2)=3
K1(5,11,3)=5
K2(5,11,3)=4
L1(5,11,3)=11
L2(5,11,3)=11
M1(5,11,3)=2
M2(5,11,3)=2
K1(5,13,1)=5
K2(5,13,1)=4
K3(5,13,1)=6
L1(5,13,1)=13
L2(5,13,1)=12
L3(5,13,1)=13
M1(5,13,1)=2
M2(5,13,1)=2
M3(5,13,1)=6
K1(6,4,3)=6
K2(6,4,3)=5
K3(6,4,3)=7
L1(6,4,3)=4
L2(6,4,3)=4
L3(6,4,3)=5
M1(6,4,3)=2
M2(6,4,3)=2
M3(6,4,3)=4
K1(6,7,1)=6

K2(6,7,1)=6
L1(6,7,1)=7
L2(6,7,1)=7
M1(6,7,1)=2
M2(6,7,1)=6
K1(6,7,6)=6
K2(6,7,6)=5
L1(6,7,6)=7
L2(6,7,6)=7
M1(6,7,6)=1
M2(6,7,6)=1
K1(6,4,2)=6
K2(6,4,2)=6
K3(6,4,2)=7
L1(6,4,2)=4
L2(6,4,2)=4
L3(6,4,2)=5
M1(6,4,2)=1
M2(6,4,2)=3
M3(6,4,2)=1
K1(6,10,2)=6
K2(6,10,2)=6
K3(6,10,2)=7
L1(6,10,2)=10
L2(6,10,2)=10
L3(6,10,2)=11
M1(6,10,2)=1
M2(6,10,2)=3
M3(6,10,2)=1
K1(6,10,3)=6
K2(6,10,3)=5
K3(6,10,3)=7
L1(6,10,3)=10
L2(6,10,3)=10
L3(6,10,3)=11
M1(6,10,3)=2
M2(6,10,3)=2
M3(6,10,3)=4
K1(6,13,1)=6
K2(6,13,1)=6
L1(6,13,1)=13
L2(6,13,1)=13
M1(6,13,1)=2
M2(6,13,1)=6
K1(6,13,6)=6
K2(6,13,6)=5
L1(6,13,6)=13
L2(6,13,6)=13
M1(6,13,6)=1
M2(6,13,6)=1
K1(7,5,4)=6
K2(7,5,4)=7
K3(7,5,4)=7
L1(7,5,4)=4
L2(7,5,4)=6

L3(7,5,4)=6
M1(7,5,4)=3
M2(7,5,4)=1
M3(7,5,4)=5
K1(7,6,3)=7
K2(7,6,3)=7
K3(7,6,3)=8
L1(7,6,3)=6
L2(7,6,3)=6
L3(7,6,3)=8
M1(7,6,3)=4
M2(7,6,3)=2
M3(7,6,3)=6
K1(7,6,4)=7
K2(7,6,4)=7
L1(7,6,4)=6
L2(7,6,4)=6
M1(7,6,4)=3
M2(7,6,4)=5
K1(7,6,5)=7
K2(7,6,5)=7
L1(7,6,5)=6
L2(7,6,5)=5
M1(7,6,5)=4
M2(7,6,5)=4
K1(7,6,1)=7
K2(7,6,1)=7
K3(7,6,1)=7
L1(7,6,1)=5
L2(7,6,1)=5
L3(7,6,1)=6
M1(7,6,1)=4
M2(7,6,1)=2
M3(7,6,1)=2
K1(7,6,2)=7
K2(7,6,2)=7
K3(7,6,2)=8
L1(7,6,2)=6
L2(7,6,2)=6
L3(7,6,2)=7
M1(7,6,2)=1
M2(7,6,2)=3
M3(7,6,2)=1
K1(7,8,1)=6
K2(7,8,1)=8
K3(7,8,1)=7
L1(7,8,1)=7
L2(7,8,1)=8
L3(7,8,1)=8
M1(7,8,1)=2
M2(7,8,1)=6
M3(7,8,1)=2
K1(7,11,4)=6
K2(7,11,4)=7
K3(7,11,4)=7

L1(7, 11, 4)=10
L2(7, 11, 4)=12
L3(7, 11, 4)=12
M1(7, 11, 4)=3
M2(7, 11, 4)=1
M3(7, 11, 4)=5
K1(7, 12, 1)=7
K2(7, 12, 1)=7
K3(7, 12, 1)=7
L1(7, 12, 1)=11
L2(7, 12, 1)=11
L3(7, 12, 1)=12
M1(7, 12, 1)=4
M2(7, 12, 1)=2
M3(7, 12, 1)=2
K1(7, 12, 2)=7
K2(7, 12, 2)=7
K3(7, 12, 2)=8
L1(7, 12, 2)=12
L2(7, 12, 2)=12
L3(7, 12, 2)=13
M1(7, 12, 2)=1
M2(7, 12, 2)=3
M3(7, 12, 2)=1
K1(7, 12, 3)=7
K2(7, 12, 3)=7
K3(7, 12, 3)=8
L1(7, 12, 3)=12
L2(7, 12, 3)=12
L3(7, 12, 3)=14
M1(7, 12, 3)=2
M2(7, 12, 3)=4
M3(7, 12, 3)=6
K1(7, 12, 4)=7
K2(7, 12, 4)=7
L1(7, 12, 4)=12
L2(7, 12, 4)=12
M1(7, 12, 4)=5
M2(7, 12, 4)=3
K1(7, 12, 5)=7
K2(7, 12, 5)=7
L1(7, 12, 5)=12
L2(7, 12, 5)=11
M1(7, 12, 5)=4
M2(7, 12, 5)=4
K1(7, 14, 1)=7
K2(7, 14, 1)=8
K3(7, 14, 1)=6
L1(7, 14, 1)=14
L2(7, 14, 1)=14
L3(7, 14, 1)=13
M1(7, 14, 1)=2
M2(7, 14, 1)=6
M3(7, 14, 1)=2
K1(8, 8, 6)=7

K2(8,8,6)=7
K3(8,8,6)=8
L1(8,8,6)=6
L2(8,8,6)=8
L3(8,8,6)=8
M1(8,8,6)=3
M2(8,8,6)=1
M3(8,8,6)=1
K1(8,14,6)=7
K2(8,14,6)=7
K3(8,14,6)=8
L1(8,14,6)=12
L2(8,14,6)=14
L3(8,14,6)=14
M1(8,14,6)=3
M2(8,14,6)=1
M3(8,14,6)=1
K1(8,8,1)=8
K2(8,8,1)=8
K3(8,8,1)=8
L1(8,8,1)=8
L2(8,8,1)=8
L3(8,8,1)=7
M1(8,8,1)=6
M2(8,8,1)=2
M3(8,8,1)=2
K1(8,14,1)=8
K2(8,14,1)=8
K3(8,14,1)=8
L1(8,14,1)=14
L2(8,14,1)=14
L3(8,14,1)=13
M1(8,14,1)=6
M2(8,14,1)=2
M3(8,14,1)=2
K1(10,5,2)=10
K2(10,5,2)=10
K3(10,5,2)=11
L1(10,5,2)=5
L2(10,5,2)=6
L3(10,5,2)=5
M1(10,5,2)=1
M2(10,5,2)=1
M3(10,5,2)=3
K1(10,11,2)=10
K2(10,11,2)=10
K3(10,11,2)=11
L1(10,11,2)=11
L2(10,11,2)=12
L3(10,11,2)=11
M1(10,11,2)=1
M2(10,11,2)=1
M3(10,11,2)=3
K1(10,17,2)=10
K2(10,17,2)=10

K3(10,17,2)=11
L1(10,17,2)=17
L2(10,17,2)=18
L3(10,17,2)=17
M1(10,17,2)=1
M2(10,17,2)=1
M3(10,17,2)=3
K1(11,4,2)=11
K2(11,4,2)=11
K3(11,4,2)=12
L1(11,4,2)=4
L2(11,4,2)=5
L3(11,4,2)=4
M1(11,4,2)=1
M2(11,4,2)=1
M3(11,4,2)=3
K1(11,10,2)=11
K2(11,10,2)=11
K3(11,10,2)=12
L1(11,10,2)=10
L2(11,10,2)=11
L3(11,10,2)=10
M1(11,10,2)=1
M2(11,10,2)=1
M3(11,10,2)=3
K1(11,16,2)=11
K2(11,16,2)=11
K3(11,16,2)=12
L1(11,16,2)=16
L2(11,16,2)=17
L3(11,16,2)=16
M1(11,16,2)=1
M2(11,16,2)=1
M3(11,16,2)=3
K1(11,5,2)=11
K2(11,5,2)=11
L1(11,5,2)=5
L2(11,5,2)=5
M1(11,5,2)=1
M2(11,5,2)=3
K1(11,11,2)=11
K2(11,11,2)=11
L1(11,11,2)=11
L2(11,11,2)=11
M1(11,11,2)=1
M2(11,11,2)=3
K1(11,17,2)=11
K2(11,17,2)=11
L1(11,17,2)=17
L2(11,17,2)=17
M1(11,17,2)=1
M2(11,17,2)=3
K1(11,5,3)=11
K2(11,5,3)=10
L1(11,5,3)=5

L2(11, 5, 3)=5
 M1(11, 5, 3)=2
 M2(11, 5, 3)=2
 K1(11, 11, 3)=11
 K2(11, 11, 3)=10
 L1(11, 11, 3)=11
 L2(11, 11, 3)=11
 M1(11, 11, 3)=2
 M2(11, 11, 3)=2
 K1(11, 17, 3)=11
 K2(11, 17, 3)=10
 L1(11, 17, 3)=17
 L2(11, 17, 3)=17
 M1(11, 17, 3)=2
 M2(11, 17, 3)=2
 K1(11, 7, 1)=10
 K2(11, 7, 1)=11
 K3(11, 7, 1)=12
 L1(11, 7, 1)=6
 L2(11, 7, 1)=7
 L3(11, 7, 1)=7
 M1(11, 7, 1)=2
 M2(11, 7, 1)=2
 M3(11, 7, 1)=6
 K1(11, 13, 1)=10
 K2(11, 13, 1)=11
 K3(11, 13, 1)=12
 L1(11, 13, 1)=12
 L2(11, 13, 1)=13
 L3(11, 13, 1)=13
 M1(11, 13, 1)=2
 M2(11, 13, 1)=2
 M3(11, 13, 1)=6
 K1(11, 19, 1)=10
 K2(11, 19, 1)=11
 K3(11, 19, 1)=12
 L1(11, 19, 1)=18
 L2(11, 19, 1)=19
 L3(11, 19, 1)=19
 M1(11, 19, 1)=2
 M2(11, 19, 1)=2
 M3(11, 19, 1)=6
 K1(12, 1, 1)=12
 K2(12, 1, 1)=12
 L1(12, 1, 1)=1
 L2(12, 1, 1)=1
 M1(12, 1, 1)=2
 M2(12, 1, 1)=6
 K1(12, 1, 2)=12
 K2(12, 1, 2)=12
 K3(12, 1, 2)=13
 L1(12, 1, 2)=1
 L2(12, 1, 2)=2
 L3(12, 1, 2)=1
 M1(12, 1, 2)=1

M2(12, 1, 2)=1
M3(12, 1, 2)=1
K1(12, 4, 2)=12
K2(12, 4, 2)=12
K3(12, 4, 2)=13
L1(12, 4, 2)=4
L2(12, 4, 2)=4
L3(12, 4, 2)=4
M1(12, 4, 2)=1
M2(12, 4, 2)=3
M3(12, 4, 2)=1
K1(12, 10, 2)=12
K2(12, 10, 2)=12
K3(12, 10, 2)=13
L1(12, 10, 2)=10
L2(12, 10, 2)=10
L3(12, 10, 2)=10
M1(12, 10, 2)=1
M2(12, 10, 2)=3
M3(12, 10, 2)=1
K1(12, 16, 2)=12
K2(12, 16, 2)=12
K3(12, 16, 2)=13
L1(12, 16, 2)=16
L2(12, 16, 2)=16
L3(12, 16, 2)=16
M1(12, 16, 2)=1
M2(12, 16, 2)=3
M3(12, 16, 2)=1
K1(12, 4, 3)=12
K2(12, 4, 3)=11
K3(12, 4, 3)=13
L1(12, 4, 3)=4
L2(12, 4, 3)=4
L3(12, 4, 3)=4
M1(12, 4, 3)=2
M2(12, 4, 3)=2
M3(12, 4, 3)=4
K1(12, 10, 3)=12
K2(12, 10, 3)=11
K3(12, 10, 3)=13
L1(12, 10, 3)=10
L2(12, 10, 3)=10
L3(12, 10, 3)=10
M1(12, 10, 3)=2
M2(12, 10, 3)=2
M3(12, 10, 3)=4
K1(12, 16, 3)=12
K2(12, 16, 3)=11
K3(12, 16, 3)=13
L1(12, 16, 3)=16
L2(12, 16, 3)=16
L3(12, 16, 3)=16
M1(12, 16, 3)=2
M2(12, 16, 3)=2

M3(12, 16, 3)=4
K1(12, 7, 1)=12
K2(12, 7, 1)=12
L1(12, 7, 1)=7
L2(12, 7, 1)=7
M1(12, 7, 1)=6
M2(12, 7, 1)=2
K1(12, 13, 1)=12
K2(12, 13, 1)=12
L1(12, 13, 1)=13
L2(12, 13, 1)=13
M1(12, 13, 1)=6
M2(12, 13, 1)=2
K1(12, 19, 1)=12
K2(12, 19, 1)=12
L1(12, 19, 1)=19
L2(12, 19, 1)=19
M1(12, 19, 1)=6
M2(12, 19, 1)=2
K1(12, 7, 6)=12
K2(12, 7, 6)=11
L1(12, 7, 6)=7
L2(12, 7, 6)=7
M1(12, 7, 6)=1
M2(12, 7, 6)=1
K1(12, 13, 6)=12
K2(12, 13, 6)=11
L1(12, 13, 6)=13
L2(12, 13, 6)=13
M1(12, 13, 6)=1
M2(12, 13, 6)=1
K1(12, 19, 6)=12
K2(12, 19, 6)=11
L1(12, 19, 6)=19
L2(12, 19, 6)=19
M1(12, 19, 6)=1
M2(12, 19, 6)=1
K1(12, 23, 4)=12
K2(12, 23, 4)=11
L1(12, 23, 4)=23
L2(12, 23, 4)=22
M1(12, 23, 4)=3
M2(12, 23, 4)=3
L3(12, 22, 2)=22
K1(13, 5, 1)=13
K2(13, 5, 1)=13
K3(13, 5, 1)=13
L1(13, 5, 1)=4
L2(13, 5, 1)=4
L3(13, 5, 1)=5
M1(13, 5, 1)=2
M2(13, 5, 1)=4
M3(13, 5, 1)=2
K1(13, 11, 1)=13
K2(13, 11, 1)=13

K3(13, 11, 1)=13
L1(13, 11, 1)=10
L2(13, 11, 1)=10
L3(13, 11, 1)=11
M1(13, 11, 1)=2
M2(13, 11, 1)=4
M3(13, 11, 1)=2
K1(13, 17, 1)=13
K2(13, 17, 1)=13
K3(13, 17, 1)=13
L1(13, 17, 1)=16
L2(13, 17, 1)=16
L3(13, 17, 1)=17
M1(13, 17, 1)=2
M2(13, 17, 1)=4
M3(13, 17, 1)=2
K1(13, 4, 4)=13
K2(13, 4, 4)=13
K3(13, 4, 4)=12
L1(13, 4, 4)=5
L2(13, 4, 4)=5
L3(13, 4, 4)=4
M1(13, 4, 4)=1
M2(13, 4, 4)=5
M3(13, 4, 4)=3
K1(13, 10, 4)=13
K2(13, 10, 4)=13
K3(13, 10, 4)=12
L1(13, 10, 4)=11
L2(13, 10, 4)=11
L3(13, 10, 4)=10
M1(13, 10, 4)=1
M2(13, 10, 4)=5
M3(13, 10, 4)=3
K1(13, 16, 4)=13
K2(13, 16, 4)=13
K3(13, 16, 4)=12
L1(13, 16, 4)=17
L2(13, 16, 4)=17
L3(13, 16, 4)=16
M1(13, 16, 4)=1
M2(13, 16, 4)=5
M3(13, 16, 4)=3
K1(13, 5, 2)=13
K2(13, 5, 2)=14
K3(13, 5, 2)=14
L1(13, 5, 2)=5
L2(13, 5, 2)=5
L3(13, 5, 2)=5
M1(13, 5, 2)=1
M2(13, 5, 2)=5
M3(13, 5, 2)=1
K1(13, 11, 2)=13
K2(13, 11, 2)=14
K3(13, 11, 2)=14

L1(13, 11, 2)=11
L2(13, 11, 2)=11
L3(13, 11, 2)=11
M1(13, 11, 2)=1
M2(13, 11, 2)=5
M3(13, 11, 2)=1
K1(13, 17, 2)=13
K2(13, 17, 2)=14
K3(13, 17, 2)=14
L1(13, 17, 2)=17
L2(13, 17, 2)=17
L3(13, 17, 2)=17
M1(13, 17, 2)=1
M2(13, 17, 2)=5
M3(13, 17, 2)=1
K1(14, 5, 5)=13
K2(14, 5, 5)=13
K3(14, 5, 5)=14
L1(14, 5, 5)=5
L2(14, 5, 5)=5
L3(14, 5, 5)=5
M1(14, 5, 5)=2
M2(14, 5, 5)=4
M3(14, 5, 5)=4
K1(14, 11, 5)=13
K2(14, 11, 5)=13
K3(14, 11, 5)=14
L1(14, 11, 5)=11
L2(14, 11, 5)=11
L3(14, 11, 5)=11
M1(14, 11, 5)=2
M2(14, 11, 5)=4
M3(14, 11, 5)=4
K1(14, 17, 5)=13
K2(14, 17, 5)=13
K3(14, 17, 5)=14
L1(14, 17, 5)=17
L2(14, 17, 5)=17
L3(14, 17, 5)=17
M1(14, 17, 5)=2
M2(14, 17, 5)=4
M3(14, 17, 5)=4
K1(14, 17, 4)=14
K2(14, 17, 4)=14
K3(14, 17, 4)=13
L1(14, 17, 4)=18
L2(14, 17, 4)=17
L3(14, 17, 4)=19
M1(14, 17, 4)=1
M2(14, 17, 4)=5
M3(14, 17, 4)=1
K1(13, 5, 4)=14
K2(13, 5, 4)=13
L1(13, 5, 4)=5
L2(13, 5, 4)=5

M1(13, 5, 4)=5
M2(13, 5, 4)=5
K1(13, 11, 4)=14
K2(13, 11, 4)=13
L1(13, 11, 4)=11
L2(13, 11, 4)=11
M1(13, 11, 4)=5
M2(13, 11, 4)=5
K1(13, 17, 4)=14
K2(13, 17, 4)=13
L1(13, 17, 4)=17
L2(13, 17, 4)=17
M1(13, 17, 4)=5
M2(13, 17, 4)=5
K1(13, 5, 5)=13
K2(13, 5, 5)=13
L1(13, 5, 5)=5
L2(13, 5, 5)=4
M1(13, 5, 5)=4
M2(13, 5, 5)=4
K1(13, 11, 5)=13
K2(13, 11, 5)=13
L1(13, 11, 5)=11
L2(13, 11, 5)=10
M1(13, 11, 5)=4
M2(13, 11, 5)=4
K1(13, 17, 5)=13
K2(13, 17, 5)=13
L1(13, 17, 5)=17
L2(13, 17, 5)=16
M1(13, 17, 5)=4
M2(13, 17, 5)=4
K1(13, 7, 1)=13
K2(13, 7, 1)=12
K3(13, 7, 1)=14
L1(13, 7, 1)=7
L2(13, 7, 1)=7
L3(13, 7, 1)=5
M1(13, 7, 1)=2
M2(13, 7, 1)=2
M3(13, 7, 1)=4
K1(13, 13, 1)=13
K2(13, 13, 1)=12
K3(13, 13, 1)=14
L1(13, 13, 1)=13
L2(13, 13, 1)=13
L3(13, 13, 1)=11
M1(13, 13, 1)=2
M2(13, 13, 1)=2
M3(13, 13, 1)=4
K1(13, 19, 1)=13
K2(13, 19, 1)=12
K3(13, 19, 1)=14
L1(13, 19, 1)=19
L2(13, 19, 1)=19

L3(13, 19, 1)=17
M1(13, 19, 1)=2
M2(13, 19, 1)=2
M3(13, 19, 1)=4
K1(14, 5, 4)=14
K2(14, 5, 4)=13
K3(14, 5, 4)=14
L1(14, 5, 4)=5
L2(14, 5, 4)=7
L3(14, 5, 4)=6
M1(14, 5, 4)=5
M2(14, 5, 4)=1
M3(14, 5, 4)=1
K1(14, 11, 4)=14
K2(14, 11, 4)=13
K3(14, 11, 4)=14
L1(14, 11, 4)=11
L2(14, 11, 4)=13
L3(14, 11, 4)=12
M1(14, 11, 4)=5
M2(14, 11, 4)=1
M3(14, 11, 4)=1
K1(14, 7, 4)=13
K2(14, 7, 4)=13
K3(14, 7, 4)=14
L1(14, 7, 4)=17
L2(14, 7, 4)=19
L3(14, 7, 4)=18
M1(14, 7, 4)=3
M2(14, 7, 4)=1
M3(14, 7, 4)=1
K1(14, 6, 1)=14
K2(14, 6, 1)=14
K3(14, 6, 1)=14
L1(14, 6, 1)=5
L2(14, 6, 1)=6
L3(14, 6, 1)=5
M1(14, 6, 1)=4
M2(14, 6, 1)=2
M3(14, 6, 1)=2
K1(14, 12, 1)=14
K2(14, 12, 1)=14
K3(14, 12, 1)=14
L1(14, 12, 1)=11
L2(14, 12, 1)=12
L3(14, 12, 1)=11
M1(14, 12, 1)=4
M2(14, 12, 1)=2
M3(14, 12, 1)=2
K1(14, 18, 1)=14
K2(14, 18, 1)=14
K3(14, 18, 1)=14
L1(14, 18, 1)=17
L2(14, 18, 1)=18
L3(14, 18, 1)=17

M1(14, 18, 1)=4
M2(14, 18, 1)=2
M3(14, 18, 1)=2
K1(16, 7, 2)=16
K2(16, 7, 2)=16
K3(16, 7, 2)=17
L1(16, 7, 2)=7
L2(16, 7, 2)=8
L3(16, 7, 2)=6
M1(16, 7, 2)=1
M2(16, 7, 2)=1
M3(16, 7, 2)=3
K1(16, 13, 2)=16
K2(16, 13, 2)=16
K3(16, 13, 2)=17
L1(16, 13, 2)=13
L2(16, 13, 2)=14
L3(16, 13, 2)=12
M1(16, 13, 2)=1
M2(16, 13, 2)=1
M3(16, 13, 2)=3
K1(17, 5, 2)=17
K2(17, 5, 2)=17
K3(17, 5, 2)=18
L1(17, 5, 2)=5
L2(17, 5, 2)=6
L3(17, 5, 2)=4
M1(17, 5, 2)=1
M2(17, 5, 2)=1
M3(17, 5, 2)=3
K1(17, 11, 2)=17
K2(17, 11, 2)=17
K3(17, 11, 2)=18
L1(17, 11, 2)=12
L2(17, 11, 2)=11
L3(17, 11, 2)=10
M1(17, 11, 2)=1
M2(17, 11, 2)=1
M3(17, 11, 2)=3
K1(17, 6, 2)=17
K2(17, 6, 2)=17
L1(17, 6, 2)=6
L2(17, 6, 2)=6
M1(17, 6, 2)=3
M2(17, 6, 2)=1
K1(17, 12, 2)=17
K2(17, 12, 2)=17
L1(17, 12, 2)=12
L2(17, 12, 2)=12
M1(17, 12, 2)=3
M2(17, 12, 2)=1
K1(17, 6, 3)=17
K2(17, 6, 3)=16
L1(17, 6, 3)=6
L2(17, 6, 3)=7

M1(17,6,3)=2
M2(17,6,3)=2
K1(17,12,3)=17
K2(17,12,3)=16
L1(17,12,3)=12
L2(17,12,3)=13
M1(17,12,3)=2
M2(17,12,3)=2
K1(17,8,1)=17
K2(17,8,1)=16
K3(17,8,1)=18
L1(17,8,1)=8
L2(17,8,1)=8
L3(17,8,1)=7
M1(17,8,1)=2
M2(17,8,1)=2
M3(17,8,1)=6
K1(17,14,1)=17
K2(17,14,1)=16
K3(17,14,1)=18
L1(17,14,1)=14
L2(17,14,1)=14
L3(17,14,1)=13
M1(17,14,1)=2
M2(17,14,1)=2
M3(17,14,1)=6
K1(18,4,2)=18
K2(18,4,2)=18
K3(18,4,2)=19
L1(18,4,2)=4
L2(18,4,2)=4
L3(18,4,2)=4
M1(18,4,2)=1
M2(18,4,2)=3
M3(18,4,2)=1
K1(18,10,2)=18
K2(18,10,2)=18
K3(18,10,2)=19
L1(18,10,2)=10
L2(18,10,2)=10
L3(18,10,2)=5
M1(18,10,2)=1
M2(18,10,2)=3
M3(18,10,2)=3
K1(18,4,3)=18
K2(18,4,3)=17
K3(18,4,3)=19
L1(18,4,3)=4
L2(18,4,3)=5
L3(18,4,3)=4
M1(18,4,3)=2
M2(18,4,3)=2
M3(18,4,3)=4
K1(18,10,3)=18
K2(18,10,3)=17

K3(18,10,3)=19
L1(18,10,3)=10
L2(18,10,3)=11
L3(18,10,3)=10
M1(18,10,3)=2
M2(18,10,3)=2
M3(18,10,3)=4
K1(18,7,1)=18
K2(18,7,1)=18
L1(18,7,1)=7
L2(18,7,1)=7
M1(18,7,1)=2
M2(18,7,1)=6
K1(18,13,1)=18
K2(18,13,1)=18
L1(18,13,1)=13
L2(18,13,1)=13
M1(18,13,1)=2
M2(18,13,1)=6
K1(18,7,6)=18
K2(18,7,6)=17
L1(18,7,6)=7
L2(18,7,6)=8
M1(18,7,6)=1
M2(18,7,6)=1
K1(18,13,6)=18
K2(18,13,6)=17
L1(18,13,6)=13
L2(18,13,6)=14
M1(18,13,6)=1
M2(18,13,6)=1
K1(19,5,1)=19
K2(19,5,1)=19
K3(19,5,1)=19
L1(19,5,1)=4
L2(19,5,1)=4
L3(19,5,1)=5
M1(19,5,1)=4
M2(19,5,1)=2
M3(19,5,1)=2
K1(19,11,1)=19
K2(19,11,1)=19
K3(19,11,1)=19
L1(19,11,1)=10
L2(19,11,1)=10
L3(19,11,1)=11
M1(19,11,1)=4
M2(19,11,1)=2
M3(19,11,1)=2
K1(19,4,4)=19
K2(19,4,4)=18
K3(19,4,4)=19
L1(19,4,4)=5
L2(19,4,4)=4
L3(19,4,4)=5

M1(19,4,4)=1
 M2(19,4,4)=3
 M3(19,4,4)=5
 K1(19,10,4)=19
 K2(19,10,4)=18
 K3(19,10,4)=19
 L1(19,10,4)=11
 L2(19,10,4)=10
 L3(19,10,4)=11
 M1(19,10,4)=1
 M2(19,10,4)=3
 M3(19,10,4)=5
 K1(19,5,3)=19
 K2(19,5,3)=19
 K3(19,5,3)=20
 L1(19,5,3)=5
 L2(19,5,3)=5
 L3(19,5,3)=5
 M1(19,5,3)=2
 M2(19,5,3)=4
 M3(19,5,3)=4
 K1(19,11,3)=19
 K2(19,11,3)=19
 K3(19,11,3)=20
 L1(19,11,3)=11
 L2(19,11,3)=11
 L3(19,11,3)=11
 M1(19,11,3)=2
 M2(19,11,3)=4
 M3(19,11,3)=4
 K1(19,5,4)=19
 K2(19,5,4)=19
 K3(19,5,4)=19
 L1(19,5,4)=5
 L2(19,5,4)=5
 L3(19,5,4)=4
 M1(19,5,4)=5
 M2(19,5,4)=3
 M3(19,5,4)=4
 K1(19,11,4)=19
 K2(19,11,4)=19
 L1(19,11,4)=11
 L2(19,11,4)=11
 M1(19,11,4)=5
 M2(19,11,4)=3
 K1(19,5,5)=19
 K2(19,5,5)=19
 L1(19,5,5)=5
 L2(19,5,5)=4
 M1(19,5,5)=4
 M2(19,5,5)=4
 K1(19,11,5)=19
 K2(19,11,5)=19
 L1(19,11,5)=11
 L2(19,11,5)=10

M1(19, 11, 5)=4
M2(19, 11, 5)=4
K1(19, 5, 2)=19
K2(19, 5, 2)=19
K3(19, 5, 2)=20
L1(19, 5, 2)=5
L2(19, 5, 2)=5
L3(19, 5, 2)=5
M1(19, 5, 2)=1
M2(19, 5, 2)=3
M3(19, 5, 2)=1
K1(19, 11, 2)=19
K2(19, 11, 2)=19
K3(19, 11, 2)=20
L1(19, 11, 2)=11
L2(19, 11, 2)=11
L3(19, 11, 2)=11
M1(19, 11, 2)=1
M2(19, 11, 2)=3
M3(19, 11, 2)=1
K1(19, 7, 1)=19
K2(19, 7, 1)=18
K3(19, 7, 1)=20
L1(19, 7, 1)=7
L2(19, 7, 1)=7
L3(19, 7, 1)=5
M1(19, 7, 1)=2
M2(19, 7, 1)=2
M3(19, 7, 1)=4
K1(19, 13, 1)=19
K2(19, 13, 1)=18
K3(19, 13, 1)=20
L1(19, 13, 1)=13
L2(19, 13, 1)=13
L3(19, 13, 1)=11
M1(19, 13, 1)=2
M2(19, 13, 1)=2
M3(19, 13, 1)=4
K1(20, 5, 4)=19
K2(20, 5, 4)=19
K3(20, 5, 4)=20
L1(20, 5, 4)=5
L2(20, 5, 4)=7
L3(20, 5, 4)=6
M1(20, 5, 4)=3
M2(20, 5, 4)=1
M3(20, 5, 4)=1
K1(20, 11, 4)=19
K2(20, 11, 4)=19
K3(20, 11, 4)=20
L1(20, 11, 4)=11
L2(20, 11, 4)=13
L3(20, 11, 4)=12
M1(20, 11, 4)=3
M2(20, 11, 4)=1

```

M3(20,11,4)=1
K1(20,6,1)=20
K2(20,6,1)=20
K3(20,6,1)=20
L1(20,6,1)=6
L2(20,6,1)=5
L3(20,6,1)=5
M1(20,6,1)=2
M2(20,6,1)=2
M3(20,6,1)=4
K1(20,12,1)=20
K2(20,12,1)=20
K3(20,12,1)=20
L1(20,12,1)=12
L2(20,12,1)=11
L3(20,12,1)=11
M1(20,12,1)=2
M2(20,12,1)=2
M3(20,12,1)=4
  K1(23,12,2)=23
  K2(23,12,2)=23
  L1(23,12,2)=12
  L2(23,12,2)=12
  M1(23,12,2)=1
  M2(23,12,2)=3
  K1(23,12,3)=23
  K2(23,12,3)=22
  L1(23,12,3)=12
  L2(23,12,3)=13
  M1(23,12,3)=2
  M2(23,12,3)=2
  RETURN
  END

```

```

C
C
C
C
C

```

```

SUBROUTINE VRGN(NN)

```

```

  THIS SUBROUTINE DETERMINES WHICH VOID REGIONS ARE REMOVED FROM
  THE CORE GIVEN THE PARAMETER NN

```

```

  IMPLICIT REAL*8(A-H,O-Z)
  DIMENSION NITPIC(23,23,6),N(23,23,6),K1(23,23,6),K2(23,23,6)
  DIMENSION K3(23,23,6),L1(23,23,6),L2(23,23,6),L3(23,23,6)
  DIMENSION M1(23,23,6),M2(23,23,6),M3(23,23,6),H(23,23,6)
  COMMON/FRUIT/NITPIC,N,K1,K2,K3,L1,L2,L3,M1,M2,M3,H
  DO 710 KK=1,23
    IF(KK.LE.12)LMAX=KK+11
    IF(KK.GT.12)LMAX=(24-KK)+11
    DO 710 L=1,LMAX
      DO 710 M=1,6
        H(KK,L,M)=-1.0
710 CONTINUE
    IF(NN.EQ.1)GO TO 700
    N1=NN-1
    IF(NN.EQ.4)GO TO 700

```

```
N2=NN-4
IF(NN.LE.4)N2=5
GO TO(702,706),N1
GO TO(702,706,702,708),N2
IF(NN.EQ.10)GO TO 709
```

C

700 CONTINUE

```
H(4,5,2)=0.0
H(4,6,1)=0.0
H(4,6,2)=0.0
H(5,4,2)=0.0
H(5,5,1)=0.0
H(5,5,2)=0.0
H(5,5,3)=0.0
H(5,7,1)=0.0
H(6,4,3)=0.0
H(6,7,1)=0.0
H(6,7,2)=0.0
H(7,5,4)=0.0
H(7,6,3)=0.0
H(6,7,6)=0.0
H(7,6,4)=0.0
H(7,6,5)=0.0
H(7,8,1)=0.0
H(8,8,6)=0.0
H(10,17,2)=0.0
H(10,18,1)=0.0
H(10,18,2)=0.0
H(11,16,2)=0.0
H(11,17,1)=0.0
H(11,17,2)=0.0
H(11,17,3)=0.0
H(11,19,1)=0.0
H(12,16,3)=0.0
H(12,19,1)=0.0
H(12,19,2)=0.0
H(12,19,6)=0.0
H(13,16,4)=0.0
H(13,17,4)=0.0
H(13,17,5)=0.0
H(13,19,1)=0.0
H(14,17,4)=0.0
H(14,17,5)=0.0
H(16,7,2)=0.0
H(16,8,1)=0.0
H(16,8,2)=0.0
H(17,5,2)=0.0
H(17,6,1)=0.0
H(17,6,2)=0.0
H(17,6,3)=0.0
H(17,8,1)=0.0
H(18,4,3)=0.0
H(18,7,1)=0.0
H(18,7,6)=0.0
H(19,4,4)=0.0
```


H(19,5,4)=0.0
H(19,5,5)=0.0
H(19,5,3)=0.0
H(19,7,1)=0.0
H(19,7,6)=0.0
H(20,5,4)=0.0

C
701 CONTINUE
IF(NN.EQ.9)GO TO 704

C
702 CONTINUE
H(10,11,2)=0.0
H(10,12,1)=0.0
H(10,12,2)=0.0
H(11,10,2)=0.0
H(11,11,1)=0.0
H(11,11,2)=0.0
H(11,11,3)=0.0
H(11,13,1)=0.0
H(12,10,3)=0.0
H(12,13,1)=0.0
H(12,13,2)=0.0
H(12,13,6)=0.0
H(13,10,4)=0.0
H(13,11,4)=0.0
H(13,11,5)=0.0
H(13,13,1)=0.0
H(14,11,4)=0.0
H(14,11,5)=0.0

C
703 CONTINUE
IF(NN.EQ.9)GO TO 706

C
704 CONTINUE
H(4,11,2)=0.0
H(4,12,1)=0.0
H(4,12,2)=0.0
H(5,10,2)=0.0
H(5,11,1)=0.0
H(5,11,2)=0.0
H(5,11,3)=0.0
H(5,13,1)=0.0
H(6,10,3)=0.0
H(6,13,1)=0.0
H(6,13,2)=0.0
H(6,13,6)=0.0
H(7,11,4)=0.0
H(7,12,3)=0.0
H(7,12,4)=0.0
H(7,12,5)=0.0
H(7,14,1)=0.0
H(8,14,6)=0.0
H(10,5,2)=0.0
H(10,6,1)=0.0
H(10,6,2)=0.0

H(11,4,2)=0.0
 H(11,5,1)=0.0
 H(11,5,2)=0.0
 H(11,5,3)=0.0
 H(11,7,1)=0.0
 H(12,4,3)=0.0
 H(12,7,1)=0.0
 H(12,7,2)=0.0
 H(12,7,6)=0.0
 H(13,4,4)=0.0
 H(13,5,4)=0.0
 H(13,5,5)=0.0
 H(13,7,1)=0.0
 H(14,5,4)=0.0
 H(14,5,5)=0.0
 H(16,13,2)=0.0
 H(16,14,1)=0.0
 H(16,14,2)=0.0
 H(17,11,2)=0.0
 H(17,12,1)=0.0
 H(17,12,2)=0.0
 H(17,12,3)=0.0
 H(17,14,1)=0.0
 H(18,10,3)=0.0
 H(18,13,1)=0.0
 H(18,13,2)=0.0
 H(18,13,6)=0.0
 H(19,10,4)=0.0
 H(19,11,3)=0.0
 H(19,11,4)=0.0
 H(19,11,5)=0.0
 H(19,13,1)=0.0
 H(20,11,4)=0.0

C

705 CONTINUE
 IF(NN.EQ.7)GO TO 708
 IF(NN.EQ.9)GO TO 709

C

706 DO 707 KK=1,23
 IF(KK.LE.12)LMAX=KK+11
 IF(KK.GT.12)LMAX=(24-KK)+11
 DO 707 L=1,LMAX
 DO 707 M=1,6
 IF((N(KK,L,M).EQ.1).OR.(N(KK,L,M).EQ.4))GO TO 800
 IF((KK.EQ.1).AND.(L.GT.4))H(KK,L,M)=0.0
 IF((KK.GT.1).AND.(KK.LT.4).AND.(L.EQ.LMAX))H(KK,L,M)=0.0
 IF((KK.GT.3).AND.(KK.LT.9).AND.(L.EQ.LMAX))H(KK,L,M)=0.0
 IF((KK.GT.3).AND.(KK.LT.9).AND.(L.EQ.1))H(KK,L,M)=0.0
 IF((KK.GT.8).AND.(KK.LT.15).AND.(L.EQ.1))H(KK,L,M)=0.0
 IF((KK.GT.14).AND.(KK.LT.20).AND.(L.EQ.1))H(KK,L,M)=0.0
 IF((KK.GT.14).AND.(KK.LT.21).AND.(L.EQ.LMAX))H(KK,L,M)=0.0
 IF((KK.GT.20).AND.(KK.LT.23).AND.(L.EQ.LMAX))H(KK,L,M)=0.0
 IF((KK.EQ.23).AND.(L.GT.4))H(KK,L,M)=0.0
 GO TO 707
 800 IF(N(KK,L,M).EQ.1)H(KK,L,M)=0.0

```

707 CONTINUE
   H(4,1,6)=-1.0
   H(15,20,3)=-1.0
   IF(NN.GE.4)GO TO 709
C
708 DO 711 KK=1,23
   IF(KK.LE.12)LMAX=KK+11
   IF(KK.GT.12)LMAX=(24-KK)+11
   DO 711 L=1,LMAX
   DO 711 M=1,6
   IF((N(KK,L,M).EQ.1).OR.(N(KK,L,M).EQ.4))GO TO 810
   IF((KK.EQ.1).AND.(L.LT.5))H(KK,L,M)=0.0
   IF((KK.LT.5).AND.(L.EQ.1))H(KK,L,M)=0.0
   IF((KK.GT.8).AND.(KK.LT.16).AND.(L.EQ.LMAX))H(KK,L,M)=0.0
   IF((KK.GT.19).AND.(KK.LT.23).AND.(L.EQ.1))H(KK,L,M)=0.0
   IF((KK.EQ.23).AND.(L.LT.5))H(KK,L,M)=0.0
   H(15,20,2)=-1.0
   H(4,1,1)=-1.0
   GO TO 711
810 IF(N(KK,L,M).EQ.1)H(KK,L,M)=0.0
711 CONTINUE
   IF(NN.EQ.1)H(15,20,2)=0.0
   IF(NN.EQ.1)H(4,1,1)=0.0
   IF(NN.EQ.1)H(4,1,6)=0.0
   IF(NN.EQ.1)H(15,20,3)=0.0
709 CONTINUE
   RETURN
   END
C
C
SUBROUTINE VOID(I,J)
C
C   THIS SUBROUTINE DETERMINES THE TYPE OF VOID REGION A CHANNEL
C   IS NEXT TO
C
   IMPLICIT REAL*8(A-H,O-Z)
   DIMENSION NITPIC(23,23,6),N(23,23,6),K1(23,23,6),K2(23,23,6)
   DIMENSION K3(23,23,6),L1(23,23,6),L2(23,23,6),L3(23,23,6)
   DIMENSION M1(23,23,6),M2(23,23,6),M3(23,23,6),H(23,23,6)
   COMMON/FRUIT/NITPIC,N,K1,K2,K3,L1,L2,L3,M1,M2,M3,H
   NITPIC(1,1,1)=1
   NITPIC(1,1,5)=1
   NITPIC(1,1,6)=1
   NITPIC(1,2,5)=1
   NITPIC(1,2,6)=1
   NITPIC(1,3,5)=1
   NITPIC(1,3,6)=1
   NITPIC(1,4,5)=1
   NITPIC(1,4,6)=1
   NITPIC(1,5,5)=2
   NITPIC(1,5,6)=2
   NITPIC(1,6,5)=2
   NITPIC(1,6,6)=2
   NITPIC(1,7,5)=2
   NITPIC(1,7,6)=2

```

NITPIC(1,8,5)=2
NITPIC(1,8,6)=2
NITPIC(1,9,5)=2
NITPIC(1,9,6)=2
NITPIC(1,10,5)=2
NITPIC(1,10,6)=2
NITPIC(1,11,5)=2
NITPIC(1,11,6)=2
NITPIC(1,12,3)=2
NITPIC(1,12,4)=2
NITPIC(1,12,5)=2
NITPIC(1,12,6)=2
NITPIC(2,1,1)=1
NITPIC(2,1,6)=1
NITPIC(2,13,3)=2
NITPIC(2,13,4)=2
NITPIC(3,1,1)=1
NITPIC(3,1,6)=1
NITPIC(3,14,3)=2
NITPIC(3,14,4)=2
NITPIC(4,1,1)=2
NITPIC(4,1,6)=1
NITPIC(4,5,2)=3
NITPIC(4,6,1)=3
NITPIC(4,6,2)=3
NITPIC(4,11,2)=3
NITPIC(4,12,1)=3
NITPIC(4,12,2)=3
NITPIC(4,15,3)=2
NITPIC(4,15,4)=2
NITPIC(5,1,1)=2
NITPIC(5,1,6)=2
NITPIC(5,4,2)=3
NITPIC(5,5,1)=3
NITPIC(5,5,2)=3
NITPIC(5,5,3)=3
NITPIC(5,7,1)=3
NITPIC(5,10,2)=3
NITPIC(5,11,1)=3
NITPIC(5,11,2)=3
NITPIC(5,11,3)=3
NITPIC(5,13,1)=3
NITPIC(5,16,3)=2
NITPIC(5,16,4)=2
NITPIC(6,1,1)=2
NITPIC(6,1,6)=2
NITPIC(6,4,3)=3
NITPIC(6,7,1)=3
NITPIC(6,7,2)=3
NITPIC(6,7,6)=3
NITPIC(6,10,3)=3
NITPIC(6,13,1)=3
NITPIC(6,13,2)=3
NITPIC(6,13,6)=3
NITPIC(6,17,3)=2

NITPIC(6,17,4)=2
NITPIC(7,1,1)=2
NITPIC(7,1,6)=2
NITPIC(7,5,4)=3
NITPIC(7,6,3)=3
NITPIC(7,6,4)=3
NITPIC(7,6,5)=3
NITPIC(7,8,1)=3
NITPIC(7,11,4)=3
NITPIC(7,12,3)=3
NITPIC(7,12,4)=3
NITPIC(7,12,5)=3
NITPIC(7,14,1)=3
NITPIC(7,18,3)=2
NITPIC(7,18,4)=2
NITPIC(8,1,1)=2
NITPIC(8,1,6)=2
NITPIC(8,8,6)=3
NITPIC(8,14,6)=3
NITPIC(8,19,3)=2
NITPIC(8,19,4)=2
NITPIC(9,1,1)=2
NITPIC(9,1,6)=2
NITPIC(9,20,3)=1
NITPIC(9,20,4)=1
NITPIC(10,1,1)=2
NITPIC(10,1,6)=2
NITPIC(10,5,2)=3
NITPIC(10,6,1)=3
NITPIC(10,6,2)=3
NITPIC(10,11,2)=3
NITPIC(10,12,1)=3
NITPIC(10,12,2)=3
NITPIC(10,17,2)=3
NITPIC(10,18,1)=3
NITPIC(10,18,2)=3
NITPIC(10,21,3)=1
NITPIC(10,21,4)=1
NITPIC(11,1,1)=2
NITPIC(11,1,6)=2
NITPIC(11,4,2)=3
NITPIC(11,5,1)=3
NITPIC(11,5,2)=3
NITPIC(11,5,3)=3
NITPIC(11,7,1)=3
NITPIC(11,10,2)=3
NITPIC(11,11,1)=3
NITPIC(11,11,2)=3
NITPIC(11,11,3)=3
NITPIC(11,13,1)=3
NITPIC(11,16,2)=3
NITPIC(11,17,1)=3
NITPIC(11,17,2)=3
NITPIC(11,17,3)=3
NITPIC(11,19,1)=3

NITPIC(11,22,3)=1
NITPIC(11,22,4)=1
NITPIC(12,1,1)=2
NITPIC(12,1,2)=2
NITPIC(12,1,6)=2
NITPIC(12,4,3)=3
NITPIC(12,7,1)=3
NITPIC(12,7,2)=3
NITPIC(12,7,6)=3
NITPIC(12,10,3)=3
NITPIC(12,13,1)=3
NITPIC(12,13,2)=3
NITPIC(12,13,6)=3
NITPIC(12,16,3)=3
NITPIC(12,19,1)=3
NITPIC(12,19,2)=3
NITPIC(12,23,2)=1
NITPIC(12,23,3)=1
NITPIC(12,23,4)=1
NITPIC(13,1,1)=2
NITPIC(13,1,2)=2
NITPIC(13,4,4)=3
NITPIC(13,5,4)=3
NITPIC(13,5,5)=3
NITPIC(13,7,1)=3
NITPIC(13,10,4)=3
NITPIC(13,11,4)=3
NITPIC(13,11,5)=3
NITPIC(13,13,1)=3
NITPIC(13,16,4)=3
NITPIC(13,17,4)=3
NITPIC(13,17,5)=3
NITPIC(13,19,1)=3
NITPIC(13,22,2)=1
NITPIC(13,22,3)=1
NITPIC(14,1,1)=2
NITPIC(14,1,2)=2
NITPIC(14,5,4)=3
NITPIC(14,5,5)=3
NITPIC(14,11,4)=3
NITPIC(14,11,5)=3
NITPIC(14,17,4)=3
NITPIC(14,17,5)=3
NITPIC(14,21,2)=1
NITPIC(14,21,3)=1
NITPIC(15,1,1)=2
NITPIC(15,1,2)=2
NITPIC(15,20,2)=2
NITPIC(15,20,3)=1
NITPIC(16,1,1)=2
NITPIC(16,1,2)=2
NITPIC(16,7,2)=3
NITPIC(16,8,1)=3
NITPIC(16,8,2)=3
NITPIC(16,13,2)=3

NITPIC(16,14,1)=3
NITPIC(16,14,2)=3
NITPIC(16,19,2)=2
NITPIC(16,19,3)=2
NITPIC(17,1,1)=2
NITPIC(17,1,2)=2
NITPIC(17,5,2)=3
NITPIC(17,6,1)=3
NITPIC(17,6,2)=3
NITPIC(17,6,3)=3
NITPIC(17,8,1)=3
NITPIC(17,11,2)=3
NITPIC(17,12,1)=3
NITPIC(17,12,2)=3
NITPIC(17,12,3)=3
NITPIC(17,14,1)=3
NITPIC(17,18,2)=2
NITPIC(17,18,3)=2
NITPIC(18,1,1)=2
NITPIC(18,1,2)=2
NITPIC(18,4,3)=3
NITPIC(18,7,1)=3
NITPIC(18,7,6)=3
NITPIC(18,10,3)=3
NITPIC(18,13,1)=3
NITPIC(18,13,2)=3
NITPIC(18,13,6)=3
NITPIC(18,17,2)=2
NITPIC(18,17,3)=2
NITPIC(19,1,1)=2
NITPIC(19,1,2)=2
NITPIC(19,4,4)=3
NITPIC(19,5,3)=3
NITPIC(19,5,4)=3
NITPIC(19,5,5)=3
NITPIC(19,7,1)=3
NITPIC(19,7,6)=3
NITPIC(19,10,4)=3
NITPIC(19,11,3)=3
NITPIC(19,11,4)=3
NITPIC(19,11,5)=3
NITPIC(19,13,1)=3
NITPIC(19,16,2)=2
NITPIC(19,16,3)=2
NITPIC(20,1,1)=1
NITPIC(20,1,2)=1
NITPIC(20,5,4)=3
NITPIC(20,11,4)=3
NITPIC(20,15,2)=2
NITPIC(20,15,3)=2
NITPIC(21,1,1)=1
NITPIC(21,1,2)=1
NITPIC(21,14,2)=2
NITPIC(21,14,3)=2
NITPIC(22,1,1)=1

```

NITPIC(22,1,2)=1
NITPIC(22,13,2)=2
NITPIC(22,13,3)=2
NITPIC(23,1,1)=1
NITPIC(23,1,2)=1
NITPIC(23,2,1)=1
NITPIC(23,2,2)=1
NITPIC(23,3,1)=1
NITPIC(23,3,2)=1
NITPIC(23,4,1)=1
NITPIC(23,4,2)=1
NITPIC(23,5,1)=2
NITPIC(23,5,2)=2
NITPIC(23,6,1)=2
NITPIC(23,6,2)=2
NITPIC(23,7,1)=2
NITPIC(23,7,2)=2
NITPIC(23,8,1)=2
NITPIC(23,8,2)=2
NITPIC(23,9,1)=2
NITPIC(23,9,2)=2
NITPIC(23,10,1)=2
NITPIC(23,10,2)=2
NITPIC(23,11,1)=2
NITPIC(23,11,2)=2
NITPIC(23,12,1)=2
NITPIC(23,12,2)=2
NITPIC(23,12,3)=2
RETURN
END

```

C
C
C
C
C
C

```

SUBROUTINE PPRINT(TIN,PIN,Z)

```

```

THIS SUBROUTINE CONTAINS WRITE STATEMENTS AND FORMAT STATEMENTS
USED TO PRINT INDIVIDUAL CHANNEL PARAMETERS

```

```

IMPLICIT REAL*8(A-H,O-Z)
REAL*8 MU,MUL,MUV,K,KL,KV,MDOT
DIMENSION NITPIC(23,23,6),N(23,23,6),K1(23,23,6),K2(23,23,6)
DIMENSION K3(23,23,6),L1(23,23,6),L2(23,23,6),L3(23,23,6)
DIMENSION M3(23,23,6),M1(23,23,6),M2(23,23,6),H(23,23,6)
DIMENSION TE(23,23,6),PE(23,23,6),TC(23,23,6),TVWB(23,23,6)
DIMENSION PWROUT(23,23,6),T(23,23,6),P(23,23,6)
COMMON/HICK/TE,PE,TC,TVWB,PWROUT
COMMON/FRUIT/NITPIC,N,K1,K2,K3,L1,L2,L3,M1,M2,M3,H
COMMON/JING/T,P
Z=Z*12.
NTYPE=0
DO 9000 KK=1,23
IF(KK.LE.12)LMAX=KK+11
IF(KK.GT.12)LMAX=(24-KK)+11
DO 9000 L=1,LMAX
DO 9000 M=1,6

```


APPENDIX C
Program Input and Output

The input data for the program is contained in four cards. The input data includes the coolant inlet conditions, the fuel assembly height, the axial height increment, the coolant flowrates, the fuel lattice parameters, and the power density. The required input is:

- TIN - The inlet coolant temperature in degrees Fahrenheit.
- PIN - The inlet coolant pressure in PSIA.
- ZMAX - The fuel assembly height in inches.
- DZ - The height increment in inches.
- NNN - An integer that defines the FTWR. Values for NNN and the corresponding FTWR are listed in Table C-1.
- ENR - The fuel enrichment in percent U-235.
- PDENS - The power density in W/cm^3 .
- PITCH - The fuel rod lattice pitch in inches.
- LEAD - The axial lead of the wire wrap in inches.
- CLADOD - The outside diameter of the fuel rods.
- PWRIN1 - The inlet pressure of the short void plates in PSIA.
- PWRIN2 - The inlet pressure of the long void plates in PSIA.
- PWRIN3 - The inlet pressure of the void rods in PSIA.
- MDOT - The coolant mass flowrate in lbm/s.
- XMDOT1 - The coolant mass flowrate through each short void plate in lbm/s.
- XMDOT2 - The coolant mass flowrate through each long void plate in lbm/s.
- XMDOT3 - The coolant mass flowrate through the void rods in lbm/s.

The order these input parameters are read into the program is shown in Table C-2.

The program prints a summary of the input data, the coolant properties at the fuel assembly exit, the coolant enthalpy increase through the fuel assembly, and the fuel assembly pressure drop. The inlet and outlet pressures and temperatures of each coolant channel are also printed.

Table C-1 Fuel to Water Ratio Input Parameters

<u>Parameter Value</u>	<u>Fuel to Water Ratio</u>
1	1.25
2	1.19
3	1.11
4	1.05
5	1.00
6	0.95
7	0.89
8	0.85
9	0.80
10	0.75

Table C-2 Program Input Parameters

Card Number	Input Parameters
1	TIN, PIN, ZMAX, DZ, NNN, ENR, PDENS
2	PITCH, CLADOD, XLEAD
3	PWRIN1, PWRIN2, PWREN3
4	MDOT, XMDOT1, XMDOT2, XMDOT3

APPENDIX D

Program Output for Test Case 1

***** FUEL ASSEMBLY DATA *****

THE HEIGHT IS 120.0 INCHES. THE ENRICHMENT IS 2.70% URANIUM-235. THE FLOWRATE THROUGH THE FUEL RODS IS 670.00 LBM/S
THE FLOWRATE THROUGH THE VOID RODS IS 0.01 LBM/S. THE FLOWRATE THROUGH THE SHORT VOID PLATES IS 0.01 LBM/S
THE FLOWRATE THROUGH THE LONG VOID PLATES IS 0.01 LBM/S
THE FUEL TO WATER RATIO IS 0.95
THE MINIMUM DNBR IS 10.12
THE POWER DENSITY IS 597.000 W/CM**3

***** INLET CONDITIONS *****

THE INLET TEMPERATURE IS 550.00 DEGREES F
THE PRESSURE AT THE INLET TO THE FUEL RODS IS 2400.00 PSIA
THE PRESSURE AT THE INLET TO THE VOID RODS IS 2049.70 PSIA. THE PRESSURE AT THE INLET TO THE SHORT VOID PLATES IS 2049.70 PSIA
THE PRESSURE AT THE INLET TO THE LONG VOID PLATES IS 2049.70 PSIA
THE INLET ENTHALPY IS 546.71 BTU/LBM

***** OUTLET CONDITIONS *****

THE PRESSURE AT THE FUEL ROD EXIT IS 2049.66 PSIA
THE PRESSURE AT THE EXIT OF THE VOID RODS IS 2049.70 PSIA THE PRESSURE AT THE EXIT OF THE SHORT VOID PLATES IS 2049.70 PSIA
THE PRESSURE AT THE EXIT OF THE LONG VOID PLATES IS 2049.70 PSIA
THE EXIT ENTHALPY IS 667.21 BTU/LBM
THE ENTHALPY INCREASE THROUGH THE ASSEMBLY IS 120.50 BTU/LBM
THE PRESSURE DROP THROUGH THE ASSEMBLY IS 350.34 PSI

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(1, 1, 1)	550.000	633.653	2400.000	2049.659	643.525	557.186	2049.700
120.00	(1, 1, 2)	550.000	633.410	2400.000	2049.659	642.092	N/A	N/A
120.00	(1, 1, 5)	550.000	634.744	2400.000	2064.307	644.995	557.186	2049.700
120.00	(1, 1, 6)	550.000	636.127	2400.000	2064.307	645.418	557.186	2049.700
120.00	(1, 2, 1)	550.000	633.535	2400.000	2049.659	641.761	N/A	N/A
120.00	(1, 2, 2)	550.000	632.259	2400.000	2049.659	641.678	N/A	N/A
120.00	(1, 2, 5)	550.000	632.831	2400.000	2064.307	645.489	557.186	2049.700
120.00	(1, 2, 6)	550.000	633.875	2400.000	2049.659	643.285	557.186	2049.700
120.00	(1, 3, 1)	550.000	633.289	2400.000	2049.659	641.128	N/A	N/A
120.00	(1, 3, 2)	550.000	632.020	2400.000	2049.659	640.870	N/A	N/A
120.00	(1, 3, 5)	550.000	632.628	2400.000	2064.307	645.489	557.186	2049.700
120.00	(1, 3, 6)	550.000	631.073	2400.000	2049.659	643.626	557.186	2049.700
120.00	(1, 4, 1)	550.000	632.615	2400.000	2049.659	640.202	N/A	N/A
120.00	(1, 4, 2)	550.000	631.707	2400.000	2049.659	639.929	N/A	N/A
120.00	(1, 4, 5)	550.000	632.888	2400.000	2064.307	645.082	557.186	2049.700
120.00	(1, 4, 6)	550.000	630.453	2400.000	2049.659	642.860	557.186	2049.700
120.00	(1, 5, 1)	550.000	632.883	2400.000	2049.659	639.706	N/A	N/A
120.00	(1, 5, 2)	550.000	631.131	2400.000	2049.659	639.956	N/A	N/A
120.00	(1, 5, 5)	550.000	631.866	2400.000	2064.307	644.961	N/A	N/A
120.00	(1, 5, 6)	550.000	630.628	2400.000	2049.659	642.629	N/A	N/A
120.00	(1, 6, 1)	550.000	632.206	2400.000	2049.659	639.216	N/A	N/A
120.00	(1, 6, 2)	550.000	631.414	2400.000	2049.659	639.542	N/A	N/A
120.00	(1, 6, 5)	550.000	631.781	2400.000	2064.307	644.554	N/A	N/A
120.00	(1, 6, 6)	550.000	629.978	2400.000	2049.659	642.068	N/A	N/A
120.00	(1, 7, 1)	550.000	632.100	2400.000	2049.659	639.558	N/A	N/A
120.00	(1, 7, 2)	550.000	630.902	2400.000	2049.659	639.783	N/A	N/A
120.00	(1, 7, 5)	550.000	632.948	2400.000	2064.307	643.812	N/A	N/A
120.00	(1, 7, 6)	550.000	630.401	2400.000	2049.659	641.934	N/A	N/A
120.00	(1, 8, 1)	550.000	632.188	2400.000	2049.659	639.133	N/A	N/A
120.00	(1, 8, 2)	550.000	631.057	2400.000	2049.659	639.965	N/A	N/A
120.00	(1, 8, 5)	550.000	631.139	2400.000	2064.307	645.008	N/A	N/A
120.00	(1, 8, 6)	550.000	630.389	2400.000	2049.659	641.695	N/A	N/A
120.00	(1, 9, 1)	550.000	632.804	2400.000	2049.659	639.699	N/A	N/A
120.00	(1, 9, 2)	550.000	631.840	2400.000	2049.659	640.422	N/A	N/A
120.00	(1, 9, 5)	550.000	631.585	2400.000	2064.307	645.475	N/A	N/A
120.00	(1, 9, 6)	550.000	629.998	2400.000	2049.659	642.497	N/A	N/A
120.00	(1, 10, 1)	550.000	632.728	2400.000	2049.659	640.256	N/A	N/A
120.00	(1, 10, 2)	550.000	632.862	2400.000	2049.659	640.819	N/A	N/A
120.00	(1, 10, 5)	550.000	634.666	2400.000	2064.307	644.963	N/A	N/A
120.00	(1, 10, 6)	550.000	631.018	2400.000	2049.659	642.610	N/A	N/A
120.00	(1, 11, 1)	550.000	633.349	2400.000	2049.659	641.506	N/A	N/A
120.00	(1, 11, 2)	550.000	633.415	2400.000	2049.659	641.578	N/A	N/A
120.00	(1, 11, 5)	550.000	632.835	2400.000	2064.307	645.489	N/A	N/A
120.00	(1, 11, 6)	550.000	631.606	2400.000	2049.659	643.658	N/A	N/A
120.00	(1, 12, 1)	550.000	633.661	2400.000	2049.659	641.960	N/A	N/A
120.00	(1, 12, 2)	550.000	633.231	2400.000	2049.659	642.816	N/A	N/A
120.00	(1, 12, 3)	550.000	632.528	2400.000	2049.659	644.813	N/A	N/A
120.00	(1, 12, 4)	550.000	637.163	2400.000	2064.307	644.070	N/A	N/A
120.00	(1, 12, 5)	550.000	637.351	2400.000	2064.307	645.112	N/A	N/A
120.00	(1, 12, 6)	550.000	633.799	2400.000	2049.659	643.381	N/A	N/A
120.00	(2, 1, 1)	550.000	633.327	2400.000	2049.659	643.427	557.186	2049.700
120.00	(2, 1, 2)	550.000	633.166	2400.000	2049.659	641.685	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(2, 1,6)	550.000	635.098	2400.000	2064.307	645.489	557.186	2049.700
120.00	(2, 2,1)	550.000	633.664	2400.000	2049.659	641.727	N/A	N/A
120.00	(2, 2,2)	550.000	632.602	2400.000	2049.659	641.463	N/A	N/A
120.00	(2, 3,1)	550.000	632.773	2400.000	2049.659	640.994	N/A	N/A
120.00	(2, 3,2)	550.000	631.928	2400.000	2049.659	640.930	N/A	N/A
120.00	(2, 4,1)	550.000	631.859	2400.000	2049.659	640.794	N/A	N/A
120.00	(2, 4,2)	550.000	631.410	2400.000	2049.659	640.492	N/A	N/A
120.00	(2, 5,1)	550.000	631.601	2400.000	2049.659	640.183	N/A	N/A
120.00	(2, 5,2)	550.000	631.244	2400.000	2049.659	640.163	N/A	N/A
120.00	(2, 6,1)	550.000	631.070	2400.000	2049.659	639.954	N/A	N/A
120.00	(2, 6,2)	550.000	631.162	2400.000	2049.659	640.034	N/A	N/A
120.00	(2, 7,1)	550.000	631.313	2400.000	2049.659	639.913	N/A	N/A
120.00	(2, 7,2)	550.000	631.311	2400.000	2049.659	639.966	N/A	N/A
120.00	(2, 8,1)	550.000	631.073	2400.000	2049.659	640.071	N/A	N/A
120.00	(2, 8,2)	550.000	631.002	2400.000	2049.659	640.327	N/A	N/A
120.00	(2, 9,1)	550.000	631.882	2400.000	2049.659	640.091	N/A	N/A
120.00	(2, 9,2)	550.000	631.371	2400.000	2049.659	640.962	N/A	N/A
120.00	(2, 10,1)	550.000	631.930	2400.000	2049.659	640.739	N/A	N/A
120.00	(2, 10,2)	550.000	631.740	2400.000	2049.659	641.189	N/A	N/A
120.00	(2, 11,1)	550.000	632.553	2400.000	2049.659	641.236	N/A	N/A
120.00	(2, 11,2)	550.000	632.997	2400.000	2049.659	641.644	N/A	N/A
120.00	(2, 12,1)	550.000	633.421	2400.000	2049.659	641.880	N/A	N/A
120.00	(2, 12,2)	550.000	632.875	2400.000	2049.659	642.360	N/A	N/A
120.00	(2, 13,1)	550.000	634.162	2400.000	2049.659	642.175	N/A	N/A
120.00	(2, 13,2)	550.000	632.377	2400.000	2049.659	643.712	N/A	N/A
120.00	(2, 13,3)	550.000	635.025	2400.000	2049.659	643.797	N/A	N/A
120.00	(2, 13,4)	550.000	633.490	2400.000	2049.659	644.570	N/A	N/A
120.00	(3, 1,1)	550.000	633.223	2400.000	2049.659	643.224	557.186	2049.700
120.00	(3, 1,2)	550.000	633.011	2400.000	2049.659	641.551	N/A	N/A
120.00	(3, 1,6)	550.000	634.581	2400.000	2064.307	645.489	557.186	2049.700
120.00	(3, 2,1)	550.000	633.582	2400.000	2049.659	641.269	N/A	N/A
120.00	(3, 2,2)	550.000	632.871	2400.000	2049.659	641.182	N/A	N/A
120.00	(3, 3,1)	550.000	632.370	2400.000	2049.659	641.153	N/A	N/A
120.00	(3, 3,2)	550.000	631.780	2400.000	2049.659	640.603	N/A	N/A
120.00	(3, 4,1)	550.000	631.848	2400.000	2049.659	640.636	N/A	N/A
120.00	(3, 4,2)	550.000	631.491	2400.000	2049.659	640.481	N/A	N/A
120.00	(3, 5,1)	550.000	631.340	2400.000	2049.659	640.466	N/A	N/A
120.00	(3, 5,2)	550.000	630.626	2400.000	2049.659	640.333	N/A	N/A
120.00	(3, 6,1)	550.000	630.607	2400.000	2049.659	640.344	N/A	N/A
120.00	(3, 6,2)	550.000	631.461	2400.000	2049.659	640.260	N/A	N/A
120.00	(3, 7,1)	550.000	631.105	2400.000	2049.659	640.522	N/A	N/A
120.00	(3, 7,2)	550.000	631.193	2400.000	2049.659	640.357	N/A	N/A
120.00	(3, 8,1)	550.000	631.454	2400.000	2049.659	640.242	N/A	N/A
120.00	(3, 8,2)	550.000	631.456	2400.000	2049.659	640.556	N/A	N/A
120.00	(3, 9,1)	550.000	631.338	2400.000	2049.659	640.553	N/A	N/A
120.00	(3, 9,2)	550.000	631.284	2400.000	2049.659	640.688	N/A	N/A
120.00	(3, 10,1)	550.000	631.791	2400.000	2049.659	640.754	N/A	N/A
120.00	(3, 10,2)	550.000	631.578	2400.000	2049.659	641.146	N/A	N/A
120.00	(3, 11,1)	550.000	631.777	2400.000	2049.659	641.161	N/A	N/A
120.00	(3, 11,2)	550.000	631.645	2400.000	2049.659	641.479	N/A	N/A
120.00	(3, 12,1)	550.000	632.068	2400.000	2049.659	642.020	N/A	N/A
120.00	(3, 12,2)	550.000	633.104	2400.000	2049.659	641.934	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L, M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(3, 13, 1)	550.000	632.946	2400.000	2049.659	642.387	N/A	N/A
120.00	(3, 13, 2)	550.000	633.735	2400.000	2049.659	642.764	N/A	N/A
120.00	(3, 14, 1)	550.000	633.816	2400.000	2049.659	643.249	N/A	N/A
120.00	(3, 14, 2)	550.000	632.710	2400.000	2049.659	644.187	N/A	N/A
120.00	(3, 14, 3)	550.000	634.821	2400.000	2049.659	644.045	N/A	N/A
120.00	(3, 14, 4)	550.000	637.452	2400.000	2049.659	644.570	N/A	N/A
120.00	(4, 1, 1)	550.000	632.834	2400.000	2049.659	643.240	N/A	N/A
120.00	(4, 1, 2)	550.000	632.977	2400.000	2049.659	641.635	N/A	N/A
120.00	(4, 1, 6)	550.000	634.027	2400.000	2064.307	645.489	557.186	2049.700
120.00	(4, 2, 1)	550.000	633.659	2400.000	2049.659	641.529	N/A	N/A
120.00	(4, 2, 2)	550.000	632.700	2400.000	2049.659	641.699	N/A	N/A
120.00	(4, 3, 1)	550.000	632.813	2400.000	2049.659	641.000	N/A	N/A
120.00	(4, 3, 2)	550.000	632.031	2400.000	2049.659	640.620	N/A	N/A
120.00	(4, 4, 1)	550.000	631.975	2400.000	2049.659	640.372	N/A	N/A
120.00	(4, 4, 2)	550.000	631.024	2400.000	2049.659	640.440	N/A	N/A
120.00	(4, 5, 1)	550.000	630.751	2400.000	2049.659	640.314	N/A	N/A
120.00	(4, 5, 2)	550.000	631.062	2400.000	2049.659	641.093	558.642	2049.699
120.00	(4, 6, 1)	550.000	631.425	2400.000	2049.659	640.967	558.642	2049.699
120.00	(4, 6, 2)	550.000	630.608	2400.000	2049.659	641.662	558.642	2049.699
120.00	(4, 7, 1)	550.000	630.980	2400.000	2049.659	640.668	N/A	N/A
120.00	(4, 7, 2)	550.000	631.236	2400.000	2049.659	640.503	N/A	N/A
120.00	(4, 8, 1)	550.000	631.304	2400.000	2049.659	640.465	N/A	N/A
120.00	(4, 8, 2)	550.000	631.430	2400.000	2049.659	640.651	N/A	N/A
120.00	(4, 9, 1)	550.000	631.447	2400.000	2049.659	640.569	N/A	N/A
120.00	(4, 9, 2)	550.000	631.415	2400.000	2049.659	640.434	N/A	N/A
120.00	(4, 10, 1)	550.000	631.600	2400.000	2049.659	640.485	N/A	N/A
120.00	(4, 10, 2)	550.000	631.309	2400.000	2049.659	640.836	N/A	N/A
120.00	(4, 11, 1)	550.000	630.825	2400.000	2049.659	640.987	N/A	N/A
120.00	(4, 11, 2)	550.000	631.337	2400.000	2049.659	641.859	558.642	2049.699
120.00	(4, 12, 1)	550.000	632.563	2400.000	2049.659	642.009	558.642	2049.699
120.00	(4, 12, 2)	550.000	631.721	2400.000	2049.659	643.160	558.642	2049.699
120.00	(4, 13, 1)	550.000	632.029	2400.000	2049.659	642.324	N/A	N/A
120.00	(4, 13, 2)	550.000	633.320	2400.000	2049.659	642.078	N/A	N/A
120.00	(4, 14, 1)	550.000	633.305	2400.000	2049.659	643.006	N/A	N/A
120.00	(4, 14, 2)	550.000	634.112	2400.000	2049.659	643.105	N/A	N/A
120.00	(4, 15, 1)	550.000	633.724	2400.000	2049.659	644.005	N/A	N/A
120.00	(4, 15, 2)	550.000	632.324	2400.000	2049.659	644.694	N/A	N/A
120.00	(4, 15, 3)	550.000	635.057	2400.000	2049.659	644.204	N/A	N/A
120.00	(4, 15, 4)	550.000	636.690	2400.000	2049.659	644.570	N/A	N/A
120.00	(5, 1, 1)	550.000	633.442	2400.000	2049.659	642.580	N/A	N/A
120.00	(5, 1, 2)	550.000	633.083	2400.000	2049.659	641.725	N/A	N/A
120.00	(5, 1, 6)	550.000	635.550	2400.000	2064.307	645.060	N/A	N/A
120.00	(5, 2, 1)	550.000	633.452	2400.000	2049.659	641.548	N/A	N/A
120.00	(5, 2, 2)	550.000	633.232	2400.000	2049.659	641.341	N/A	N/A
120.00	(5, 3, 1)	550.000	632.818	2400.000	2049.659	641.462	N/A	N/A
120.00	(5, 3, 2)	550.000	632.282	2400.000	2049.659	640.959	N/A	N/A
120.00	(5, 4, 1)	550.000	631.927	2400.000	2049.659	640.746	N/A	N/A
120.00	(5, 4, 2)	550.000	630.838	2400.000	2049.659	641.843	558.642	2049.699
120.00	(5, 5, 1)	550.000	630.897	2400.000	2049.659	641.322	558.642	2049.699
120.00	(5, 5, 2)	550.000	633.534	2400.000	2049.659	643.183	558.642	2049.699
120.00	(5, 5, 3)	550.000	633.693	2400.000	2049.659	644.291	558.642	2049.699
120.00	(5, 7, 1)	550.000	631.732	2400.000	2049.659	640.998	558.642	2049.699

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(5, 7,2)	550.000	631.823	2400.000	2049.659	640.255	N/A	N/A
120.00	(5, 8,1)	550.000	631.453	2400.000	2049.659	640.521	N/A	N/A
120.00	(5, 8,2)	550.000	631.781	2400.000	2049.659	640.413	N/A	N/A
120.00	(5, 9,1)	550.000	631.683	2400.000	2049.659	640.690	N/A	N/A
120.00	(5, 9,2)	550.000	631.589	2400.000	2049.659	640.722	N/A	N/A
120.00	(5,10,1)	550.000	631.435	2400.000	2049.659	640.532	N/A	N/A
120.00	(5,10,2)	550.000	631.161	2400.000	2049.659	641.907	558.642	2049.699
120.00	(5,11,1)	550.000	630.782	2400.000	2049.659	641.842	558.642	2049.699
120.00	(5,11,2)	550.000	633.902	2400.000	2049.659	643.378	558.642	2049.699
120.00	(5,11,3)	550.000	633.591	2400.000	2049.659	644.570	558.642	2049.699
120.00	(5,13,1)	550.000	633.442	2400.000	2049.659	642.164	558.642	2049.699
120.00	(5,13,2)	550.000	633.276	2400.000	2049.659	641.827	N/A	N/A
120.00	(5,14,1)	550.000	633.324	2400.000	2049.659	642.166	N/A	N/A
120.00	(5,14,2)	550.000	633.744	2400.000	2049.659	642.217	N/A	N/A
120.00	(5,15,1)	550.000	634.173	2400.000	2049.659	642.784	N/A	N/A
120.00	(5,15,2)	550.000	634.813	2400.000	2049.659	643.324	N/A	N/A
120.00	(5,16,1)	550.000	634.342	2400.000	2049.659	644.062	N/A	N/A
120.00	(5,16,2)	550.000	632.656	2400.000	2049.659	644.704	N/A	N/A
120.00	(5,16,3)	550.000	634.950	2400.000	2049.659	644.399	N/A	N/A
120.00	(5,16,4)	550.000	635.893	2400.000	2049.659	644.570	N/A	N/A
120.00	(6, 1,1)	550.000	633.940	2400.000	2049.659	642.101	N/A	N/A
120.00	(6, 1,2)	550.000	633.138	2400.000	2049.659	641.607	N/A	N/A
120.00	(6, 1,6)	550.000	635.629	2400.000	2064.307	644.937	N/A	N/A
120.00	(6, 2,1)	550.000	634.139	2400.000	2049.659	641.399	N/A	N/A
120.00	(6, 2,2)	550.000	633.120	2400.000	2049.659	641.599	N/A	N/A
120.00	(6, 3,1)	550.000	633.578	2400.000	2049.659	641.364	N/A	N/A
120.00	(6, 3,2)	550.000	632.610	2400.000	2049.659	641.398	N/A	N/A
120.00	(6, 4,1)	550.000	632.403	2400.000	2049.659	640.977	N/A	N/A
120.00	(6, 4,2)	550.000	632.023	2400.000	2049.659	640.900	N/A	N/A
120.00	(6, 4,3)	550.000	630.845	2400.000	2049.659	641.884	558.642	2049.699
120.00	(6, 7,1)	550.000	633.907	2400.000	2064.307	642.554	558.642	2049.699
120.00	(6, 7,2)	550.000	631.356	2400.000	2064.307	641.715	558.642	2049.699
120.00	(6, 7,6)	550.000	634.637	2400.000	2064.307	643.390	558.642	2049.699
120.00	(6, 8,1)	550.000	632.382	2400.000	2049.659	640.179	N/A	N/A
120.00	(6, 8,2)	550.000	631.700	2400.000	2049.659	640.673	N/A	N/A
120.00	(6, 9,1)	550.000	632.204	2400.000	2049.659	640.622	N/A	N/A
120.00	(6, 9,2)	550.000	632.107	2400.000	2049.659	641.086	N/A	N/A
120.00	(6,10,1)	550.000	631.935	2400.000	2049.659	640.855	N/A	N/A
120.00	(6,10,2)	550.000	632.142	2400.000	2049.659	641.003	N/A	N/A
120.00	(6,10,3)	550.000	631.074	2400.000	2049.659	642.213	558.642	2049.699
120.00	(6,13,1)	550.000	634.631	2400.000	2064.307	644.255	558.642	2049.699
120.00	(6,13,2)	550.000	632.426	2400.000	2064.307	642.814	558.642	2049.699
120.00	(6,13,6)	550.000	635.529	2400.000	2064.307	645.021	558.642	2049.699
120.00	(6,14,1)	550.000	633.487	2400.000	2049.659	641.640	N/A	N/A
120.00	(6,14,2)	550.000	633.162	2400.000	2049.659	642.101	N/A	N/A
120.00	(6,15,1)	550.000	633.582	2400.000	2049.659	642.488	N/A	N/A
120.00	(6,15,2)	550.000	634.196	2400.000	2049.659	642.923	N/A	N/A
120.00	(6,16,1)	550.000	634.281	2400.000	2049.659	643.543	N/A	N/A
120.00	(6,16,2)	550.000	635.332	2400.000	2049.659	643.589	N/A	N/A
120.00	(6,17,1)	550.000	634.891	2400.000	2049.659	644.498	N/A	N/A
120.00	(6,17,2)	550.000	633.602	2400.000	2049.659	644.704	N/A	N/A
120.00	(6,17,3)	550.000	635.089	2400.000	2049.659	644.852	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L, M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(6, 17, 4)	550.000	637.261	2400.000	2049.659	644.570	N/A	N/A
120.00	(7, 1, 1)	550.000	633.065	2400.000	2049.659	642.608	N/A	N/A
120.00	(7, 1, 2)	550.000	633.145	2400.000	2049.659	641.399	N/A	N/A
120.00	(7, 1, 6)	550.000	635.481	2400.000	2064.307	644.870	N/A	N/A
120.00	(7, 2, 1)	550.000	634.310	2400.000	2049.659	641.132	N/A	N/A
120.00	(7, 2, 2)	550.000	633.174	2400.000	2049.659	641.455	N/A	N/A
120.00	(7, 3, 1)	550.000	633.561	2400.000	2049.659	641.382	N/A	N/A
120.00	(7, 3, 2)	550.000	632.869	2400.000	2049.659	641.397	N/A	N/A
120.00	(7, 4, 1)	550.000	632.427	2400.000	2049.659	641.323	N/A	N/A
120.00	(7, 4, 2)	550.000	632.336	2400.000	2049.659	640.969	N/A	N/A
120.00	(7, 5, 1)	550.000	631.946	2400.000	2049.659	641.243	N/A	N/A
120.00	(7, 5, 2)	550.000	631.682	2400.000	2049.659	641.167	N/A	N/A
120.00	(7, 5, 4)	550.000	631.770	2400.000	2049.659	641.669	558.642	2049.699
120.00	(7, 6, 1)	550.000	632.476	2400.000	2049.659	640.781	N/A	N/A
120.00	(7, 6, 2)	550.000	632.190	2400.000	2049.659	641.228	N/A	N/A
120.00	(7, 6, 3)	550.000	631.277	2400.000	2049.659	642.306	558.642	2049.699
120.00	(7, 6, 4)	550.000	633.594	2400.000	2049.659	643.781	558.642	2049.699
120.00	(7, 6, 5)	550.000	634.178	2400.000	2049.659	644.390	558.642	2049.699
120.00	(7, 8, 1)	550.000	631.800	2400.000	2049.659	641.571	558.642	2049.699
120.00	(7, 8, 2)	550.000	631.421	2400.000	2049.659	640.866	N/A	N/A
120.00	(7, 9, 1)	550.000	632.240	2400.000	2049.659	640.631	N/A	N/A
120.00	(7, 9, 2)	550.000	632.630	2400.000	2049.659	641.196	N/A	N/A
120.00	(7, 10, 1)	550.000	632.144	2400.000	2049.659	641.352	N/A	N/A
120.00	(7, 10, 2)	550.000	632.408	2400.000	2049.659	641.099	N/A	N/A
120.00	(7, 11, 1)	550.000	632.039	2400.000	2049.659	641.501	N/A	N/A
120.00	(7, 11, 2)	550.000	631.880	2400.000	2049.659	641.445	N/A	N/A
120.00	(7, 11, 4)	550.000	631.908	2400.000	2049.659	642.017	558.642	2049.699
120.00	(7, 12, 1)	550.000	632.729	2400.000	2049.659	641.048	N/A	N/A
120.00	(7, 12, 2)	550.000	632.597	2400.000	2049.659	641.589	N/A	N/A
120.00	(7, 12, 3)	550.000	631.395	2400.000	2049.659	642.844	558.642	2049.699
120.00	(7, 12, 4)	550.000	634.009	2400.000	2049.659	643.868	558.642	2049.699
120.00	(7, 12, 5)	550.000	634.308	2400.000	2049.659	644.522	558.642	2049.699
120.00	(7, 14, 1)	550.000	632.648	2400.000	2049.659	642.433	558.642	2049.699
120.00	(7, 14, 2)	550.000	632.299	2400.000	2049.659	641.929	N/A	N/A
120.00	(7, 15, 1)	550.000	633.467	2400.000	2049.659	641.908	N/A	N/A
120.00	(7, 15, 2)	550.000	633.476	2400.000	2049.659	642.685	N/A	N/A
120.00	(7, 16, 1)	550.000	633.973	2400.000	2049.659	643.032	N/A	N/A
120.00	(7, 16, 2)	550.000	634.499	2400.000	2049.659	643.298	N/A	N/A
120.00	(7, 17, 1)	550.000	634.996	2400.000	2049.659	643.909	N/A	N/A
120.00	(7, 17, 2)	550.000	635.165	2400.000	2049.659	644.127	N/A	N/A
120.00	(7, 18, 1)	550.000	635.108	2400.000	2049.659	644.675	N/A	N/A
120.00	(7, 18, 2)	550.000	633.511	2400.000	2049.659	644.704	N/A	N/A
120.00	(7, 18, 3)	550.000	635.968	2400.000	2049.659	644.852	N/A	N/A
120.00	(7, 18, 4)	550.000	636.288	2400.000	2049.659	644.570	N/A	N/A
120.00	(8, 1, 1)	550.000	633.002	2400.000	2049.659	643.133	N/A	N/A
120.00	(8, 1, 2)	550.000	633.200	2400.000	2049.659	641.443	N/A	N/A
120.00	(8, 1, 6)	550.000	634.728	2400.000	2064.307	645.324	N/A	N/A
120.00	(8, 2, 1)	550.000	633.515	2400.000	2049.659	641.605	N/A	N/A
120.00	(8, 2, 2)	550.000	632.891	2400.000	2049.659	641.395	N/A	N/A
120.00	(8, 3, 1)	550.000	633.492	2400.000	2049.659	641.184	N/A	N/A
120.00	(8, 3, 2)	550.000	632.517	2400.000	2049.659	641.373	N/A	N/A
120.00	(8, 4, 1)	550.000	632.380	2400.000	2049.659	641.332	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(8, 4,2)	550.000	632.242	2400.000	2049.659	640.946	N/A	N/A
120.00	(8, 5,1)	550.000	632.492	2400.000	2049.659	640.953	N/A	N/A
120.00	(8, 5,2)	550.000	632.103	2400.000	2049.659	641.149	N/A	N/A
120.00	(8, 6,1)	550.000	631.597	2400.000	2049.659	641.157	N/A	N/A
120.00	(8, 6,2)	550.000	632.504	2400.000	2049.659	640.917	N/A	N/A
120.00	(8, 7,1)	550.000	631.878	2400.000	2049.659	641.274	N/A	N/A
120.00	(8, 7,2)	550.000	632.388	2400.000	2049.659	640.813	N/A	N/A
120.00	(8, 8,1)	550.000	631.459	2400.000	2049.659	641.201	N/A	N/A
120.00	(8, 8,2)	550.000	631.845	2400.000	2049.659	641.108	N/A	N/A
120.00	(8, 8,6)	550.000	631.826	2400.000	2049.659	641.863	558.642	2049.699
120.00	(8, 9,1)	550.000	632.386	2400.000	2049.659	640.922	N/A	N/A
120.00	(8, 9,2)	550.000	632.172	2400.000	2049.659	641.571	N/A	N/A
120.00	(8,10,1)	550.000	632.106	2400.000	2049.659	641.622	N/A	N/A
120.00	(8,10,2)	550.000	632.264	2400.000	2049.659	641.222	N/A	N/A
120.00	(8,11,1)	550.000	632.663	2400.000	2049.659	641.139	N/A	N/A
120.00	(8,11,2)	550.000	632.368	2400.000	2049.659	641.482	N/A	N/A
120.00	(8,12,1)	550.000	631.819	2400.000	2049.659	641.462	N/A	N/A
120.00	(8,12,2)	550.000	632.713	2400.000	2049.659	641.197	N/A	N/A
120.00	(8,13,1)	550.000	632.331	2400.000	2049.659	641.587	N/A	N/A
120.00	(8,13,2)	550.000	632.490	2400.000	2049.659	641.266	N/A	N/A
120.00	(8,14,1)	550.000	631.989	2400.000	2049.659	641.602	N/A	N/A
120.00	(8,14,2)	550.000	632.506	2400.000	2049.659	641.777	N/A	N/A
120.00	(8,14,6)	550.000	632.241	2400.000	2049.659	642.399	558.642	2049.699
120.00	(8,15,1)	550.000	633.210	2400.000	2049.659	641.753	N/A	N/A
120.00	(8,15,2)	550.000	632.817	2400.000	2049.659	642.474	N/A	N/A
120.00	(8,16,1)	550.000	633.432	2400.000	2049.659	642.549	N/A	N/A
120.00	(8,16,2)	550.000	633.721	2400.000	2049.659	642.795	N/A	N/A
120.00	(8,17,1)	550.000	634.058	2400.000	2049.659	643.243	N/A	N/A
120.00	(8,17,2)	550.000	634.348	2400.000	2049.659	643.232	N/A	N/A
120.00	(8,18,1)	550.000	634.462	2400.000	2049.659	643.849	N/A	N/A
120.00	(8,18,2)	550.000	635.664	2400.000	2049.659	643.873	N/A	N/A
120.00	(8,19,1)	550.000	635.011	2400.000	2049.659	644.704	N/A	N/A
120.00	(8,19,2)	550.000	633.461	2400.000	2049.659	644.704	N/A	N/A
120.00	(8,19,3)	550.000	635.514	2400.000	2049.659	644.852	N/A	N/A
120.00	(8,19,4)	550.000	637.163	2400.000	2049.659	644.570	N/A	N/A
120.00	(9, 1,1)	550.000	632.751	2400.000	2049.659	643.435	N/A	N/A
120.00	(9, 1,2)	550.000	632.891	2400.000	2049.659	641.403	N/A	N/A
120.00	(9, 1,6)	550.000	633.475	2400.000	2064.307	645.489	N/A	N/A
120.00	(9, 2,1)	550.000	633.722	2400.000	2049.659	641.293	N/A	N/A
120.00	(9, 2,2)	550.000	632.514	2400.000	2049.659	641.552	N/A	N/A
120.00	(9, 3,1)	550.000	632.984	2400.000	2049.659	641.232	N/A	N/A
120.00	(9, 3,2)	550.000	631.882	2400.000	2049.659	641.324	N/A	N/A
120.00	(9, 4,1)	550.000	632.646	2400.000	2049.659	640.987	N/A	N/A
120.00	(9, 4,2)	550.000	631.895	2400.000	2049.659	641.236	N/A	N/A
120.00	(9, 5,1)	550.000	631.978	2400.000	2049.659	641.118	N/A	N/A
120.00	(9, 5,2)	550.000	631.203	2400.000	2049.659	641.027	N/A	N/A
120.00	(9, 6,1)	550.000	631.732	2400.000	2049.659	640.998	N/A	N/A
120.00	(9, 6,2)	550.000	631.895	2400.000	2049.659	641.257	N/A	N/A
120.00	(9, 7,1)	550.000	631.851	2400.000	2049.659	641.496	N/A	N/A
120.00	(9, 7,2)	550.000	631.940	2400.000	2049.659	641.151	N/A	N/A
120.00	(9, 8,1)	550.000	632.197	2400.000	2049.659	641.149	N/A	N/A
120.00	(9, 8,2)	550.000	631.994	2400.000	2049.659	641.366	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L, M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(9, 9, 1)	550.000	632.153	2400.000	2049.659	641.393	N/A	N/A
120.00	(9, 9, 2)	550.000	631.581	2400.000	2049.659	641.569	N/A	N/A
120.00	(9, 10, 1)	550.000	632.346	2400.000	2049.659	641.212	N/A	N/A
120.00	(9, 10, 2)	550.000	632.085	2400.000	2049.659	641.491	N/A	N/A
120.00	(9, 11, 1)	550.000	632.086	2400.000	2049.659	641.495	N/A	N/A
120.00	(9, 11, 2)	550.000	631.454	2400.000	2049.659	641.421	N/A	N/A
120.00	(9, 12, 1)	550.000	631.931	2400.000	2049.659	641.358	N/A	N/A
120.00	(9, 12, 2)	550.000	631.988	2400.000	2049.659	641.478	N/A	N/A
120.00	(9, 13, 1)	550.000	632.055	2400.000	2049.659	641.684	N/A	N/A
120.00	(9, 13, 2)	550.000	631.972	2400.000	2049.659	641.373	N/A	N/A
120.00	(9, 14, 1)	550.000	632.292	2400.000	2049.659	641.336	N/A	N/A
120.00	(9, 14, 2)	550.000	632.381	2400.000	2049.659	641.618	N/A	N/A
120.00	(9, 15, 1)	550.000	632.498	2400.000	2049.659	642.044	N/A	N/A
120.00	(9, 15, 2)	550.000	632.065	2400.000	2049.659	642.058	N/A	N/A
120.00	(9, 16, 1)	550.000	632.881	2400.000	2049.659	642.017	N/A	N/A
120.00	(9, 16, 2)	550.000	632.895	2400.000	2049.659	642.430	N/A	N/A
120.00	(9, 17, 1)	550.000	633.422	2400.000	2049.659	642.713	N/A	N/A
120.00	(9, 17, 2)	550.000	632.793	2400.000	2049.659	642.946	N/A	N/A
120.00	(9, 18, 1)	550.000	633.778	2400.000	2049.659	643.108	N/A	N/A
120.00	(9, 18, 2)	550.000	634.350	2400.000	2049.659	643.525	N/A	N/A
120.00	(9, 19, 1)	550.000	634.616	2400.000	2049.659	644.221	N/A	N/A
120.00	(9, 19, 2)	550.000	635.228	2400.000	2049.659	643.978	N/A	N/A
120.00	(9, 20, 1)	550.000	635.400	2400.000	2049.659	644.490	N/A	N/A
120.00	(9, 20, 2)	550.000	633.244	2400.000	2049.659	644.704	N/A	N/A
120.00	(9, 20, 3)	550.000	635.473	2400.000	2049.659	644.852	557.186	2049.700
120.00	(9, 20, 4)	550.000	637.034	2400.000	2049.659	644.570	557.186	2049.700
120.00	(10, 1, 1)	550.000	632.938	2400.000	2049.659	643.343	N/A	N/A
120.00	(10, 1, 2)	550.000	632.969	2400.000	2049.659	641.809	N/A	N/A
120.00	(10, 1, 6)	550.000	634.109	2400.000	2064.307	645.489	N/A	N/A
120.00	(10, 2, 1)	550.000	633.084	2400.000	2049.659	641.498	N/A	N/A
120.00	(10, 2, 2)	550.000	632.697	2400.000	2049.659	641.321	N/A	N/A
120.00	(10, 3, 1)	550.000	632.683	2400.000	2049.659	640.932	N/A	N/A
120.00	(10, 3, 2)	550.000	632.389	2400.000	2049.659	640.685	N/A	N/A
120.00	(10, 4, 1)	550.000	632.439	2400.000	2049.659	640.838	N/A	N/A
120.00	(10, 4, 2)	550.000	631.288	2400.000	2049.659	641.097	N/A	N/A
120.00	(10, 5, 1)	550.000	631.351	2400.000	2049.659	640.884	N/A	N/A
120.00	(10, 5, 2)	550.000	631.577	2400.000	2049.659	641.827	558.642	2049.699
120.00	(10, 6, 1)	550.000	631.723	2400.000	2049.659	641.651	558.642	2049.699
120.00	(10, 6, 2)	550.000	631.561	2400.000	2049.659	642.078	558.642	2049.699
120.00	(10, 7, 1)	550.000	632.092	2400.000	2049.659	641.011	N/A	N/A
120.00	(10, 7, 2)	550.000	631.959	2400.000	2049.659	641.117	N/A	N/A
120.00	(10, 8, 1)	550.000	631.925	2400.000	2049.659	641.074	N/A	N/A
120.00	(10, 8, 2)	550.000	632.067	2400.000	2049.659	641.071	N/A	N/A
120.00	(10, 9, 1)	550.000	632.324	2400.000	2049.659	640.967	N/A	N/A
120.00	(10, 9, 2)	550.000	632.140	2400.000	2049.659	640.997	N/A	N/A
120.00	(10, 10, 1)	550.000	632.401	2400.000	2049.659	641.048	N/A	N/A
120.00	(10, 10, 2)	550.000	631.620	2400.000	2049.659	641.547	N/A	N/A
120.00	(10, 11, 1)	550.000	631.498	2400.000	2049.659	641.320	N/A	N/A
120.00	(10, 11, 2)	550.000	631.671	2400.000	2049.659	642.144	558.642	2049.699
120.00	(10, 12, 1)	550.000	631.789	2400.000	2049.659	641.976	558.642	2049.699
120.00	(10, 12, 2)	550.000	631.435	2400.000	2049.659	642.177	558.642	2049.699
120.00	(10, 13, 1)	550.000	632.018	2400.000	2049.659	641.109	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(10, 13, 2)	550.000	631.939	2400.000	2049.659	641.163	N/A	N/A
120.00	(10, 14, 1)	550.000	631.988	2400.000	2049.659	641.160	N/A	N/A
120.00	(10, 14, 2)	550.000	631.966	2400.000	2049.659	641.224	N/A	N/A
120.00	(10, 15, 1)	550.000	632.513	2400.000	2049.659	641.148	N/A	N/A
120.00	(10, 15, 2)	550.000	632.214	2400.000	2049.659	641.230	N/A	N/A
120.00	(10, 16, 1)	550.000	632.839	2400.000	2049.659	641.314	N/A	N/A
120.00	(10, 16, 2)	550.000	632.214	2400.000	2049.659	642.004	N/A	N/A
120.00	(10, 17, 1)	550.000	632.003	2400.000	2049.659	642.153	N/A	N/A
120.00	(10, 17, 2)	550.000	632.501	2400.000	2049.659	642.978	558.642	2049.699
120.00	(10, 18, 1)	550.000	633.645	2400.000	2049.659	643.323	558.642	2049.699
120.00	(10, 18, 2)	550.000	632.424	2400.000	2049.659	644.423	558.642	2049.699
120.00	(10, 19, 1)	550.000	633.412	2400.000	2049.659	643.221	N/A	N/A
120.00	(10, 19, 2)	550.000	634.270	2400.000	2049.659	643.145	N/A	N/A
120.00	(10, 20, 1)	550.000	634.208	2400.000	2049.659	644.039	N/A	N/A
120.00	(10, 20, 2)	550.000	634.630	2400.000	2049.659	643.866	N/A	N/A
120.00	(10, 21, 1)	550.000	634.563	2400.000	2049.659	644.595	N/A	N/A
120.00	(10, 21, 2)	550.000	633.506	2400.000	2049.659	644.704	N/A	N/A
120.00	(10, 21, 3)	550.000	636.396	2400.000	2049.659	644.852	557.186	2049.700
120.00	(10, 21, 4)	550.000	637.379	2400.000	2049.659	644.570	557.186	2049.700
120.00	(11, 1, 1)	550.000	633.752	2400.000	2049.659	643.357	N/A	N/A
120.00	(11, 1, 2)	550.000	633.192	2400.000	2049.659	642.159	N/A	N/A
120.00	(11, 1, 6)	550.000	635.663	2400.000	2064.307	645.489	N/A	N/A
120.00	(11, 2, 1)	550.000	633.208	2400.000	2049.659	641.911	N/A	N/A
120.00	(11, 2, 2)	550.000	633.434	2400.000	2049.659	641.510	N/A	N/A
120.00	(11, 3, 1)	550.000	632.729	2400.000	2049.659	641.494	N/A	N/A
120.00	(11, 3, 2)	550.000	632.337	2400.000	2049.659	640.942	N/A	N/A
120.00	(11, 4, 1)	550.000	631.804	2400.000	2049.659	640.922	N/A	N/A
120.00	(11, 4, 2)	550.000	631.258	2400.000	2049.659	641.790	558.642	2049.699
120.00	(11, 5, 1)	550.000	631.197	2400.000	2049.659	641.736	558.642	2049.699
120.00	(11, 5, 2)	550.000	634.225	2400.000	2049.659	643.663	558.642	2049.699
120.00	(11, 5, 3)	550.000	634.204	2400.000	2049.659	644.570	558.642	2049.699
120.00	(11, 7, 1)	550.000	632.157	2400.000	2049.659	642.136	558.642	2049.699
120.00	(11, 7, 2)	550.000	632.345	2400.000	2049.659	640.806	N/A	N/A
120.00	(11, 8, 1)	550.000	631.921	2400.000	2049.659	641.094	N/A	N/A
120.00	(11, 8, 2)	550.000	632.506	2400.000	2049.659	640.833	N/A	N/A
120.00	(11, 9, 1)	550.000	632.078	2400.000	2049.659	641.274	N/A	N/A
120.00	(11, 9, 2)	550.000	631.867	2400.000	2049.659	640.976	N/A	N/A
120.00	(11, 10, 1)	550.000	631.616	2400.000	2049.659	641.026	N/A	N/A
120.00	(11, 10, 2)	550.000	631.390	2400.000	2049.659	642.042	558.642	2049.699
120.00	(11, 11, 1)	550.000	630.686	2400.000	2049.659	642.364	558.642	2049.699
120.00	(11, 11, 2)	550.000	634.250	2400.000	2049.659	643.509	558.642	2049.699
120.00	(11, 11, 3)	550.000	633.842	2400.000	2049.659	644.570	558.642	2049.699
120.00	(11, 13, 1)	550.000	632.212	2400.000	2049.659	641.945	558.642	2049.699
120.00	(11, 13, 2)	550.000	632.443	2400.000	2049.659	640.680	N/A	N/A
120.00	(11, 14, 1)	550.000	631.877	2400.000	2049.659	641.065	N/A	N/A
120.00	(11, 14, 2)	550.000	632.497	2400.000	2049.659	640.713	N/A	N/A
120.00	(11, 15, 1)	550.000	631.999	2400.000	2049.659	641.205	N/A	N/A
120.00	(11, 15, 2)	550.000	631.960	2400.000	2049.659	640.899	N/A	N/A
120.00	(11, 16, 1)	550.000	631.800	2400.000	2049.659	641.121	N/A	N/A
120.00	(11, 16, 2)	550.000	631.491	2400.000	2049.659	642.219	558.642	2049.699
120.00	(11, 17, 1)	550.000	631.131	2400.000	2049.659	642.677	558.642	2049.699
120.00	(11, 17, 2)	550.000	634.351	2400.000	2049.659	644.176	558.642	2049.699

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(11, 17, 3)	550.000	634.198	2400.000	2049.659	644.570	558.642	2049.699
120.00	(11, 19, 1)	550.000	634.132	2400.000	2049.659	643.292	558.642	2049.699
120.00	(11, 19, 2)	550.000	633.294	2400.000	2049.659	642.920	N/A	N/A
120.00	(11, 20, 1)	550.000	633.726	2400.000	2049.659	643.129	N/A	N/A
120.00	(11, 20, 2)	550.000	634.539	2400.000	2049.659	643.103	N/A	N/A
120.00	(11, 21, 1)	550.000	635.568	2400.000	2049.659	643.476	N/A	N/A
120.00	(11, 21, 2)	550.000	635.298	2400.000	2049.659	644.508	N/A	N/A
120.00	(11, 22, 1)	550.000	634.849	2400.000	2049.659	644.704	N/A	N/A
120.00	(11, 22, 2)	550.000	633.315	2400.000	2049.659	644.704	N/A	N/A
120.00	(11, 22, 3)	550.000	635.387	2400.000	2049.659	644.852	557.186	2049.700
120.00	(11, 22, 4)	550.000	636.569	2400.000	2049.659	644.570	557.186	2049.700
120.00	(12, 1, 1)	550.000	634.571	2400.000	2064.307	645.489	N/A	N/A
120.00	(12, 1, 2)	550.000	633.452	2400.000	2049.659	643.282	N/A	N/A
120.00	(12, 1, 6)	550.000	634.953	2400.000	2064.307	645.489	N/A	N/A
120.00	(12, 2, 1)	550.000	634.672	2400.000	2049.659	641.627	N/A	N/A
120.00	(12, 2, 2)	550.000	632.882	2400.000	2049.659	642.091	N/A	N/A
120.00	(12, 3, 1)	550.000	632.908	2400.000	2049.659	641.852	N/A	N/A
120.00	(12, 3, 2)	550.000	632.179	2400.000	2049.659	641.345	N/A	N/A
120.00	(12, 4, 1)	550.000	632.394	2400.000	2049.659	640.897	N/A	N/A
120.00	(12, 4, 2)	550.000	631.817	2400.000	2049.659	641.155	N/A	N/A
120.00	(12, 4, 3)	550.000	631.112	2400.000	2049.659	642.015	558.642	2049.699
120.00	(12, 7, 1)	550.000	634.740	2400.000	2064.307	643.978	558.642	2049.699
120.00	(12, 7, 2)	550.000	632.037	2400.000	2064.307	642.322	558.642	2049.699
120.00	(12, 7, 6)	550.000	634.491	2400.000	2064.307	645.088	558.642	2049.699
120.00	(12, 8, 1)	550.000	633.032	2400.000	2049.659	640.707	N/A	N/A
120.00	(12, 8, 2)	550.000	632.095	2400.000	2049.659	641.308	N/A	N/A
120.00	(12, 9, 1)	550.000	632.294	2400.000	2049.659	641.060	N/A	N/A
120.00	(12, 9, 2)	550.000	631.972	2400.000	2049.659	640.970	N/A	N/A
120.00	(12, 10, 1)	550.000	631.996	2400.000	2049.659	640.677	N/A	N/A
120.00	(12, 10, 2)	550.000	631.874	2400.000	2049.659	640.859	N/A	N/A
120.00	(12, 10, 3)	550.000	631.093	2400.000	2049.659	642.026	558.642	2049.699
120.00	(12, 13, 1)	550.000	634.928	2400.000	2064.307	643.811	558.642	2049.699
120.00	(12, 13, 2)	550.000	631.508	2400.000	2064.307	642.376	558.642	2049.699
120.00	(12, 13, 6)	550.000	634.861	2400.000	2064.307	645.067	558.642	2049.699
120.00	(12, 14, 1)	550.000	632.629	2400.000	2049.659	640.652	N/A	N/A
120.00	(12, 14, 2)	550.000	632.118	2400.000	2049.659	641.131	N/A	N/A
120.00	(12, 15, 1)	550.000	632.213	2400.000	2049.659	641.001	N/A	N/A
120.00	(12, 15, 2)	550.000	631.799	2400.000	2049.659	640.836	N/A	N/A
120.00	(12, 16, 1)	550.000	631.796	2400.000	2049.659	640.646	N/A	N/A
120.00	(12, 16, 2)	550.000	631.643	2400.000	2049.659	640.661	N/A	N/A
120.00	(12, 16, 3)	550.000	630.965	2400.000	2049.659	641.959	558.642	2049.699
120.00	(12, 19, 1)	550.000	635.697	2400.000	2064.307	644.829	558.642	2049.699
120.00	(12, 19, 2)	550.000	633.959	2400.000	2064.307	643.318	558.642	2049.699
120.00	(12, 19, 6)	550.000	635.463	2400.000	2064.307	645.489	557.186	2049.700
120.00	(12, 20, 1)	550.000	635.520	2400.000	2049.659	641.929	N/A	N/A
120.00	(12, 20, 2)	550.000	634.983	2400.000	2049.659	643.330	N/A	N/A
120.00	(12, 21, 1)	550.000	635.055	2400.000	2049.659	643.594	N/A	N/A
120.00	(12, 21, 2)	550.000	634.797	2400.000	2049.659	643.708	N/A	N/A
120.00	(12, 22, 1)	550.000	634.873	2400.000	2049.659	643.781	N/A	N/A
120.00	(12, 22, 2)	550.000	634.980	2400.000	2049.659	643.609	N/A	N/A
120.00	(12, 23, 1)	550.000	633.751	2400.000	2049.659	644.529	N/A	N/A
120.00	(12, 23, 2)	550.000	634.238	2400.000	2049.659	644.852	557.186	2049.700

Z (IN.)	CHANNEL NUMBER (KK, L, M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(12, 23, 3)	550.000	635.784	2400.000	2049.659	644.570	557.186	2049.700
120.00	(12, 23, 4)	550.000	637.882	2400.000	2049.659	644.570	557.186	2049.700
120.00	(13, 1, 1)	550.000	633.640	2400.000	2064.307	645.489	N/A	N/A
120.00	(13, 1, 2)	550.000	632.970	2400.000	2049.659	642.964	N/A	N/A
120.00	(13, 2, 1)	550.000	634.158	2400.000	2049.659	641.079	N/A	N/A
120.00	(13, 2, 2)	550.000	632.484	2400.000	2049.659	641.775	N/A	N/A
120.00	(13, 3, 1)	550.000	632.681	2400.000	2049.659	640.950	N/A	N/A
120.00	(13, 3, 2)	550.000	632.417	2400.000	2049.659	641.221	N/A	N/A
120.00	(13, 4, 1)	550.000	632.357	2400.000	2049.659	641.322	N/A	N/A
120.00	(13, 4, 2)	550.000	632.005	2400.000	2049.659	641.690	N/A	N/A
120.00	(13, 4, 4)	550.000	632.257	2400.000	2049.659	642.030	558.642	2049.699
120.00	(13, 5, 1)	550.000	632.845	2400.000	2049.659	641.290	N/A	N/A
120.00	(13, 5, 2)	550.000	632.189	2400.000	2049.659	641.634	N/A	N/A
120.00	(13, 5, 4)	550.000	633.482	2400.000	2049.659	644.234	558.642	2049.699
120.00	(13, 5, 5)	550.000	633.633	2400.000	2049.659	644.570	558.642	2049.699
120.00	(13, 7, 1)	550.000	632.192	2400.000	2049.659	642.110	558.642	2049.699
120.00	(13, 7, 2)	550.000	631.658	2400.000	2049.659	641.393	N/A	N/A
120.00	(13, 8, 1)	550.000	632.546	2400.000	2049.659	641.096	N/A	N/A
120.00	(13, 8, 2)	550.000	632.103	2400.000	2049.659	641.600	N/A	N/A
120.00	(13, 9, 1)	550.000	632.086	2400.000	2049.659	641.016	N/A	N/A
120.00	(13, 9, 2)	550.000	632.185	2400.000	2049.659	641.035	N/A	N/A
120.00	(13, 10, 1)	550.000	632.156	2400.000	2049.659	641.247	N/A	N/A
120.00	(13, 10, 2)	550.000	631.879	2400.000	2049.659	641.518	N/A	N/A
120.00	(13, 10, 4)	550.000	632.190	2400.000	2049.659	641.889	558.642	2049.699
120.00	(13, 11, 1)	550.000	632.807	2400.000	2049.659	641.064	N/A	N/A
120.00	(13, 11, 2)	550.000	632.190	2400.000	2049.659	641.435	N/A	N/A
120.00	(13, 11, 4)	550.000	633.521	2400.000	2049.659	644.055	558.642	2049.699
120.00	(13, 11, 5)	550.000	633.595	2400.000	2049.659	644.570	558.642	2049.699
120.00	(13, 13, 1)	550.000	631.834	2400.000	2049.659	642.160	558.642	2049.699
120.00	(13, 13, 2)	550.000	630.697	2400.000	2049.659	641.466	N/A	N/A
120.00	(13, 14, 1)	550.000	632.357	2400.000	2049.659	640.657	N/A	N/A
120.00	(13, 14, 2)	550.000	632.259	2400.000	2049.659	641.425	N/A	N/A
120.00	(13, 15, 1)	550.000	631.813	2400.000	2049.659	641.074	N/A	N/A
120.00	(13, 15, 2)	550.000	631.662	2400.000	2049.659	640.764	N/A	N/A
120.00	(13, 16, 1)	550.000	632.058	2400.000	2049.659	640.866	N/A	N/A
120.00	(13, 16, 2)	550.000	631.703	2400.000	2049.659	641.422	N/A	N/A
120.00	(13, 16, 4)	550.000	632.295	2400.000	2049.659	641.749	558.642	2049.699
120.00	(13, 17, 1)	550.000	632.745	2400.000	2049.659	640.885	N/A	N/A
120.00	(13, 17, 2)	550.000	632.292	2400.000	2049.659	641.332	N/A	N/A
120.00	(13, 17, 4)	550.000	633.800	2400.000	2049.659	644.228	558.642	2049.699
120.00	(13, 17, 5)	550.000	633.531	2400.000	2049.659	644.570	558.642	2049.699
120.00	(13, 19, 1)	550.000	633.022	2400.000	2049.659	643.490	558.642	2049.699
120.00	(13, 19, 2)	550.000	632.799	2400.000	2049.659	642.469	N/A	N/A
120.00	(13, 20, 1)	550.000	635.015	2400.000	2049.659	642.869	N/A	N/A
120.00	(13, 20, 2)	550.000	633.950	2400.000	2049.659	643.927	N/A	N/A
120.00	(13, 21, 1)	550.000	634.191	2400.000	2049.659	643.265	N/A	N/A
120.00	(13, 21, 2)	550.000	634.326	2400.000	2049.659	642.925	N/A	N/A
120.00	(13, 22, 1)	550.000	633.542	2400.000	2049.659	643.631	N/A	N/A
120.00	(13, 22, 2)	550.000	634.668	2400.000	2049.659	644.285	557.186	2049.700
120.00	(13, 22, 3)	550.000	635.462	2400.000	2049.659	644.570	557.186	2049.700
120.00	(14, 1, 1)	550.000	631.244	2400.000	2064.307	645.489	N/A	N/A
120.00	(14, 1, 2)	550.000	633.180	2400.000	2049.659	643.357	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(14, 2, 1)	550.000	632.781	2400.000	2049.659	641.896	N/A	N/A
120.00	(14, 2, 2)	550.000	632.358	2400.000	2049.659	641.739	N/A	N/A
120.00	(14, 3, 1)	550.000	632.459	2400.000	2049.659	641.492	N/A	N/A
120.00	(14, 3, 2)	550.000	632.670	2400.000	2049.659	641.650	N/A	N/A
120.00	(14, 4, 1)	550.000	632.269	2400.000	2049.659	641.658	N/A	N/A
120.00	(14, 4, 2)	550.000	633.224	2400.000	2049.659	641.566	N/A	N/A
120.00	(14, 5, 1)	550.000	632.319	2400.000	2049.659	641.905	N/A	N/A
120.00	(14, 5, 2)	550.000	632.600	2400.000	2049.659	641.395	N/A	N/A
120.00	(14, 5, 4)	550.000	631.814	2400.000	2049.659	642.131	558.642	2049.699
120.00	(14, 5, 5)	550.000	632.919	2400.000	2049.659	641.935	558.642	2049.699
120.00	(14, 6, 1)	550.000	632.035	2400.000	2049.659	641.269	N/A	N/A
120.00	(14, 6, 2)	550.000	632.185	2400.000	2049.659	641.174	N/A	N/A
120.00	(14, 7, 1)	550.000	632.481	2400.000	2049.659	641.164	N/A	N/A
120.00	(14, 7, 2)	550.000	632.299	2400.000	2049.659	641.651	N/A	N/A
120.00	(14, 8, 1)	550.000	631.700	2400.000	2049.659	641.856	N/A	N/A
120.00	(14, 8, 2)	550.000	632.176	2400.000	2049.659	641.323	N/A	N/A
120.00	(14, 9, 1)	550.000	632.258	2400.000	2049.659	641.233	N/A	N/A
120.00	(14, 9, 2)	550.000	632.487	2400.000	2049.659	641.330	N/A	N/A
120.00	(14, 10, 1)	550.000	631.897	2400.000	2049.659	641.495	N/A	N/A
120.00	(14, 10, 2)	550.000	633.132	2400.000	2049.659	641.217	N/A	N/A
120.00	(14, 11, 1)	550.000	631.984	2400.000	2049.659	641.735	N/A	N/A
120.00	(14, 11, 2)	550.000	632.223	2400.000	2049.659	640.998	N/A	N/A
120.00	(14, 11, 4)	550.000	631.405	2400.000	2049.659	642.066	558.642	2049.699
120.00	(14, 11, 5)	550.000	632.759	2400.000	2049.659	641.822	558.642	2049.699
120.00	(14, 12, 1)	550.000	631.891	2400.000	2049.659	640.999	N/A	N/A
120.00	(14, 12, 2)	550.000	631.881	2400.000	2049.659	641.174	N/A	N/A
120.00	(14, 13, 1)	550.000	631.750	2400.000	2049.659	640.936	N/A	N/A
120.00	(14, 13, 2)	550.000	632.179	2400.000	2049.659	641.405	N/A	N/A
120.00	(14, 14, 1)	550.000	631.444	2400.000	2049.659	641.865	N/A	N/A
120.00	(14, 14, 2)	550.000	631.698	2400.000	2049.659	640.913	N/A	N/A
120.00	(14, 15, 1)	550.000	632.240	2400.000	2049.659	640.720	N/A	N/A
120.00	(14, 15, 2)	550.000	632.409	2400.000	2049.659	641.287	N/A	N/A
120.00	(14, 16, 1)	550.000	631.279	2400.000	2049.659	641.451	N/A	N/A
120.00	(14, 16, 2)	550.000	633.059	2400.000	2049.659	640.837	N/A	N/A
120.00	(14, 17, 1)	550.000	632.204	2400.000	2049.659	641.748	N/A	N/A
120.00	(14, 17, 2)	550.000	631.924	2400.000	2049.659	641.302	N/A	N/A
120.00	(14, 17, 4)	550.000	631.608	2400.000	2049.659	642.786	558.642	2049.699
120.00	(14, 17, 5)	550.000	633.111	2400.000	2049.659	642.001	558.642	2049.699
120.00	(14, 18, 1)	550.000	633.323	2400.000	2049.659	641.067	N/A	N/A
120.00	(14, 18, 2)	550.000	631.763	2400.000	2049.659	642.814	N/A	N/A
120.00	(14, 19, 1)	550.000	633.343	2400.000	2049.659	641.816	N/A	N/A
120.00	(14, 19, 2)	550.000	633.809	2400.000	2049.659	642.810	N/A	N/A
120.00	(14, 20, 1)	550.000	633.814	2400.000	2049.659	643.462	N/A	N/A
120.00	(14, 20, 2)	550.000	633.901	2400.000	2049.659	643.026	N/A	N/A
120.00	(14, 21, 1)	550.000	632.840	2400.000	2049.659	643.096	N/A	N/A
120.00	(14, 21, 2)	550.000	633.193	2400.000	2049.659	643.433	557.186	2049.700
120.00	(14, 21, 3)	550.000	636.152	2400.000	2049.659	644.570	557.186	2049.700
120.00	(15, 1, 1)	550.000	631.174	2400.000	2064.307	645.489	N/A	N/A
120.00	(15, 1, 2)	550.000	633.060	2400.000	2049.659	643.313	N/A	N/A
120.00	(15, 2, 1)	550.000	632.988	2400.000	2049.659	641.769	N/A	N/A
120.00	(15, 2, 2)	550.000	632.810	2400.000	2049.659	641.946	N/A	N/A
120.00	(15, 3, 1)	550.000	632.696	2400.000	2049.659	641.986	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(15, 3,2)	550.000	633.026	2400.000	2049.659	642.073	N/A	N/A
120.00	(15, 4,1)	550.000	632.759	2400.000	2049.659	642.164	N/A	N/A
120.00	(15, 4,2)	550.000	632.740	2400.000	2049.659	641.724	N/A	N/A
120.00	(15, 5,1)	550.000	632.159	2400.000	2049.659	641.738	N/A	N/A
120.00	(15, 5,2)	550.000	632.591	2400.000	2049.659	641.435	N/A	N/A
120.00	(15, 6,1)	550.000	632.416	2400.000	2049.659	641.361	N/A	N/A
120.00	(15, 6,2)	550.000	632.427	2400.000	2049.659	641.405	N/A	N/A
120.00	(15, 7,1)	550.000	632.735	2400.000	2049.659	641.234	N/A	N/A
120.00	(15, 7,2)	550.000	632.597	2400.000	2049.659	641.473	N/A	N/A
120.00	(15, 8,1)	550.000	632.255	2400.000	2049.659	641.648	N/A	N/A
120.00	(15, 8,2)	550.000	631.448	2400.000	2049.659	641.557	N/A	N/A
120.00	(15, 9,1)	550.000	631.835	2400.000	2049.659	641.524	N/A	N/A
120.00	(15, 9,2)	550.000	632.459	2400.000	2049.659	641.644	N/A	N/A
120.00	(15, 10,1)	550.000	632.225	2400.000	2049.659	641.908	N/A	N/A
120.00	(15, 10,2)	550.000	632.428	2400.000	2049.659	641.297	N/A	N/A
120.00	(15, 11,1)	550.000	632.300	2400.000	2049.659	641.229	N/A	N/A
120.00	(15, 11,2)	550.000	632.324	2400.000	2049.659	641.377	N/A	N/A
120.00	(15, 12,1)	550.000	632.014	2400.000	2049.659	641.328	N/A	N/A
120.00	(15, 12,2)	550.000	632.248	2400.000	2049.659	641.206	N/A	N/A
120.00	(15, 13,1)	550.000	632.465	2400.000	2049.659	641.199	N/A	N/A
120.00	(15, 13,2)	550.000	631.980	2400.000	2049.659	641.199	N/A	N/A
120.00	(15, 14,1)	550.000	632.032	2400.000	2049.659	641.126	N/A	N/A
120.00	(15, 14,2)	550.000	631.437	2400.000	2049.659	641.358	N/A	N/A
120.00	(15, 15,1)	550.000	630.924	2400.000	2049.659	641.420	N/A	N/A
120.00	(15, 15,2)	550.000	632.589	2400.000	2049.659	640.740	N/A	N/A
120.00	(15, 16,1)	550.000	632.326	2400.000	2049.659	641.739	N/A	N/A
120.00	(15, 16,2)	550.000	632.510	2400.000	2049.659	641.261	N/A	N/A
120.00	(15, 17,1)	550.000	632.619	2400.000	2049.659	641.167	N/A	N/A
120.00	(15, 17,2)	550.000	632.536	2400.000	2049.659	641.852	N/A	N/A
120.00	(15, 18,1)	550.000	632.555	2400.000	2049.659	642.114	N/A	N/A
120.00	(15, 18,2)	550.000	632.974	2400.000	2049.659	642.521	N/A	N/A
120.00	(15, 19,1)	550.000	633.419	2400.000	2049.659	642.806	N/A	N/A
120.00	(15, 19,2)	550.000	634.069	2400.000	2049.659	642.473	N/A	N/A
120.00	(15, 20,1)	550.000	632.281	2400.000	2049.659	643.143	N/A	N/A
120.00	(15, 20,2)	550.000	633.026	2400.000	2049.659	643.141	N/A	N/A
120.00	(15, 20,3)	550.000	635.430	2400.000	2049.659	644.570	557.186	2049.700
120.00	(16, 1,1)	550.000	631.531	2400.000	2064.307	645.489	N/A	N/A
120.00	(16, 1,2)	550.000	633.134	2400.000	2049.659	643.926	N/A	N/A
120.00	(16, 2,1)	550.000	633.102	2400.000	2049.659	641.962	N/A	N/A
120.00	(16, 2,2)	550.000	633.109	2400.000	2049.659	642.067	N/A	N/A
120.00	(16, 3,1)	550.000	633.241	2400.000	2049.659	642.119	N/A	N/A
120.00	(16, 3,2)	550.000	632.631	2400.000	2049.659	642.203	N/A	N/A
120.00	(16, 4,1)	550.000	633.172	2400.000	2049.659	641.742	N/A	N/A
120.00	(16, 4,2)	550.000	632.666	2400.000	2049.659	642.316	N/A	N/A
120.00	(16, 5,1)	550.000	632.797	2400.000	2049.659	641.855	N/A	N/A
120.00	(16, 5,2)	550.000	632.499	2400.000	2049.659	641.804	N/A	N/A
120.00	(16, 6,1)	550.000	632.233	2400.000	2049.659	641.651	N/A	N/A
120.00	(16, 6,2)	550.000	632.049	2400.000	2049.659	641.521	N/A	N/A
120.00	(16, 7,1)	550.000	631.715	2400.000	2049.659	641.455	N/A	N/A
120.00	(16, 7,2)	550.000	631.995	2400.000	2049.659	642.156	558.642	2049.699
120.00	(16, 8,1)	550.000	632.243	2400.000	2049.659	641.931	558.642	2049.699
120.00	(16, 8,2)	550.000	631.911	2400.000	2049.659	642.560	558.642	2049.699

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(16, 9, 1)	550.000	632.466	2400.000	2049.659	641.640	N/A	N/A
120.00	(16, 9, 2)	550.000	632.145	2400.000	2049.659	641.723	N/A	N/A
120.00	(16, 10, 1)	550.000	632.306	2400.000	2049.659	641.529	N/A	N/A
120.00	(16, 10, 2)	550.000	632.432	2400.000	2049.659	641.618	N/A	N/A
120.00	(16, 11, 1)	550.000	632.587	2400.000	2049.659	641.344	N/A	N/A
120.00	(16, 11, 2)	550.000	631.893	2400.000	2049.659	641.272	N/A	N/A
120.00	(16, 12, 1)	550.000	631.828	2400.000	2049.659	641.373	N/A	N/A
120.00	(16, 12, 2)	550.000	631.535	2400.000	2049.659	641.163	N/A	N/A
120.00	(16, 13, 1)	550.000	631.034	2400.000	2049.659	640.950	N/A	N/A
120.00	(16, 13, 2)	550.000	631.670	2400.000	2049.659	641.555	558.642	2049.699
120.00	(16, 14, 1)	550.000	631.340	2400.000	2049.659	641.796	558.642	2049.699
120.00	(16, 14, 2)	550.000	631.273	2400.000	2049.659	641.720	558.642	2049.699
120.00	(16, 15, 1)	550.000	631.745	2400.000	2049.659	641.327	N/A	N/A
120.00	(16, 15, 2)	550.000	632.081	2400.000	2049.659	641.099	N/A	N/A
120.00	(16, 16, 1)	550.000	632.474	2400.000	2049.659	641.300	N/A	N/A
120.00	(16, 16, 2)	550.000	632.166	2400.000	2049.659	641.691	N/A	N/A
120.00	(16, 17, 1)	550.000	632.616	2400.000	2049.659	641.676	N/A	N/A
120.00	(16, 17, 2)	550.000	633.047	2400.000	2049.659	642.112	N/A	N/A
120.00	(16, 18, 1)	550.000	633.019	2400.000	2049.659	642.436	N/A	N/A
120.00	(16, 18, 2)	550.000	633.684	2400.000	2049.659	642.237	N/A	N/A
120.00	(16, 19, 1)	550.000	632.007	2400.000	2049.659	642.707	N/A	N/A
120.00	(16, 19, 2)	550.000	633.423	2400.000	2049.659	642.526	N/A	N/A
120.00	(16, 19, 3)	550.000	634.435	2400.000	2049.659	644.570	N/A	N/A
120.00	(17, 1, 1)	550.000	630.233	2400.000	2064.307	645.489	N/A	N/A
120.00	(17, 1, 2)	550.000	633.386	2400.000	2049.659	643.704	N/A	N/A
120.00	(17, 2, 1)	550.000	633.396	2400.000	2049.659	642.365	N/A	N/A
120.00	(17, 2, 2)	550.000	633.821	2400.000	2049.659	642.327	N/A	N/A
120.00	(17, 3, 1)	550.000	633.173	2400.000	2049.659	642.139	N/A	N/A
120.00	(17, 3, 2)	550.000	633.443	2400.000	2049.659	642.127	N/A	N/A
120.00	(17, 4, 1)	550.000	633.368	2400.000	2049.659	642.130	N/A	N/A
120.00	(17, 4, 2)	550.000	632.643	2400.000	2049.659	642.182	N/A	N/A
120.00	(17, 5, 1)	550.000	632.974	2400.000	2049.659	641.639	N/A	N/A
120.00	(17, 5, 2)	550.000	632.057	2400.000	2049.659	643.333	558.642	2049.699
120.00	(17, 6, 1)	550.000	631.394	2400.000	2049.659	642.810	558.642	2049.699
120.00	(17, 6, 2)	550.000	634.783	2400.000	2049.659	643.858	558.642	2049.699
120.00	(17, 6, 3)	550.000	634.425	2400.000	2049.659	644.570	558.642	2049.699
120.00	(17, 8, 1)	550.000	633.127	2400.000	2049.659	642.440	558.642	2049.699
120.00	(17, 8, 2)	550.000	633.537	2400.000	2049.659	641.454	N/A	N/A
120.00	(17, 9, 1)	550.000	632.914	2400.000	2049.659	641.451	N/A	N/A
120.00	(17, 9, 2)	550.000	633.299	2400.000	2049.659	641.348	N/A	N/A
120.00	(17, 10, 1)	550.000	632.573	2400.000	2049.659	641.728	N/A	N/A
120.00	(17, 10, 2)	550.000	632.340	2400.000	2049.659	641.236	N/A	N/A
120.00	(17, 11, 1)	550.000	632.674	2400.000	2049.659	640.640	N/A	N/A
120.00	(17, 11, 2)	550.000	631.730	2400.000	2049.659	642.517	558.642	2049.699
120.00	(17, 12, 1)	550.000	630.665	2400.000	2049.659	642.361	558.642	2049.699
120.00	(17, 12, 2)	550.000	633.991	2400.000	2049.659	643.157	558.642	2049.699
120.00	(17, 12, 3)	550.000	634.027	2400.000	2049.659	644.374	558.642	2049.699
120.00	(17, 14, 1)	550.000	632.938	2400.000	2049.659	641.265	558.642	2049.699
120.00	(17, 14, 2)	550.000	632.446	2400.000	2049.659	640.357	N/A	N/A
120.00	(17, 15, 1)	550.000	632.991	2400.000	2049.659	640.767	N/A	N/A
120.00	(17, 15, 2)	550.000	632.263	2400.000	2049.659	641.489	N/A	N/A
120.00	(17, 16, 1)	550.000	632.730	2400.000	2049.659	641.460	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (-DEGREES F)	VOID PRES (PSIA)
120.00	(17, 16, 2)	550.000	633.028	2400.000	2049.659	642.161	N/A	N/A
120.00	(17, 17, 1)	550.000	633.335	2400.000	2049.659	642.236	N/A	N/A
120.00	(17, 17, 2)	550.000	633.699	2400.000	2049.659	642.315	N/A	N/A
120.00	(17, 18, 1)	550.000	632.108	2400.000	2049.659	642.621	N/A	N/A
120.00	(17, 18, 2)	550.000	632.898	2400.000	2049.659	642.696	N/A	N/A
120.00	(17, 18, 3)	550.000	635.097	2400.000	2049.659	644.570	N/A	N/A
120.00	(18, 1, 1)	550.000	631.928	2400.000	2064.307	645.489	N/A	N/A
120.00	(18, 1, 2)	550.000	633.580	2400.000	2049.659	644.636	N/A	N/A
120.00	(18, 2, 1)	550.000	633.383	2400.000	2049.659	643.080	N/A	N/A
120.00	(18, 2, 2)	550.000	633.214	2400.000	2049.659	642.888	N/A	N/A
120.00	(18, 3, 1)	550.000	633.160	2400.000	2049.659	642.600	N/A	N/A
120.00	(18, 3, 2)	550.000	633.194	2400.000	2049.659	642.405	N/A	N/A
120.00	(18, 4, 1)	550.000	632.873	2400.000	2049.659	642.140	N/A	N/A
120.00	(18, 4, 2)	550.000	633.318	2400.000	2049.659	642.196	N/A	N/A
120.00	(18, 4, 3)	550.000	631.898	2400.000	2049.659	643.470	558.642	2049.699
120.00	(18, 7, 1)	550.000	634.830	2400.000	2064.307	645.172	558.642	2049.699
120.00	(18, 7, 2)	550.000	634.497	2400.000	2064.307	642.170	N/A	N/A
120.00	(18, 7, 6)	550.000	635.123	2400.000	2064.307	645.489	558.642	2049.699
120.00	(18, 8, 1)	550.000	634.105	2400.000	2049.659	642.099	N/A	N/A
120.00	(18, 8, 2)	550.000	633.308	2400.000	2049.659	641.863	N/A	N/A
120.00	(18, 9, 1)	550.000	633.447	2400.000	2049.659	641.728	N/A	N/A
120.00	(18, 9, 2)	550.000	632.840	2400.000	2049.659	641.787	N/A	N/A
120.00	(18, 10, 1)	550.000	632.483	2400.000	2049.659	641.801	N/A	N/A
120.00	(18, 10, 2)	550.000	632.453	2400.000	2049.659	642.139	N/A	N/A
120.00	(18, 10, 3)	550.000	631.769	2400.000	2049.659	642.682	558.642	2049.699
120.00	(18, 13, 1)	550.000	634.153	2400.000	2064.307	643.774	558.642	2049.699
120.00	(18, 13, 2)	550.000	632.290	2400.000	2064.307	641.601	558.642	2049.699
120.00	(18, 13, 6)	550.000	633.949	2400.000	2064.307	645.489	558.642	2049.699
120.00	(18, 14, 1)	550.000	634.101	2400.000	2049.659	640.036	N/A	N/A
120.00	(18, 14, 2)	550.000	632.112	2400.000	2049.659	641.678	N/A	N/A
120.00	(18, 15, 1)	550.000	633.155	2400.000	2049.659	641.263	N/A	N/A
120.00	(18, 15, 2)	550.000	633.058	2400.000	2049.659	642.253	N/A	N/A
120.00	(18, 16, 1)	550.000	633.159	2400.000	2049.659	642.392	N/A	N/A
120.00	(18, 16, 2)	550.000	633.598	2400.000	2049.659	642.280	N/A	N/A
120.00	(18, 17, 1)	550.000	632.237	2400.000	2049.659	642.645	N/A	N/A
120.00	(18, 17, 2)	550.000	633.078	2400.000	2049.659	642.880	N/A	N/A
120.00	(18, 17, 3)	550.000	635.203	2400.000	2049.659	644.570	N/A	N/A
120.00	(19, 1, 1)	550.000	632.546	2400.000	2064.307	645.489	N/A	N/A
120.00	(19, 1, 2)	550.000	634.134	2400.000	2049.659	643.846	N/A	N/A
120.00	(19, 2, 1)	550.000	634.123	2400.000	2049.659	642.755	N/A	N/A
120.00	(19, 2, 2)	550.000	634.130	2400.000	2049.659	643.046	N/A	N/A
120.00	(19, 3, 1)	550.000	633.698	2400.000	2049.659	642.651	N/A	N/A
120.00	(19, 3, 2)	550.000	633.709	2400.000	2049.659	642.607	N/A	N/A
120.00	(19, 4, 1)	550.000	633.206	2400.000	2049.659	642.771	N/A	N/A
120.00	(19, 4, 2)	550.000	633.048	2400.000	2049.659	642.688	N/A	N/A
120.00	(19, 4, 4)	550.000	633.181	2400.000	2049.659	643.037	558.642	2049.699
120.00	(19, 5, 1)	550.000	633.459	2400.000	2049.659	642.424	N/A	N/A
120.00	(19, 5, 2)	550.000	633.624	2400.000	2049.659	642.542	N/A	N/A
120.00	(19, 5, 3)	550.000	632.460	2400.000	2049.659	644.112	558.642	2049.699
120.00	(19, 5, 4)	550.000	635.199	2400.000	2049.659	644.570	558.642	2049.699
120.00	(19, 5, 5)	550.000	635.655	2400.000	2049.659	644.570	558.642	2049.699
120.00	(19, 7, 1)	550.000	633.946	2400.000	2049.659	643.403	558.642	2049.699

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(19, 7,2)	550.000	633.068	2400.000	2049.659	642.112	N/A	N/A
120.00	(19, 8,1)	550.000	633.838	2400.000	2049.659	641.719	N/A	N/A
120.00	(19, 8,2)	550.000	633.101	2400.000	2049.659	642.307	N/A	N/A
120.00	(19, 9,1)	550.000	633.523	2400.000	2049.659	641.505	N/A	N/A
120.00	(19, 9,2)	550.000	632.590	2400.000	2049.659	641.979	N/A	N/A
120.00	(19, 10,1)	550.000	633.235	2400.000	2049.659	641.732	N/A	N/A
120.00	(19, 10,2)	550.000	632.020	2400.000	2049.659	642.455	N/A	N/A
120.00	(19, 10,4)	550.000	632.393	2400.000	2049.659	642.673	558.642	2049.699
120.00	(19, 11,1)	550.000	633.058	2400.000	2049.659	641.515	N/A	N/A
120.00	(19, 11,2)	550.000	632.970	2400.000	2049.659	641.801	N/A	N/A
120.00	(19, 11,3)	550.000	631.456	2400.000	2049.659	642.923	558.642	2049.699
120.00	(19, 11,4)	550.000	634.743	2400.000	2049.659	644.037	558.642	2049.699
120.00	(19, 11,5)	550.000	634.834	2400.000	2049.659	644.570	558.642	2049.699
120.00	(19, 13,1)	550.000	631.975	2400.000	2049.659	642.273	558.642	2049.699
120.00	(19, 13,2)	550.000	631.250	2400.000	2049.659	641.550	N/A	N/A
120.00	(19, 14,1)	550.000	632.960	2400.000	2049.659	641.043	N/A	N/A
120.00	(19, 14,2)	550.000	632.631	2400.000	2049.659	642.339	N/A	N/A
120.00	(19, 15,1)	550.000	633.066	2400.000	2049.659	642.266	N/A	N/A
120.00	(19, 15,2)	550.000	633.459	2400.000	2049.659	642.172	N/A	N/A
120.00	(19, 16,1)	550.000	632.108	2400.000	2049.659	642.602	N/A	N/A
120.00	(19, 16,2)	550.000	633.113	2400.000	2049.659	642.890	N/A	N/A
120.00	(19, 16,3)	550.000	634.580	2400.000	2049.659	644.570	N/A	N/A
120.00	(20, 1,1)	550.000	631.411	2400.000	2064.307	645.489	557.186	2049.700
120.00	(20, 1,2)	550.000	635.025	2400.000	2049.659	644.152	557.186	2049.700
120.00	(20, 2,1)	550.000	634.556	2400.000	2049.659	643.390	N/A	N/A
120.00	(20, 2,2)	550.000	634.132	2400.000	2049.659	643.187	N/A	N/A
120.00	(20, 3,1)	550.000	634.000	2400.000	2049.659	642.677	N/A	N/A
120.00	(20, 3,2)	550.000	634.288	2400.000	2049.659	642.831	N/A	N/A
120.00	(20, 4,1)	550.000	633.761	2400.000	2049.659	642.583	N/A	N/A
120.00	(20, 4,2)	550.000	633.845	2400.000	2049.659	642.639	N/A	N/A
120.00	(20, 5,1)	550.000	633.812	2400.000	2049.659	642.435	N/A	N/A
120.00	(20, 5,2)	550.000	633.710	2400.000	2049.659	642.516	N/A	N/A
120.00	(20, 5,4)	550.000	633.285	2400.000	2049.659	643.710	558.642	2049.699
120.00	(20, 6,1)	550.000	633.760	2400.000	2049.659	642.419	N/A	N/A
120.00	(20, 6,2)	550.000	633.388	2400.000	2049.659	642.463	N/A	N/A
120.00	(20, 7,1)	550.000	633.345	2400.000	2049.659	642.087	N/A	N/A
120.00	(20, 7,2)	550.000	633.852	2400.000	2049.659	642.169	N/A	N/A
120.00	(20, 8,1)	550.000	632.814	2400.000	2049.659	642.650	N/A	N/A
120.00	(20, 8,2)	550.000	632.946	2400.000	2049.659	641.998	N/A	N/A
120.00	(20, 9,1)	550.000	633.319	2400.000	2049.659	641.910	N/A	N/A
120.00	(20, 9,2)	550.000	633.068	2400.000	2049.659	642.484	N/A	N/A
120.00	(20, 10,1)	550.000	632.614	2400.000	2049.659	642.132	N/A	N/A
120.00	(20, 10,2)	550.000	633.052	2400.000	2049.659	642.034	N/A	N/A
120.00	(20, 11,1)	550.000	632.198	2400.000	2049.659	642.161	N/A	N/A
120.00	(20, 11,2)	550.000	632.633	2400.000	2049.659	641.243	N/A	N/A
120.00	(20, 11,4)	550.000	632.343	2400.000	2049.659	642.192	558.642	2049.699
120.00	(20, 12,1)	550.000	632.500	2400.000	2049.659	641.439	N/A	N/A
120.00	(20, 12,2)	550.000	632.350	2400.000	2049.659	641.640	N/A	N/A
120.00	(20, 13,1)	550.000	632.814	2400.000	2049.659	641.239	N/A	N/A
120.00	(20, 13,2)	550.000	632.552	2400.000	2049.659	642.390	N/A	N/A
120.00	(20, 14,1)	550.000	633.151	2400.000	2049.659	642.219	N/A	N/A
120.00	(20, 14,2)	550.000	633.258	2400.000	2049.659	642.430	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(20,15,1)	550.000	631.965	2400.000	2049.659	642.528	N/A	N/A
120.00	(20,15,2)	550.000	632.798	2400.000	2049.659	642.784	N/A	N/A
120.00	(20,15,3)	550.000	634.876	2400.000	2049.659	644.570	N/A	N/A
120.00	(21,1,1)	550.000	631.923	2400.000	2064.307	645.489	557.186	2049.700
120.00	(21,1,2)	550.000	634.570	2400.000	2049.659	644.108	557.186	2049.700
120.00	(21,2,1)	550.000	634.319	2400.000	2049.659	643.388	N/A	N/A
120.00	(21,2,2)	550.000	634.451	2400.000	2049.659	643.586	N/A	N/A
120.00	(21,3,1)	550.000	634.185	2400.000	2049.659	643.733	N/A	N/A
120.00	(21,3,2)	550.000	634.421	2400.000	2049.659	643.617	N/A	N/A
120.00	(21,4,1)	550.000	634.110	2400.000	2049.659	643.225	N/A	N/A
120.00	(21,4,2)	550.000	633.918	2400.000	2049.659	643.186	N/A	N/A
120.00	(21,5,1)	550.000	633.874	2400.000	2049.659	642.818	N/A	N/A
120.00	(21,5,2)	550.000	633.744	2400.000	2049.659	642.820	N/A	N/A
120.00	(21,6,1)	550.000	633.477	2400.000	2049.659	642.694	N/A	N/A
120.00	(21,6,2)	550.000	633.433	2400.000	2049.659	642.656	N/A	N/A
120.00	(21,7,1)	550.000	633.652	2400.000	2049.659	642.436	N/A	N/A
120.00	(21,7,2)	550.000	633.214	2400.000	2049.659	642.374	N/A	N/A
120.00	(21,8,1)	550.000	633.079	2400.000	2049.659	642.222	N/A	N/A
120.00	(21,8,2)	550.000	633.289	2400.000	2049.659	642.343	N/A	N/A
120.00	(21,9,1)	550.000	632.779	2400.000	2049.659	642.549	N/A	N/A
120.00	(21,9,2)	550.000	633.188	2400.000	2049.659	642.206	N/A	N/A
120.00	(21,10,1)	550.000	633.236	2400.000	2049.659	642.296	N/A	N/A
120.00	(21,10,2)	550.000	632.594	2400.000	2049.659	642.238	N/A	N/A
120.00	(21,11,1)	550.000	632.435	2400.000	2049.659	641.612	N/A	N/A
120.00	(21,11,2)	550.000	632.846	2400.000	2049.659	641.623	N/A	N/A
120.00	(21,12,1)	550.000	632.881	2400.000	2049.659	641.858	N/A	N/A
120.00	(21,12,2)	550.000	633.003	2400.000	2049.659	642.264	N/A	N/A
120.00	(21,13,1)	550.000	633.349	2400.000	2049.659	642.196	N/A	N/A
120.00	(21,13,2)	550.000	633.555	2400.000	2049.659	642.543	N/A	N/A
120.00	(21,14,1)	550.000	632.208	2400.000	2049.659	642.713	N/A	N/A
120.00	(21,14,2)	550.000	633.009	2400.000	2049.659	643.121	N/A	N/A
120.00	(21,14,3)	550.000	634.704	2400.000	2049.659	644.570	N/A	N/A
120.00	(22,1,1)	550.000	633.911	2400.000	2064.307	645.489	557.186	2049.700
120.00	(22,1,2)	550.000	633.246	2400.000	2049.659	644.852	557.186	2049.700
120.00	(22,2,1)	550.000	634.659	2400.000	2049.659	643.454	N/A	N/A
120.00	(22,2,2)	550.000	634.401	2400.000	2049.659	643.912	N/A	N/A
120.00	(22,3,1)	550.000	634.496	2400.000	2049.659	643.840	N/A	N/A
120.00	(22,3,2)	550.000	633.964	2400.000	2049.659	643.744	N/A	N/A
120.00	(22,4,1)	550.000	634.189	2400.000	2049.659	643.307	N/A	N/A
120.00	(22,4,2)	550.000	633.703	2400.000	2049.659	643.526	N/A	N/A
120.00	(22,5,1)	550.000	633.792	2400.000	2049.659	642.931	N/A	N/A
120.00	(22,5,2)	550.000	633.326	2400.000	2049.659	642.954	N/A	N/A
120.00	(22,6,1)	550.000	633.415	2400.000	2049.659	642.788	N/A	N/A
120.00	(22,6,2)	550.000	633.379	2400.000	2049.659	642.823	N/A	N/A
120.00	(22,7,1)	550.000	633.691	2400.000	2049.659	642.317	N/A	N/A
120.00	(22,7,2)	550.000	633.151	2400.000	2049.659	642.678	N/A	N/A
120.00	(22,8,1)	550.000	633.097	2400.000	2049.659	642.301	N/A	N/A
120.00	(22,8,2)	550.000	633.055	2400.000	2049.659	642.160	N/A	N/A
120.00	(22,9,1)	550.000	632.955	2400.000	2049.659	642.363	N/A	N/A
120.00	(22,9,2)	550.000	632.990	2400.000	2049.659	642.165	N/A	N/A
120.00	(22,10,1)	550.000	632.583	2400.000	2049.659	642.068	N/A	N/A
120.00	(22,10,2)	550.000	632.696	2400.000	2049.659	641.936	N/A	N/A

Z (IN.)	CHANNEL NUMBER (KK, L,M)	INLET TEMP (DEGREES F)	OUTLET TEMP (DEGREES F)	INLET PRES (PSIA)	OUTLET PRES (PSIA)	CLAD TEMP (DEGREES F)	VOID TEMP (DEGREES F)	VOID PRES (PSIA)
120.00	(22, 11, 1)	550.000	632.497	2400.000	2049.659	641.931	N/A	N/A
120.00	(22, 11, 2)	550.000	632.732	2400.000	2049.659	641.778	N/A	N/A
120.00	(22, 12, 1)	550.000	632.775	2400.000	2049.659	642.260	N/A	N/A
120.00	(22, 12, 2)	550.000	633.662	2400.000	2049.659	642.248	N/A	N/A
120.00	(22, 13, 1)	550.000	632.063	2400.000	2049.659	642.883	N/A	N/A
120.00	(22, 13, 2)	550.000	633.652	2400.000	2049.659	643.089	N/A	N/A
120.00	(22, 13, 3)	550.000	635.197	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 1, 1)	550.000	637.847	2400.000	2064.307	645.489	557.186	2049.700
120.00	(23, 1, 2)	550.000	635.500	2400.000	2064.307	645.489	557.186	2049.700
120.00	(23, 2, 1)	550.000	635.818	2400.000	2049.659	644.852	557.186	2049.700
120.00	(23, 2, 2)	550.000	633.416	2400.000	2049.659	644.570	557.186	2049.700
120.00	(23, 3, 1)	550.000	634.304	2400.000	2049.659	644.722	557.186	2049.700
120.00	(23, 3, 2)	550.000	632.874	2400.000	2049.659	644.570	557.186	2049.700
120.00	(23, 4, 1)	550.000	634.114	2400.000	2049.659	644.731	557.186	2049.700
120.00	(23, 4, 2)	550.000	631.512	2400.000	2049.659	644.570	557.186	2049.700
120.00	(23, 5, 1)	550.000	633.907	2400.000	2049.659	644.019	N/A	N/A
120.00	(23, 5, 2)	550.000	631.968	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 6, 1)	550.000	633.395	2400.000	2049.659	644.409	N/A	N/A
120.00	(23, 6, 2)	550.000	631.976	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 7, 1)	550.000	633.722	2400.000	2049.659	643.925	N/A	N/A
120.00	(23, 7, 2)	550.000	630.726	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 8, 1)	550.000	633.499	2400.000	2049.659	643.396	N/A	N/A
120.00	(23, 8, 2)	550.000	631.198	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 9, 1)	550.000	633.215	2400.000	2049.659	643.433	N/A	N/A
120.00	(23, 9, 2)	550.000	631.352	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 10, 1)	550.000	632.932	2400.000	2049.659	643.332	N/A	N/A
120.00	(23, 10, 2)	550.000	630.490	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 11, 1)	550.000	633.538	2400.000	2049.659	642.846	N/A	N/A
120.00	(23, 11, 2)	550.000	631.798	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 12, 1)	550.000	631.941	2400.000	2049.659	643.910	N/A	N/A
120.00	(23, 12, 2)	550.000	633.909	2400.000	2049.659	644.570	N/A	N/A
120.00	(23, 12, 3)	550.000	634.793	2400.000	2049.659	644.570	N/A	N/A

**The vita has been removed from
the scanned document**

THERMAL-HYDRAULIC ANALYSIS OF A
SPECTRAL SHIFT REACTOR

by

Brian Damiano

(ABSTRACT)

A computer program has been developed which performs a thermal-hydraulic analysis of a mechanical spectral shift reactor fuel assembly. In this reactor type, the fuel to water volume ratio is changed to shift the neutron energy spectrum and control reactivity. The ability to handle different fuel to water ratios is the unique feature of this program.

The required input parameters are the coolant inlet pressure and temperature, the mass flow rates, and the power density. The cladding temperature and the coolant pressure and temperature are calculated throughout the fuel assembly.

Three test cases were performed using a conceptual reactor core design. The fuel to water ratio of this design can be varied from 1.25 to 0.75 by removing blank rods from the core. Each fuel assembly is enclosed in a hex can. The fuel assembly flowrates can be independently selected.

The test case results indicate that proper flowrate selection can produce equal fuel assembly enthalpy gains. The maximum allowable pressure drop determines the maximum coolant flowrate and the maximum

power density variation between fuel assemblies. The coolant exit properties are relatively unaffected by changing the fuel to water ratio. This indicates that little heat is transferred into the moderator regions that are formed when void rods are removed.

The most useful program modification would be the addition of a routine that defines the coolant channel parameters for any fuel assembly.